

INTORSURA BUZAUULI, Romania

WMO: 152610

Lat: 45.6683N

Lon: 26.0567E

Elev: 708

StdP: 93.10

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.6	-16.7	-22.8	0.5	-21.1	-18.5	0.8	-16.0	14.2	-0.9	12.3	-0.9	0.2	0	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	28.2	19.5	26.8	18.9	25.4	18.2	21.1	25.6	20.0	24.7	19.1	23.8	2.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	15.7	23.0	18.5	14.5	22.1	17.5	13.6	21.2	64.5	25.9	60.7	24.9	57.5	23.8	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	7.7	6.4	-26.9	30.4	4.4	1.5	-30.1	31.5	-32.7	32.4	-35.2	33.2	-38.4	34.3		
(5)			-27.0	23.1	4.4	1.7	-30.2	24.3	-32.8	25.3	-35.3	26.3	-38.6	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-3.9	-1.2	2.1	7.5	12.3	16.4	17.6	17.3	12.8	7.8	2.8	-3.0		
	DBStd	8.70	5.52	5.31	4.48	4.17	3.08	2.69	2.47	2.57	3.62	3.75	4.75	5.99		
	HDD10.0	1822	430	315	245	94	14	1	0	0	15	86	219	403		
	HDD18.3	4029	688	548	502	327	187	67	42	50	166	326	466	661		
	CDD10.0	884	0	0	1	18	87	194	237	226	100	19	3	0		
	CDD18.3	48	0	0	0	0	0	10	20	17	1	0	0	0		
	CDH23.3	851	0	0	0	2	33	174	273	303	64	2	0	0		
	CDH26.7	134	0	0	0	0	2	22	43	60	7	0	0	0		
(14) Wind	WSAvg	2.1	2.1	2.3	2.4	2.5	2.2	2.0	1.8	1.5	1.9	2.1	2.3	2.0		
(15) Precipitation	PrecAvg	672	31	26	34	57	83	103	95	78	55	47	32	33		
	PrecMax	916	61	50	68	118	180	174	199	146	117	101	78	73		
	PrecMin	435	6	3	7	18	31	43	36	25	9	1	1	9		
	PrecStd	117	16	12	15	28	40	40	43	36	27	27	18	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	15.2	18.3	23.2	26.3	29.0	29.5	30.2	27.6	23.1	18.2	9.9		
		MCWB	5.9	9.2	10.2	13.2	16.4	20.7	21.1	19.9	17.4	15.2	12.0	7.4		
	2%	DB	6.0	10.9	14.7	20.8	23.9	26.9	27.8	28.3	25.3	21.0	15.0	7.3		
		MCWB	4.0	6.9	8.7	12.8	15.4	19.6	20.2	18.9	16.8	14.0	10.3	5.4		
	5%	DB	4.1	8.1	12.0	18.3	22.0	25.3	26.5	26.8	23.2	18.2	12.4	5.2		
		MCWB	2.7	4.7	7.2	11.7	15.1	18.6	19.4	18.3	16.0	13.0	9.2	3.8		
	10%	DB	2.5	5.7	9.3	15.8	20.1	23.8	24.7	24.8	21.0	15.2	10.1	3.4		
		MCWB	1.5	3.4	5.7	10.3	14.3	18.0	18.6	17.9	15.2	11.8	8.0	2.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	9.3	11.1	14.5	18.8	22.2	23.0	21.6	18.6	17.3	12.5	8.0		
		MCDB	8.2	14.1	17.2	20.8	24.3	26.5	27.2	26.2	25.4	20.4	16.8	9.4		
	2%	WB	4.3	6.9	9.0	13.3	16.8	20.7	21.2	20.5	17.5	15.0	11.1	5.4		
		MCDB	5.7	10.4	14.1	19.1	21.1	25.0	25.8	25.1	23.2	19.2	14.5	6.9		
	5%	WB	2.8	5.2	7.6	12.2	15.8	19.7	20.0	19.4	16.5	13.5	9.6	4.0		
		MCDB	3.8	7.5	11.4	17.3	20.3	23.9	25.1	24.5	21.8	17.3	12.1	5.1		
	10%	WB	1.7	3.8	6.1	10.9	14.8	18.7	19.0	18.5	15.6	12.0	8.1	2.7		
		MCDB	2.4	5.5	8.8	14.9	19.2	22.8	23.5	23.6	20.1	14.7	10.0	3.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	10.2	10.1	11.4	12.1	12.2	11.8	13.4	12.2	11.7	9.1	7.8		
		MCDBR	9.4	13.7	15.6	17.5	16.9	15.5	15.8	17.6	17.4	18.7	14.7	9.8		
		MCWBR	7.0	9.5	9.6	9.8	9.2	8.6	8.3	8.7	9.2	12.0	9.8	7.5		
		MCDBR	8.1	12.9	14.5	15.5	14.6	14.3	14.1	14.5	15.6	16.3	13.7	8.7		
	5% WB	MCWBR	6.5	9.0	9.4	9.2	8.8	9.0	8.2	8.2	8.6	10.8	9.4	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.299	0.328	0.369	0.428	0.406	0.406	0.422	0.435	0.391	0.355	0.328	0.300		
	taud		2.347	2.268	2.233	2.112	2.246	2.279	2.240	2.198	2.292	2.385	2.410	2.380		
	Ebn at Noon		801	840	852	828	862	862	842	813	820	802	760	759		
	Edh at Noon		76	100	120	148	134	130	134	134	112	89	72	67		
(44) All-Sky Solar Radiation	RadAvg		1.33	2.15	3.27	4.37	5.44	5.81	5.90	5.35	3.89	2.60	1.46	1.09		
	RadStd		0.15	0.26	0.34	0.46	0.48	0.48	0.47	0.41	0.37	0.31	0.14	0.13		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (70 neighbors)	+0.57	N/A	N/A	+0.64	N/A	N/A	-121	-165	+70	+23

Nomenclature: See separate page