

LACAUTI, Romania

WMO: 152620

Lat: 45.8239N

Lon: 26.3756E

Elev: 5833

StdP: 11.85

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.6	1.7	-14.7	3.1	18.3	-7.2	4.6	11.1	62.5	14.2	54.2	14.7	19.1	290	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	68.3	57.1	65.3	55.3	62.8	54.2	59.7	65.6	57.7	62.8	56.3	61.0	8.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.6	88.3	61.3	55.9	82.7	59.6	54.3	78.0	58.3	29.1	65.6	27.6	63.0	26.5	61.3	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.7	36.8	30.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.4	18.4	21.9	25.2	33.5	43.5	50.9	53.1	53.6	45.0	38.4	31.4	21.3		
	DBStd	15.01	9.50	9.36	9.05	9.89	6.85	6.44	6.02	6.53	8.99	9.80	9.42	9.02		
	HDD50	5424	978	786	770	498	222	67	37	42	201	376	559	888		
	HDD65	10434	1443	1206	1235	945	667	426	369	355	601	825	1009	1353		
	CDD50	471	0	0	0	3	20	93	134	154	51	16	0	0		
	CDD65	4	0	0	0	0	0	1	1	1	0	0	0	0		
	CDH74	6	0	0	0	0	0	3	2	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	14.3	17.4	17.2	15.8	14.0	12.3	11.7	11.9	10.1	13.8	14.3	15.4	17.6		
	PrecAvg	26.3	1.1	1.0	1.4	2.2	3.3	4.0	3.7	3.2	2.1	1.7	1.1	1.3		
(15) Precipitation	PrecMax	37.6	2.6	2.2	2.8	3.9	6.9	7.0	7.3	6.9	5.4	4.1	2.3	2.4		
	PrecMin	16.3	0.2	0.2	0.2	0.6	1.5	1.3	1.2	1.1	0.4	0.1	0.0	0.3		
	PrecStd	4.7	0.6	0.5	0.6	0.9	1.6	1.8	1.7	1.5	1.1	1.0	0.6	0.6		
	PrecStd	4.7	0.6	0.5	0.6	0.9	1.6	1.8	1.7	1.5	1.1	1.0	0.6	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.5	44.5	50.3	58.3	64.5	71.8	72.3	71.7	69.8	63.2	53.4	44.1		
		MCWB	30.5	37.9	39.4	46.3	50.8	56.8	60.3	59.4	58.5	46.1	42.3	31.9		
	2%	DB	35.0	40.6	45.8	53.5	59.2	65.8	67.8	67.6	63.6	58.6	49.6	37.4		
		MCWB	30.5	35.7	37.2	43.3	49.1	55.5	57.4	57.1	54.1	46.0	38.1	33.2		
	5%	DB	32.8	35.8	41.6	49.9	56.1	62.7	64.4	64.4	60.0	54.8	46.6	34.7		
		MCWB	30.1	31.2	35.1	41.5	48.2	54.5	55.5	55.6	51.9	43.9	37.7	32.1		
	10%	DB	30.1	33.3	37.0	46.1	53.1	60.0	61.6	61.7	56.8	51.4	43.7	32.4		
		MCWB	27.8	30.4	32.9	39.7	46.5	53.2	54.3	54.4	50.1	43.4	37.5	30.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.9	40.3	41.1	47.5	53.0	61.1	62.3	61.1	60.2	51.5	46.2	36.3		
		MCDB	36.1	43.6	49.4	56.2	58.8	66.6	68.0	67.5	66.9	59.5	51.0	38.1		
	2%	WB	32.5	36.6	38.5	45.2	50.8	57.8	59.6	59.3	56.8	48.7	42.6	34.3		
		MCDB	34.1	40.2	44.6	51.7	56.0	62.8	65.1	65.8	61.9	54.0	45.8	36.4		
	5%	WB	30.5	33.0	36.1	43.1	48.9	56.0	57.4	57.4	52.9	46.7	40.8	32.6		
		MCDB	32.2	35.2	40.5	48.7	54.3	61.0	62.3	62.5	58.7	52.7	44.4	34.7		
	10%	WB	28.4	31.1	33.4	40.9	47.4	54.4	55.9	55.9	51.0	44.6	38.7	30.6		
		MCDB	29.9	32.9	37.0	45.8	52.2	58.8	60.0	60.5	56.0	50.0	41.6	32.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.2	10.0	10.7	10.5	11.8	11.3	10.7	9.7	10.0	8.5	8.1		
		MCDBR	9.2	11.4	15.3	15.7	13.9	15.1	14.7	13.1	13.4	13.3	11.5	9.5		
		MCWBR	6.8	8.1	9.2	9.5	8.6	9.3	10.0	8.2	9.1	8.8	7.4	7.4		
		MCDBR	8.3	9.3	12.3	13.9	13.1	13.1	13.2	12.5	12.1	13.0	9.7	8.1		
	5% WB	MCWBR	6.9	7.5	8.7	9.2	8.7	9.0	9.8	8.5	9.2	9.0	7.6	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.253	0.276	0.307	0.352	0.336	0.336	0.348	0.357	0.325	0.298	0.278	0.254		
	taud		2.437	2.391	2.396	2.312	2.402	2.414	2.375	2.347	2.427	2.505	2.522	2.467		
	Ebn at Noon		277	290	294	287	295	294	289	282	284	278	266	265		
	Edh at Noon		22	28	32	38	36	36	37	36	31	24	20	19		
(44) All-Sky Solar Radiation	RadAvg		412	669	1033	1400	1766	1871	1901	1723	1245	814	447	340		
	RadStd		50	80	107	141	150	152	149	126	117	94	43	40		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)	+1.08	N/A	N/A	+1.15	N/A	N/A	-230	-310	+135	+43

Nomenclature: See separate page