

FOCSANI, Romania

WMO: 152640

Lat: 45.6875N

Lon: 27.1997E

Elev: 58

StdP: 100.63

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.6	-14.8	1.0	-9.8	-12.5	1.3	-7.9	14.3	-4.1	11.9	-3.3	1.7	320	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	33.8	21.2	32.2	20.8	30.7	20.3	23.0	30.9	22.2	29.8	21.4	28.4	2.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.3	25.7	19.7	14.5	25.1	19.0	13.9	24.4	68.1	30.5	65.1	29.6	62.3	28.7	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.1	6.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	-2.4	1.9	6.4	11.5	17.9	22.1	23.2	23.3	18.3	11.7	6.8	0.8		
	DBStd	9.61	4.29	4.96	4.65	4.23	3.23	2.89	2.54	3.17	4.19	4.10	4.11	4.23		
	HDD10.0	1202	384	227	127	34	1	0	0	0	1	30	114	284		
	HDD18.3	2886	642	459	371	208	47	4	1	3	55	207	347	542		
	CDD10.0	1870	0	2	14	78	244	363	409	412	248	83	17	0		
	CDD18.3	512	0	0	0	2	32	117	151	157	52	1	0	0		
	CDH23.3	4864	0	0	4	39	344	1076	1389	1513	479	19	1	0		
	CDH26.7	1851	0	0	0	4	78	388	549	669	162	1	0	0		
(14) Wind	WSAvg	2.3	2.4	2.4	2.9	2.7	2.3	2.4	2.1	2.2	1.9	1.9	1.9	2.1		
(15) Precipitation	PrecAvg	575	29	26	33	46	68	75	66	52	50	52	35	38		
	PrecMax	803	72	75	73	100	161	151	172	140	133	184	106	109		
	PrecMin	355	2	4	1	21	9	11	7	11	13	2	1	2		
	PrecStd	130	21	21	19	22	40	36	38	35	31	40	26	32		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	18.3	23.4	26.7	31.2	34.5	35.5	35.7	32.6	25.7	21.1	13.6		
		MCWB	6.2	10.5	12.8	16.7	18.7	22.4	22.5	21.5	18.8	17.2	14.5	9.2		
	2%	DB	6.6	13.9	18.9	24.3	28.9	32.3	33.2	34.0	30.4	23.1	18.1	10.9		
		MCWB	4.3	9.3	11.0	15.6	18.0	21.9	21.4	20.7	18.8	16.2	12.8	8.2		
	5%	DB	4.7	10.9	16.2	21.7	27.1	30.6	31.5	32.3	28.5	20.7	15.0	8.5		
		MCWB	3.3	7.1	10.0	14.0	17.6	21.0	21.0	20.5	18.0	14.8	11.4	6.5		
	10%	DB	3.3	8.4	13.8	19.5	25.3	29.0	29.8	30.5	25.9	18.3	12.6	6.2		
		MCWB	2.0	6.1	8.5	12.8	16.5	20.2	20.8	20.0	18.0	13.9	10.3	4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	12.5	13.6	17.7	20.9	24.1	23.8	23.7	21.6	18.8	14.8	10.4		
		MCDB	9.2	16.7	19.9	24.9	27.4	30.7	32.7	33.1	28.9	23.9	20.1	12.1		
	2%	WB	5.1	9.4	11.7	16.0	19.5	22.9	22.8	22.6	20.1	17.2	13.4	8.6		
		MCDB	6.4	13.3	18.1	22.8	26.3	30.3	30.5	30.9	26.6	21.1	17.6	10.8		
	5%	WB	3.5	7.6	10.4	14.7	18.4	22.0	22.0	21.6	19.2	15.8	12.0	6.6		
		MCDB	4.7	10.1	15.8	20.7	24.6	29.7	29.3	29.2	26.0	19.4	14.3	8.5		
	10%	WB	2.2	6.3	9.0	13.4	17.4	21.1	21.2	20.9	18.3	14.5	10.5	4.7		
		MCDB	3.1	8.0	12.6	18.3	23.4	27.7	27.7	28.0	25.2	17.5	12.4	6.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	7.6	9.5	10.9	11.7	11.2	11.4	11.6	11.4	9.6	7.5	6.3		
		MCDBR	8.6	13.1	15.3	16.0	14.8	13.7	14.5	14.5	15.3	14.0	12.7	10.1		
	5% WB	MCWBR	6.1	8.4	8.5	8.6	6.3	5.4	5.1	4.7	5.7	7.4	7.3	7.2		
		MCWBR	7.6	12.0	14.2	15.4	13.0	12.7	12.6	13.0	13.7	12.4	10.7	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.360	0.396	0.456	0.429	0.429	0.446	0.461	0.418	0.383	0.356	0.330		
	taud		2.328	2.251	2.207	2.063	2.221	2.257	2.216	2.167	2.247	2.328	2.354	2.339		
	Ebn at Noon		759	801	823	802	841	841	820	790	792	767	720	713		
	Edh at Noon		79	103	123	155	137	133	137	139	118	94	77	71		
(44) All-Sky Solar Radiation	RadAvg		1.29	2.10	3.26	4.44	5.61	5.94	6.04	5.47	3.96	2.57	1.41	1.08		
	RadStd		0.16	0.25	0.34	0.45	0.46	0.47	0.46	0.39	0.36	0.29	0.13	0.13		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (58 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	-115	-155	+72	+29

Nomenclature: See separate page