

BOITA, Romania

WMO: 152770

Lat: 45.6531N

Lon: 24.2717E

Elev: 1703

StdP: 13.81

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	14.2	3.1	6.9	11.3	8.8	9.2	16.4	62.6	35.8	53.6	35.0	3.3	340	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.4	85.8	68.9	83.3	67.9	80.5	66.9	71.4	82.1	69.9	80.8	68.4	78.2	6.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	109.7	76.5	66.3	103.1	74.9	64.8	97.8	73.4	36.3	82.3	35.0	81.0	33.7	78.2	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
41.1	31.0	22.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	29.4	35.4	41.8	50.6	59.4	66.1	68.3	69.4	59.9	51.1	41.7	32.4
	DBStd	15.61	8.59	8.32	8.58	9.36	6.08	5.71	4.96	5.62	7.22	7.57	9.07	7.81
	HDD50	2351	638	410	280	107	7	0	0	0	5	83	275	546
	HDD65	5707	1103	828	720	433	189	55	25	26	186	433	698	1011
	CDD50	2547	0	2	26	125	300	483	566	601	301	116	27	0
	CDD65	426	0	0	0	2	16	88	126	162	31	1	0	0
	CDH74	2974	0	0	1	31	123	604	842	1153	214	6	0	0
	CDH80	706	0	0	0	1	13	123	192	333	44	0	0	0
Wind	WSAvg	7.2	7.5	8.1	7.9	8.2	7.2	6.1	5.8	6.4	6.6	7.0	8.6	6.6
Precipitation	PrecAvg	33.4	1.8	1.6	1.9	2.8	3.7	4.3	4.6	3.3	2.9	2.4	2.0	1.9
	PrecMax	50.1	3.6	3.3	3.6	6.5	8.2	8.3	8.1	6.5	6.5	5.2	5.4	3.7
	PrecMin	21.1	0.4	0.2	0.6	0.6	1.6	0.4	0.8	0.6	0.3	0.0	0.1	0.3
	PrecStd	7.2	0.9	0.8	0.8	1.3	1.8	2.1	1.9	1.8	1.5	1.4	1.3	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	58.6	70.1	77.0	81.9	86.8	88.3	89.8	84.6	74.4	65.4	54.7
		MCWB	44.3	47.9	54.3	61.4	63.4	69.2	71.1	69.4	65.8	58.4	55.0	47.7
	2%	DB	45.7	53.3	64.0	73.7	77.4	83.4	84.7	86.2	79.5	70.6	61.1	49.6
		MCWB	41.0	44.5	50.8	57.8	63.9	68.3	69.0	68.8	64.3	56.4	52.1	44.2
	5%	DB	42.6	50.0	58.6	69.2	73.8	80.3	81.5	83.8	75.4	66.7	57.5	46.0
		MCWB	39.0	43.3	48.0	55.3	62.2	66.6	68.3	68.2	62.5	55.3	50.7	41.5
	10%	DB	39.8	46.8	54.0	64.3	70.7	77.2	78.6	80.7	71.3	62.4	54.3	42.6
		MCWB	36.5	41.2	45.2	53.1	60.9	65.0	67.1	67.8	60.8	53.9	48.8	39.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	47.7	56.3	66.4	74.0	72.6	73.2	72.8	68.8	62.1	57.0	49.8
		MCDB	50.2	53.8	69.1	70.0	74.0	83.1	85.3	84.8	81.5	66.3	63.4	54.7
	2%	WB	41.7	45.4	52.0	59.7	67.0	69.8	70.9	71.1	65.9	58.6	54.0	45.1
		MCDB	44.9	50.8	62.4	71.1	71.8	81.5	81.4	83.4	76.4	67.4	59.9	49.4
	5%	WB	39.0	43.5	49.1	56.8	63.6	67.8	69.5	69.6	63.8	56.7	51.9	42.2
		MCDB	41.8	48.7	58.5	68.0	72.7	78.2	79.6	81.7	73.8	64.6	58.0	45.8
	10%	WB	36.8	41.4	46.5	54.1	61.4	66.1	68.1	68.1	62.0	55.0	49.4	40.0
		MCDB	39.1	45.6	53.4	63.8	70.2	75.8	76.2	78.9	70.4	61.9	54.5	42.9
Mean Daily Temperature Range	5% DB	MDBR	10.9	13.2	16.1	17.6	17.7	18.5	18.6	19.4	17.1	16.6	12.1	9.4
		MCDBR	12.8	16.1	23.3	24.0	22.5	22.6	21.8	23.4	22.3	23.5	16.1	14.3
		MCWBR	8.6	9.9	13.5	11.7	11.5	10.6	10.5	10.2	9.8	11.8	8.8	9.0
	5% WB	MCDBR	11.0	15.6	23.1	21.4	21.2	20.4	19.8	21.3	20.1	20.1	15.0	13.1
MCWBR		8.1	9.5	13.4	11.5	13.6	10.4	10.2	10.2	9.6	11.5	8.9	8.6	
Clear-Sky Solar Irradiance	taub	0.300	0.328	0.368	0.425	0.410	0.409	0.426	0.438	0.393	0.356	0.331	0.302	
	taud	2.354	2.292	2.260	2.146	2.255	2.290	2.249	2.212	2.311	2.411	2.426	2.393	
	Ebn at Noon	254	267	271	264	272	272	266	257	260	255	241	240	
	Edh at Noon	24	31	37	45	42	41	42	42	35	28	23	21	
All-Sky Solar Radiation	RadAvg	433	693	1034	1361	1649	1800	1813	1648	1197	831	486	351	
	RadStd	48	86	118	149	160	165	157	146	121	103	53	43	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (79 neighbors)	+1.15	N/A	N/A	+1.46	N/A	N/A	-230	-324	+148	+45

Nomenclature: See separate page