

BANLOC, Romania

WMO: 152890

Lat: 45.3828N

Lon: 21.1364E

Elev: 278

StdP: 14.55

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.9	18.6	7.8	8.3	19.5	13.3	10.9	24.5	27.1	42.4	23.5	40.4	4.2	150	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.6	93.5	70.1	90.5	70.1	87.2	69.4	73.7	86.6	72.0	85.7	70.7	84.2	7.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.7	110.4	79.8	67.9	103.5	77.4	66.3	97.9	75.4	37.3	86.1	35.8	85.7	34.7	84.5	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	19.5	17.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	31.6	38.4	43.8	52.9	62.3	69.5	71.6	72.3	63.6	53.6	46.0	35.8	(6)
	DBStd	15.61	8.44	8.10	7.36	8.54	6.24	5.38	5.48	5.82	7.59	7.55	7.73	7.44	(7)
	HDD50	1857	571	331	218	70	2	0	0	0	1	53	169	442	(8)
	HDD65	4916	1035	745	658	368	124	19	9	8	116	359	570	905	(9)
	CDD50	3140	0	6	24	156	383	585	671	692	410	163	49	1	(10)
	CDD65	728	0	0	0	5	40	154	215	235	75	4	0	0	(11)
	CDH74	8175	0	0	1	95	467	1627	2496	2631	776	82	0	0	(12)
	CDH80	3200	0	0	0	4	84	569	1070	1215	253	5	0	0	(13)
(14) Wind	WSAvg	6.8	6.6	7.5	7.7	8.3	6.6	5.8	5.7	5.8	6.1	6.1	8.2	6.7	(14)
(15) Precipitation	PrecAvg	24.1	1.5	1.3	1.4	1.7	2.4	3.0	2.9	1.9	2.0	1.8	1.9	1.9	(15)
	PrecMax	32.0	2.6	2.8	4.2	3.7	4.5	6.7	8.1	4.2	4.5	3.7	4.9	4.6	(16)
	PrecMin	11.9	0.2	0.1	0.3	0.6	0.7	1.0	0.3	0.1	0.1	0.1	0.0	0.2	(17)
	PrecStd	5.2	0.8	0.8	0.9	0.7	0.9	1.5	2.0	1.1	1.1	1.1	1.1	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	62.3	70.7	80.6	85.3	92.6	96.8	98.8	92.0	80.4	68.8	57.3	(19)
		MCWB	47.9	51.9	55.5	62.9	66.9	73.0	71.2	70.8	67.7	62.9	55.9	50.3	(20)
	2%	DB	48.7	57.5	65.3	77.1	82.5	89.7	93.1	94.2	86.4	76.5	64.4	52.8	(21)
		MCWB	44.8	49.1	52.4	60.8	66.0	71.6	70.4	69.2	67.6	60.6	55.0	48.0	(22)
	5%	DB	46.0	53.8	60.7	72.5	79.6	86.5	89.7	90.9	82.4	72.4	61.4	49.0	(23)
		MCWB	43.0	47.0	49.9	57.5	64.8	70.4	70.3	69.4	65.0	59.1	53.6	45.3	(24)
	10%	DB	43.1	50.5	56.4	68.7	76.2	83.1	86.0	86.9	78.5	67.4	58.4	45.3	(25)
		MCWB	40.5	45.2	47.3	55.9	62.8	68.9	68.8	69.1	64.4	57.2	52.1	42.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	53.6	57.4	64.9	69.8	77.3	74.6	74.7	71.2	66.1	57.9	51.7	(27)
		MCDB	53.1	60.7	70.2	78.5	81.8	89.7	87.9	88.0	88.3	74.5	66.6	55.0	(28)
	2%	WB	45.8	50.1	53.7	61.6	67.3	74.4	73.0	72.6	68.5	62.5	56.0	48.3	(29)
		MCDB	48.4	55.6	63.6	74.8	79.3	85.9	87.7	86.8	82.3	72.1	62.6	53.0	(30)
	5%	WB	43.7	47.6	50.9	59.2	65.8	72.1	71.5	71.1	66.7	60.3	54.3	45.4	(31)
		MCDB	46.2	52.7	59.3	70.0	77.0	83.3	86.3	85.7	79.1	70.3	60.3	48.6	(32)
	10%	WB	40.6	45.5	48.5	57.0	63.8	70.2	70.1	69.9	65.0	58.2	52.4	43.1	(33)
		MCDB	43.2	49.9	55.3	66.4	73.9	80.8	83.7	84.5	75.5	66.8	58.1	45.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	15.0	19.4	21.4	20.7	21.8	24.0	23.6	20.9	20.5	15.4	10.6	(35)
		MCDBR	15.2	20.6	26.3	27.7	26.2	26.9	29.4	30.1	27.0	28.5	18.5	16.3	(36)
		MCWBR	10.8	13.3	15.6	14.1	13.4	11.6	10.8	9.6	10.6	14.8	10.8	11.6	(37)
	5% WB	MCDBR	13.9	17.6	23.4	26.1	24.5	24.0	26.1	26.2	23.8	25.4	17.6	16.0	(38)
		MCWBR	10.4	11.4	14.5	13.8	12.8	11.7	10.8	9.8	9.7	13.8	10.6	11.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.344	0.370	0.405	0.460	0.446	0.440	0.448	0.459	0.434	0.395	0.361	0.342	(40)
	taud		2.324	2.248	2.198	2.055	2.164	2.218	2.193	2.163	2.198	2.299	2.345	2.345	(41)
	Ebn at Noon		236	251	259	253	262	264	260	251	246	239	227	223	(42)
	Edh at Noon		25	33	40	50	46	44	44	44	39	31	25	23	(43)
(44) All-Sky Solar Radiation	RadAvg		378	646	1047	1462	1775	1964	1967	1750	1220	836	501	307	(44)
	RadStd		43	87	132	142	161	171	149	163	134	88	41	45	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (60 neighbors)		+1.26	N/A	N/A	N/A	+0.67	N/A	-209	-331	+232	+122	

Nomenclature: See separate page