

PREDEAL, Romania

WMO: 153020

Lat: 45.5064N

Lon: 25.5836E

Elev: 1091

StdP: 88.88

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-13.2	-17.5	0.9	-13.7	-15.3	1.1	-11.6	8.4	-1.7	7.4	-4.1	0.8	320	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	25.4	17.0	23.9	16.3	22.4	15.7	18.2	23.2	17.4	21.9	16.6	20.9	1.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	13.6	19.6	15.9	12.9	18.9	15.1	12.2	18.3	56.4	23.4	53.4	21.9	51.0	21.0	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.2	4.2	-18.9	28.0	2.1	1.7	-20.5	29.2	-21.7	30.2	-22.9	31.2	-24.4	32.4		
(5)			-19.2	20.2	2.1	0.8	-20.7	20.8	-21.9	21.3	-23.1	21.7	-24.7	22.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-3.6	-1.7	0.3	5.5	10.4	14.3	15.5	15.6	11.2	6.6	2.2	-2.5	(6)
(7)		DBStd	8.03	4.90	4.84	4.41	4.56	3.33	3.05	2.72	2.86	4.21	4.28	4.82	4.63	(7)
(8)		HDD10.0	2017	422	328	300	144	36	4	1	1	37	121	236	389	(8)
(9)		HDD18.3	4449	681	561	558	384	247	124	93	93	214	363	484	647	(9)
(10)		CDD10.0	626	0	0	0	10	47	133	171	173	74	16	1	0	(10)
(11)		CDD18.3	17	0	0	0	0	0	3	5	7	1	0	0	0	(11)
(12)		CDH23.3	196	0	0	0	1	2	34	60	81	17	1	0	0	(12)
(13)		CDH26.7	17	0	0	0	0	0	3	3	9	2	0	0	0	(13)
(14)	Wind	WSAvg	1.4	1.4	1.5	1.6	1.6	1.5	1.4	1.3	1.5	1.4	1.4	1.4	(14)	
(15)	Precipitation	PrecAvg	950	49	48	46	74	116	142	136	99	72	56	55	57	(15)
(16)		PrecMax	1211	114	103	136	125	233	271	305	176	189	189	124	173	(16)
(17)		PrecMin	617	10	3	3	16	31	39	37	18	4	9	17	2	(17)
(18)		PrecStd	155	27	23	32	27	52	58	64	46	51	42	25	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	12.9	15.4	20.2	23.1	26.3	26.9	27.9	25.3	20.5	15.5	10.0	(19)
(20)			MCWB	3.9	6.9	7.6	11.0	13.2	17.8	17.8	18.4	16.6	12.4	9.4	5.9	(20)
(21)		2%	DB	6.3	9.3	12.1	18.3	20.9	24.0	25.1	25.4	22.6	18.4	13.2	6.6	(21)
(22)			MCWB	3.5	4.8	6.2	10.5	13.0	16.5	17.2	16.9	14.8	11.7	8.8	4.3	(22)
(23)		5%	DB	4.2	7.1	9.4	15.6	19.1	22.4	23.5	23.6	20.4	16.0	11.2	4.9	(23)
(24)			MCWB	2.1	3.4	4.7	9.1	12.5	15.8	16.6	16.2	14.2	10.8	7.6	2.9	(24)
(25)		10%	DB	2.2	5.0	7.0	13.0	17.2	20.8	21.7	21.8	18.4	13.3	9.1	3.0	(25)
(26)			MCWB	1.0	2.3	3.4	8.0	11.7	15.3	16.1	15.9	13.3	9.7	6.7	1.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	7.2	8.4	12.2	15.3	19.1	19.2	19.4	17.2	14.2	10.3	6.3	(27)
(28)			MCDWB	7.7	12.0	14.4	18.3	19.6	24.5	24.3	25.4	23.9	17.4	13.8	7.9	(28)
(29)		2%	WB	3.9	5.2	6.5	10.9	14.1	17.6	18.1	18.2	15.7	12.6	9.2	4.8	(29)
(30)			MCDWB	6.1	8.5	11.2	17.0	18.8	21.8	22.7	23.6	20.6	16.7	12.5	7.0	(30)
(31)		5%	WB	2.4	3.9	5.2	9.8	13.1	16.6	17.4	17.2	14.7	11.3	8.2	3.1	(31)
(32)			MCDWB	3.8	6.4	8.9	14.7	18.0	20.8	21.6	21.9	19.1	15.2	11.0	4.6	(32)
(33)		10%	WB	1.1	2.7	3.8	8.6	12.1	15.8	16.6	16.4	13.8	10.1	6.9	2.0	(33)
(34)			MCDWB	2.1	4.8	6.4	12.2	16.1	19.9	20.6	20.7	17.6	13.0	8.9	3.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.9	7.9	7.9	9.4	9.9	9.5	10.1	9.2	8.7	7.2	6.2	(35)	
(36)			MCDBR	9.5	11.0	12.6	14.2	13.6	12.7	12.7	13.1	12.7	13.0	10.8	8.4	(36)
(37)			MCWBR	6.3	6.9	7.2	7.2	6.8	6.2	5.9	6.0	6.0	7.2	6.3	5.7	(37)
(38)		5% WB	MCDWB	8.7	10.1	11.4	12.9	12.0	11.6	11.2	11.7	11.4	12.2	9.6	7.5	(38)
(39)			MCWBR	6.1	6.7	7.1	6.8	6.5	6.2	5.8	6.1	5.7	7.0	5.8	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.277	0.303	0.341	0.393	0.377	0.378	0.391	0.403	0.364	0.331	0.308	0.280	(40)	
(41)		taud	2.368	2.307	2.296	2.216	2.320	2.339	2.304	2.268	2.359	2.448	2.465	2.415	(41)	
(42)		Ebn at Noon	835	874	886	864	891	889	871	845	852	835	794	794	(42)	
(43)		Edh at Noon	74	96	112	133	124	122	125	125	105	83	68	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.39	2.21	3.28	4.28	5.22	5.64	5.74	5.20	3.81	2.63	1.54	1.14	(44)	
(45)		RadStd	0.14	0.28	0.34	0.47	0.51	0.51	0.49	0.43	0.37	0.33	0.15	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (70 neighbors)	+0.57	N/A	N/A	+0.66	N/A	N/A	-121	-166	+70	+23

Nomenclature: See separate page