

RESITA, Romania

WMO: 153140

Lat: 45.3144N

Lon: 21.8869E

Elev: 920

StdP: 14.21

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	18.4	10.6	9.8	16.6	14.2	11.7	22.2	21.2	40.3	16.3	40.1	1.7	170	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.6	90.7	69.2	87.4	69.0	84.3	68.3	72.3	84.0	71.0	82.4	69.7	81.5	6.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	109.9	77.0	67.4	104.4	75.6	66.1	99.6	74.1	36.5	83.7	35.3	82.4	34.2	81.8	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	15.1	11.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	32.5	38.8	43.9	52.6	60.9	67.4	69.8	70.7	62.1	52.9	45.6	36.1		
	DBStd	14.88	8.76	8.19	7.82	8.65	6.09	5.67	5.17	5.59	7.60	7.53	8.54	8.00		
	HDD50	1843	543	323	218	74	4	0	0	0	2	60	185	434		
	HDD65	4992	1007	734	653	376	152	40	16	14	143	379	583	895		
	CDD50	2880	1	9	30	152	342	521	614	643	363	149	52	4		
	CDD65	556	0	0	0	4	26	111	165	192	55	3	0	0		
	CDH74	5722	0	0	1	72	275	1102	1694	1964	552	62	0	0		
	CDH80	1907	0	0	0	1	30	298	604	810	161	3	0	0		
	WSAvg	3.6	2.5	3.9	4.1	4.5	4.1	3.9	3.8	3.4	3.4	3.1	3.8	3.2		
	PrecAvg	32.5	2.0	1.8	1.9	2.8	3.3	4.1	3.8	2.6	3.2	2.6	2.2	2.4		
(15) Precipitation	PrecMax	42.4	4.0	5.4	5.0	4.6	7.6	9.5	9.0	5.3	8.4	5.4	5.2	6.0		
(16) PrecMin		20.6	0.5	0.2	0.5	0.7	1.3	0.7	0.7	0.3	0.5	0.1	0.0	0.4		
(17) PrecStd		6.1	1.0	1.1	1.1	1.1	1.5	2.0	2.1	1.4	1.8	1.4	1.2	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.5	62.6	70.9	79.0	82.8	89.6	94.2	95.8	90.0	79.8	69.7	59.9		
		MCWB	48.0	50.1	54.3	60.2	65.9	70.9	68.7	68.6	66.7	61.3	55.3	49.7		
	2%	DB	52.5	59.3	66.1	76.0	80.3	86.6	90.0	91.4	84.6	75.3	65.6	55.0		
		MCWB	45.1	48.9	51.2	58.5	64.7	70.9	69.1	69.3	65.3	59.6	54.7	47.7		
	5%	DB	48.9	55.8	61.8	72.2	77.3	83.7	86.2	88.0	80.5	71.4	62.8	51.5		
		MCWB	43.4	46.3	49.2	56.1	62.8	69.1	69.0	68.6	64.1	58.8	53.4	45.4		
	10%	DB	44.8	52.1	57.6	68.1	74.0	80.7	82.7	84.4	76.4	66.5	59.2	47.1		
		MCWB	40.7	44.2	47.3	54.4	61.3	68.0	67.9	68.5	63.5	57.1	51.8	43.0		
	0.4%	WB	49.2	52.2	55.3	62.9	68.3	75.1	73.3	73.8	69.2	64.3	56.7	52.3		
		MCDB	56.5	60.3	70.7	76.0	80.1	86.1	84.3	87.7	84.3	74.3	66.4	55.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.7	49.6	52.3	60.0	66.2	72.4	71.6	72.1	67.5	61.6	55.3	48.4		
		MCDB	51.9	56.8	63.8	72.9	77.5	82.8	82.5	84.5	81.1	71.0	63.8	55.7		
	5%	WB	43.8	47.4	50.4	57.5	64.4	70.6	70.3	70.7	65.9	59.8	54.2	45.8		
		MCDB	47.9	54.4	60.2	69.8	74.5	81.3	82.1	82.6	76.1	69.1	61.7	51.1		
	10%	WB	40.9	45.3	48.1	55.5	62.4	69.0	69.1	69.4	64.5	57.8	52.5	43.6		
		MCDB	44.8	51.6	56.5	65.2	71.6	79.0	80.7	81.3	73.6	65.8	58.8	47.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	14.9	17.1	19.0	18.9	19.8	21.3	21.6	18.4	19.1	15.1	11.3		
		MCDBR	18.7	20.3	24.1	25.8	25.0	24.2	27.1	28.8	25.8	27.5	19.1	17.7		
		MCWBR	10.9	11.4	12.4	12.1	11.5	10.9	10.0	9.6	10.0	13.4	10.3	11.2		
	5% WB	MCDBR	16.4	17.8	21.1	23.3	23.4	22.4	23.1	24.2	21.9	24.5	17.9	17.1		
		MCWBR	10.1	10.2	11.0	11.0	11.5	11.1	10.1	10.4	9.4	12.5	9.6	11.0		
(40) Clear-Sky Solar Irradiance	taub		0.328	0.356	0.395	0.450	0.437	0.429	0.440	0.454	0.422	0.382	0.350	0.327		
	taud		2.334	2.251	2.213	2.076	2.173	2.237	2.207	2.167	2.225	2.331	2.371	2.364		
	Ebn at Noon		243	257	262	257	265	267	262	253	250	245	233	230		
	Edh at Noon		25	33	39	49	46	43	44	44	38	30	24	22		
(44) All-Sky Solar Radiation	RadAvg		395	656	1039	1432	1726	1924	1918	1718	1207	829	494	325		
	RadStd		47	87	137	148	159	175	149	165	128	93	50	46		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (69 neighbors)	+1.21	N/A	N/A	N/A	N/A	N/A	N/A	-198	-313	+214	+113

Nomenclature: See separate page