

CUNTU, Romania

WMO: 153160

Lat: 45.3004N

Lon: 22.5009E

Elev: 1458

StdP: 84.99

Time Zone: 2.00 (EUE)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -14.0	(c) -12.0	(d) -21.1	(e) 0.7	(f) -9.0	(g) -17.8	(h) 0.9	(i) -7.7	(j) 15.8	(k) -4.1	(l) 12.2	(m) -5.6	(n) 2.7	(o) 0	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.6	(c) 22.3	(d) 15.6	(e) 21.0	(f) 15.0	(g) 19.8	(h) 14.5	(i) 17.1	(j) 20.5	(k) 16.2	(l) 19.7	(m) 15.4	(n) 18.7	(o) 2.5	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 16.1	(b) 13.7	(c) 18.3	(d) 15.0	(e) 12.8	(f) 17.3	(g) 14.2	(h) 12.1	(i) 16.8	(j) 54.2	(k) 20.7	(l) 51.2	(m) 19.8	(n) 48.5	(o) 18.7	(p) 19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.4	(b) 8.3	(c) 6.8	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 10.4	(b) 8.3	(c) 6.8	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-4.0	-2.2	-0.1	4.3	9.1	13.2	14.4	14.8	10.3	6.3	2.5	-2.0
	DBStd	7.88	4.93	4.58	4.55	5.39	3.64	3.53	3.19	3.49	4.69	4.93	5.06	4.48
	HDD10.0	2143	435	342	313	183	60	12	4	5	54	134	228	372
	HDD18.3	4671	693	576	572	422	286	157	128	117	243	372	476	631
	CDD10.0	530	0	0	0	11	33	107	139	154	64	21	2	0
	CDD18.3	16	0	0	0	0	0	2	5	7	2	0	0	0
	CDH23.3	23	0	0	0	0	0	0	4	15	3	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	2.3	2.3	2.6	2.3	2.4	2.2	2.1	2.3	1.8	2.2	2.3	2.7	2.8
Precipitation	PrecAvg	853	51	47	48	63	86	104	111	75	90	66	53	55
	PrecMax	1276	110	167	115	106	164	225	250	207	193	137	149	119
	PrecMin	590	17	7	10	11	34	26	38	5	6	3	0	6
	PrecStd	202	23	34	25	24	35	47	51	48	49	35	36	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.9	9.7	11.7	17.2	19.1	22.1	23.8	25.0	22.9	18.0	14.3	10.4
		MCWB	2.7	3.8	6.1	10.1	13.3	15.9	15.8	16.4	14.9	10.7	8.3	2.1
	2%	DB	5.1	7.1	9.6	15.2	17.2	21.0	22.1	22.6	20.1	16.1	11.6	7.2
		MCWB	1.8	3.1	4.9	8.8	12.2	15.9	16.1	15.6	13.0	10.0	7.3	2.4
	5%	DB	3.8	4.8	7.8	13.2	15.8	19.8	20.5	20.9	18.3	14.3	9.9	5.5
		MCWB	1.4	2.0	3.8	7.9	11.6	15.1	15.2	14.5	12.6	8.7	6.0	2.0
	10%	DB	2.5	3.4	6.1	11.3	14.3	18.4	19.1	19.5	16.5	12.8	8.5	3.9
		MCWB	0.8	1.1	3.0	6.6	10.9	14.2	14.7	14.2	11.8	8.0	5.6	1.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.9	4.8	7.0	11.6	14.9	18.2	18.1	18.1	16.2	12.3	10.1	5.1
		MCDB	5.0	7.4	10.5	16.1	17.6	20.2	20.4	21.7	21.5	16.1	12.2	6.8
	2%	WB	2.9	3.5	5.5	9.7	13.7	16.9	16.9	16.8	14.2	10.9	8.6	3.8
		MCDB	4.3	6.1	8.3	13.8	16.1	19.8	20.1	21.0	17.8	14.9	10.9	5.7
	5%	WB	1.9	2.7	4.4	8.5	12.5	15.9	16.1	15.7	13.2	9.9	7.3	2.5
		MCDB	3.2	5.0	7.2	12.6	14.6	18.6	19.6	19.6	17.1	13.3	9.1	4.3
	10%	WB	0.9	1.8	3.3	7.3	11.4	14.9	15.3	14.9	12.2	9.0	6.2	1.7
		MCDB	2.1	3.4	5.8	11.1	13.7	17.6	18.5	18.6	15.7	12.0	7.8	3.7
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.2	5.5	5.9	5.4	5.7	5.6	5.6	5.2	5.4	4.9	4.9
		MCDBR	5.6	5.9	7.0	7.6	6.8	7.0	7.1	7.1	6.8	6.8	5.9	5.9
		MCWBR	4.5	4.2	4.8	5.1	5.2	6.0	5.4	5.1	4.8	5.6	4.3	3.9
	5% WB	MCDBR	4.9	5.5	6.3	7.1	6.2	6.4	6.3	6.6	6.4	6.4	5.2	5.2
		MCWBR	4.3	4.4	4.9	5.1	5.5	6.2	5.4	5.5	5.1	5.4	4.2	4.4
Clear-Sky Solar Irradiance	taub	0.278	0.303	0.340	0.389	0.377	0.369	0.382	0.395	0.363	0.330	0.305	0.279	
	taud	2.381	2.316	2.310	2.195	2.277	2.327	2.287	2.249	2.324	2.425	2.451	2.426	
	Ebn at Noon	838	876	889	868	890	897	879	853	852	836	799	799	
	Edh at Noon	73	95	111	136	130	124	128	128	109	85	69	64	
All-Sky Solar Radiation	RadAvg	1.32	2.12	3.24	4.38	5.22	5.88	5.82	5.26	3.75	2.58	1.52	1.10	
	RadStd	0.17	0.27	0.45	0.49	0.48	0.56	0.47	0.52	0.38	0.31	0.20	0.15	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (74 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-115	-176	+120	+62

Nomenclature: See separate page