

TARGU JIU, Romania

WMO: 153400

Lat: 45.0406N

Lon: 23.2592E

Elev: 674

StdP: 14.34

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	16.1	7.9	8.5	13.8	12.5	10.7	21.5	16.0	39.7	11.2	35.0	0.9	170	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.9	91.3	69.7	88.6	69.0	85.9	68.4	73.2	84.9	71.5	83.0	70.1	81.9	3.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.7	112.0	77.9	67.9	105.1	76.5	66.3	99.5	74.6	37.2	85.0	35.7	82.9	34.4	81.9	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	9.7	7.5	1.5	95.1	3.6	3.5	-1.1	97.6	-3.2	99.6	-5.2	101.6	-7.8	104.1
			1.3	75.6	3.6	2.0	-1.2	77.0	-3.3	78.2	-5.3	79.3	-7.9	80.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	30.7	36.8	44.0	53.5	62.2	69.4	71.9	72.0	63.2	52.6	42.4	33.6	(6)
	DBStd	15.88	7.09	7.95	7.08	7.11	5.54	4.88	4.61	5.05	7.02	6.77	7.14	7.07	(7)
	HDD50	2029	599	372	204	47	1	0	0	0	1	52	243	510	(8)
	HDD65	5156	1064	790	650	348	119	16	4	8	118	387	677	975	(9)
	CDD50	3043	0	2	20	151	379	583	680	683	397	132	16	0	(10)
	CDD65	694	0	0	0	2	32	149	219	226	65	1	0	0	(11)
	CDH74	7491	0	0	1	74	417	1525	2345	2361	718	50	0	0	(12)
	CDH80	2646	0	0	0	5	56	484	896	978	226	1	0	0	(13)
(14) Wind	WSAvg	2.1	1.3	1.9	2.8	2.8	2.6	2.4	2.5	2.2	2.0	1.7	1.5	1.4	(14)
(15) Precipitation	PrecAvg	30.5	1.8	1.6	1.7	2.5	3.2	3.8	4.0	2.4	2.7	2.5	2.1	2.3	(15)
	PrecMax	43.2	3.2	3.4	3.7	4.9	7.2	6.3	8.2	4.9	5.1	6.2	5.8	5.7	(16)
	PrecMin	16.2	0.3	0.2	0.3	0.7	1.4	0.6	1.1	0.7	0.1	0.0	0.1	0.3	(17)
	PrecStd	6.6	0.9	0.9	1.0	1.1	1.4	1.7	2.0	1.3	1.4	1.5	1.3	1.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	63.6	72.1	80.3	84.5	92.2	94.6	95.8	89.7	79.2	67.1	55.0	(19)
		MCWB	44.4	50.8	52.9	60.7	65.2	69.6	70.0	69.6	66.3	62.0	54.3	45.9	(20)
	2%	DB	46.9	57.7	65.9	75.7	81.3	88.3	90.6	91.8	85.7	74.5	61.4	49.4	(21)
		MCWB	40.7	47.8	50.9	58.9	63.9	70.2	70.5	69.1	64.9	59.6	52.8	44.1	(22)
	5%	DB	43.2	53.1	61.2	71.6	78.7	85.2	87.8	88.8	82.0	69.7	56.6	45.8	(23)
		MCWB	39.8	45.4	48.5	56.4	63.2	69.4	69.5	68.6	64.1	58.1	50.6	41.6	(24)
	10%	DB	40.2	48.7	57.1	67.6	75.8	82.4	85.1	85.6	78.0	65.4	53.1	42.5	(25)
		MCWB	37.4	42.7	46.2	54.5	61.6	67.8	68.7	67.9	62.9	55.9	49.1	39.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	51.8	54.3	62.2	68.9	74.7	76.0	74.4	69.5	64.5	57.0	48.0	(27)
		MCDB	50.9	60.9	68.5	76.3	80.1	85.2	88.1	87.7	83.5	71.9	64.0	51.0	(28)
	2%	WB	42.8	48.9	51.9	59.9	66.1	72.8	73.2	72.5	67.0	61.6	54.5	45.1	(29)
		MCDB	45.2	56.0	63.6	73.7	77.6	83.9	84.5	84.7	79.4	70.4	59.3	49.4	(30)
	5%	WB	40.4	46.5	49.8	57.5	64.5	71.0	71.4	70.8	65.4	59.3	52.2	42.6	(31)
		MCDB	42.7	51.3	59.9	69.2	75.8	81.7	83.1	82.9	76.6	67.5	55.4	45.1	(32)
	10%	WB	37.9	44.0	47.5	55.4	62.8	69.2	70.0	69.4	64.1	57.2	49.9	40.3	(33)
		MCDB	39.7	48.1	55.4	64.9	73.0	79.9	82.1	81.5	74.6	63.9	53.2	42.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	17.1	19.7	20.7	21.2	22.7	23.9	24.1	22.2	20.9	14.4	13.4	(35)
		MCDBR	19.8	25.8	29.3	29.8	27.5	27.1	28.0	29.5	29.2	29.7	23.2	19.9	(36)
	5% WB	MCWBR	13.5	15.9	15.5	13.4	11.9	11.3	10.1	9.5	10.6	15.4	14.3	13.8	(37)
		MCWBR	17.0	24.0	26.7	26.9	24.9	25.1	24.7	24.7	24.7	26.8	19.4	18.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.329	0.363	0.404	0.470	0.451	0.445	0.463	0.483	0.436	0.394	0.364	0.331	(40)
		taud	2.298	2.210	2.170	2.018	2.137	2.198	2.156	2.093	2.185	2.292	2.319	2.329	(41)
	Ebn at Noon		242	254	259	251	261	263	256	245	246	240	227	228	(42)
		Edh at Noon	26	34	41	52	48	45	46	48	40	31	26	23	(43)
(44) All-Sky Solar Radiation	RadAvg		430	684	1054	1427	1723	1933	1914	1716	1226	826	477	353	(44)
	RadStd		59	95	139	153	145	170	143	157	116	103	64	49	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (75 neighbors)		+1.13	N/A	N/A	+1.60	N/A	N/A	-205	-302	+164	+79	

Nomenclature: See separate page