

TARGU JIU, Romania

WMO: 153400

Lat: 45.0406N

Lon: 23.2592E

Elev: 206

StdP: 98.88

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.8	-13.4	1.2	-10.1	-10.8	1.5	-5.8	7.2	4.3	5.0	1.7	0.4	170	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	33.0	21.0	31.4	20.6	30.0	20.2	22.9	29.4	22.0	28.3	21.2	27.7	1.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.9	16.0	25.5	19.9	15.0	24.7	19.1	14.2	23.7	68.6	29.5	65.1	28.3	62.2	27.7	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.1	4.4	3.3	-16.9	35.1	2.0	1.9	-18.4	36.4	-19.5	37.6	-20.7	38.6	-22.1	40.0
			-17.0	24.2	2.0	1.1	-18.5	25.0	-19.6	25.6	-20.7	26.3	-22.2	27.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-0.7	2.7	6.7	11.9	16.8	20.8	22.2	22.2	17.3	11.4	5.8	0.9
	DBStd	8.82	3.94	4.41	3.93	3.95	3.08	2.71	2.56	2.80	3.90	3.76	3.97	3.93
	HDD10.0	1127	333	207	113	26	1	0	0	1	29	135	283	
	HDD18.3	2864	591	439	361	193	66	9	2	4	66	215	376	542
	CDD10.0	1691	0	1	11	84	211	324	378	379	221	73	9	0
	CDD18.3	386	0	0	0	1	18	83	122	126	36	1	0	0
	CDH23.3	4162	0	0	1	41	232	847	1303	1312	399	28	0	0
	CDH26.7	1470	0	0	0	3	31	269	498	543	126	1	0	0
(14) Wind	WSAvg	0.9	0.6	0.9	1.3	1.3	1.2	1.1	1.1	1.0	0.9	0.7	0.7	0.6
(15) Precipitation	PrecAvg	774	45	40	43	64	81	96	101	62	69	63	53	58
	PrecMax	1098	82	86	93	125	183	161	208	125	129	157	147	145
	PrecMin	411	7	5	7	18	35	16	29	18	3	1	2	7
	PrecStd	167	24	23	25	27	35	42	51	32	36	37	33	40
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	17.6	22.3	26.8	29.2	33.4	34.8	35.4	32.0	26.2	19.5	12.8
		MCWB	6.9	10.4	11.6	16.0	18.4	20.9	21.1	20.9	19.1	16.6	12.4	7.7
	2%	DB	8.3	14.3	18.8	24.3	27.4	31.3	32.6	33.2	29.8	23.6	16.3	9.7
		MCWB	4.8	8.8	10.5	14.9	17.7	21.2	21.4	20.6	18.3	15.3	11.6	6.7
	5%	DB	6.2	11.7	16.2	22.0	25.9	29.6	31.0	31.6	27.8	20.9	13.7	7.7
		MCWB	4.3	7.4	9.2	13.5	17.3	20.8	20.8	20.3	17.8	14.5	10.3	5.3
	10%	DB	4.5	9.3	13.9	19.8	24.3	28.0	29.5	29.8	25.5	18.5	11.7	5.8
		MCWB	3.0	5.9	7.9	12.5	16.5	19.9	20.4	19.9	17.2	13.3	9.5	4.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	11.0	12.4	16.8	20.5	23.7	24.4	23.6	20.8	18.0	13.9	8.9
		MCDB	10.5	16.1	20.3	24.6	26.7	29.6	31.2	30.9	28.6	22.1	17.8	10.6
	2%	WB	6.0	9.4	11.1	15.5	18.9	22.7	22.9	22.5	19.4	16.4	12.5	7.3
		MCDB	7.3	13.4	17.6	23.1	25.3	28.8	29.2	29.3	26.4	21.4	15.2	9.7
	5%	WB	4.7	8.0	9.9	14.2	18.0	21.7	21.9	21.6	18.6	15.2	11.2	5.9
		MCDB	6.0	10.7	15.5	20.7	24.3	27.6	28.4	28.3	24.8	19.7	13.0	7.3
	10%	WB	3.3	6.7	8.6	13.0	17.1	20.7	21.1	20.8	17.8	14.0	9.9	4.6
		MCDB	4.3	8.9	13.0	18.3	22.8	26.6	27.8	27.5	23.7	17.7	11.8	5.8
(35) Mean Daily Temperature Range	MDBR		7.3	9.5	11.0	11.5	11.8	12.6	13.3	13.4	12.3	11.6	8.0	7.5
	5% DB	MCDBR	11.0	14.3	16.3	16.6	15.3	15.0	15.5	16.4	16.2	16.5	12.9	11.1
		MCWBR	7.5	8.9	8.6	7.4	6.6	6.3	5.6	5.3	5.9	8.6	7.9	7.6
	5% WB	MCDBR	9.5	13.3	14.8	15.0	13.9	14.0	13.7	13.7	13.7	14.9	10.8	10.0
		MCWBR	6.9	8.6	8.2	6.8	6.5	6.7	6.0	5.6	5.6	7.9	6.8	7.3
(40) Clear-Sky Solar Irradiance	taub		0.329	0.363	0.404	0.470	0.451	0.445	0.463	0.483	0.436	0.394	0.364	0.331
	taud		2.298	2.210	2.170	2.018	2.137	2.198	2.156	2.093	2.185	2.292	2.319	2.329
	Ebn at Noon		764	801	817	791	823	828	807	772	775	758	715	720
	Edh at Noon		82	108	129	163	150	141	146	150	126	99	81	73
(44) All-Sky Solar Radiation	RadAvg		1.36	2.16	3.32	4.50	5.43	6.09	6.04	5.41	3.87	2.60	1.50	1.11
	RadStd		0.18	0.30	0.44	0.48	0.46	0.54	0.45	0.49	0.37	0.33	0.20	0.15

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (75 neighbors)		+0.63	N/A	N/A	+0.89	N/A	N/A	-114	-168	+91	+44

Nomenclature: See separate page