

TARGU LOGRESTI, Romania

WMO: 153690

Lat: 44.8781N

Lon: 23.7086E

Elev: 864

StdP: 14.24

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.2	13.3	4.5	7.1	7.7	10.1	9.5	16.0	15.6	45.1	12.9	41.5	1.2	40	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.6	89.8	70.0	87.2	69.3	84.7	68.8	73.5	84.8	71.8	82.7	70.4	81.2	3.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.1	114.4	78.1	68.4	107.6	76.7	66.8	101.9	75.2	37.6	85.1	36.1	82.9	34.9	81.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	9.6	7.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	29.5	35.6	42.1	51.6	60.7	67.8	69.8	70.3	61.0	50.9	41.6	33.8
	DBStd	15.49	8.32	7.69	7.61	6.72	4.83	4.75	4.63	4.81	6.65	6.48	7.29	7.07
	HDD50	2199	636	404	259	60	2	0	0	0	2	69	265	502
	HDD65	5491	1101	823	709	401	146	26	12	13	153	438	702	967
	CDD50	2675	0	1	15	109	333	533	613	628	333	97	13	0
	CDD65	491	0	0	0	0	12	109	160	176	34	0	0	0
	CDH74	6049	0	0	0	63	274	1247	1875	2031	516	43	0	0
	CDH80	1973	0	0	0	3	26	347	645	817	134	1	0	0
Wind	WSAvg	2.3	1.6	2.3	2.4	2.8	2.7	2.9	2.6	2.4	2.3	2.1	1.6	1.8
Precipitation	PrecAvg	27.2	1.6	1.4	1.5	2.3	2.9	3.2	3.4	2.3	2.2	2.2	1.9	2.1
	PrecMax	44.7	3.6	3.1	3.9	5.4	7.8	6.0	8.5	5.8	4.4	5.7	4.4	5.4
	PrecMin	14.8	0.2	0.2	0.0	0.4	1.0	0.7	0.8	0.2	0.0	0.0	0.0	0.0
	PrecStd	6.5	1.0	0.9	1.0	1.1	1.5	1.5	2.0	1.5	1.3	1.3	1.1	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	62.0	72.1	79.5	82.9	90.2	92.6	93.9	87.9	78.7	66.2	58.2
		MCWB	45.3	49.4	55.5	60.4	65.4	71.1	71.5	70.3	66.2	61.5	53.7	46.4
	2%	DB	49.6	56.4	67.1	75.4	79.8	86.7	89.4	90.3	83.6	73.9	61.3	52.7
		MCWB	43.2	47.2	52.4	59.4	64.2	70.4	70.7	69.1	64.4	59.4	53.0	45.3
	5%	DB	45.2	51.9	61.7	70.4	77.2	84.0	86.4	87.7	79.7	68.8	57.1	48.5
		MCWB	40.0	44.6	49.7	55.6	62.9	70.0	70.1	68.7	63.5	56.8	51.1	42.8
	10%	DB	41.0	47.8	57.1	66.1	74.3	81.1	83.7	84.7	75.5	64.1	53.2	44.4
		MCWB	37.5	41.8	46.8	54.1	61.2	68.1	68.9	68.6	62.8	54.8	49.0	40.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	51.9	58.3	62.3	68.5	74.7	75.2	75.6	69.5	63.2	56.4	49.5
		MCDB	53.5	60.3	69.4	76.0	78.7	84.1	84.7	86.1	84.5	75.4	62.2	52.8
	2%	WB	43.7	48.3	53.6	60.1	66.2	72.7	73.1	73.6	66.7	60.2	54.6	46.1
		MCDB	48.6	55.7	65.2	73.0	76.5	83.5	84.6	84.8	78.4	70.8	59.9	51.4
	5%	WB	40.6	45.6	50.4	58.0	64.2	71.0	71.5	71.7	64.9	58.2	52.4	43.6
		MCDB	43.9	50.8	60.0	69.3	74.0	81.5	82.4	82.3	75.7	67.1	56.7	48.2
	10%	WB	37.9	42.9	48.0	55.2	62.5	69.3	70.2	69.8	63.6	55.9	49.9	41.3
		MCDB	40.6	46.7	55.2	63.7	71.4	79.8	80.7	80.8	73.4	62.7	53.1	44.3
Mean Daily Temperature Range	5% DB	MDBR	17.3	18.5	21.1	22.3	21.9	23.1	24.6	25.5	23.9	21.9	15.2	15.9
		MCDBR	23.8	26.3	31.8	31.7	27.9	27.1	28.7	31.1	30.4	32.5	23.7	23.7
		MCWBR	17.1	17.1	17.5	16.0	13.6	12.7	12.4	11.8	12.6	18.1	14.9	15.9
	5% WB	MCDBR	20.9	24.9	28.3	29.7	24.7	24.6	26.0	26.9	25.9	30.0	20.2	22.6
		MCWBR	15.1	16.4	16.0	15.1	12.9	12.2	12.7	12.4	11.3	17.1	13.1	15.6
Clear-Sky Solar Irradiance	taub	0.330	0.364	0.403	0.467	0.445	0.444	0.459	0.480	0.434	0.393	0.364	0.333	
	taud	2.300	2.214	2.175	2.018	2.150	2.195	2.160	2.091	2.184	2.287	2.308	2.324	
	Ebn at Noon	242	254	260	252	263	263	257	246	247	241	227	228	
	Edh at Noon	26	34	41	52	47	45	46	48	40	32	26	23	
All-Sky Solar Radiation	RadAvg	440	699	1075	1453	1770	1971	1963	1748	1257	834	476	358	
	RadStd	62	102	133	150	142	161	140	146	113	108	63	49	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (71 neighbors)	+1.03	N/A	N/A	+1.53	N/A	N/A	N/A	-277	+137	+61	

Nomenclature: See separate page