

PITESTI, Romania

WMO: 153730

Lat: 44.8489N

Lon: 24.8661E

Elev: 1041

StdP: 14.15

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	17.2	8.8	9.0	16.8	12.9	11.0	21.7	16.7	39.2	13.0	37.5	3.7	330	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.7	90.6	68.6	88.2	67.8	85.6	67.3	71.3	84.6	70.1	83.3	69.0	81.6	4.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.4	104.8	75.6	66.1	100.0	74.6	64.8	95.3	73.2	35.8	84.9	34.7	83.6	33.7	81.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	10.7	9.2		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.0	31.2	37.6	42.9	52.0	62.0	69.6	71.8	72.3	63.3	52.9	43.2	36.1
	DBStd	15.75	7.76	8.24	7.71	8.12	5.36	5.22	4.77	5.28	7.45	7.06	7.78	7.61
	HDD50	1963	582	352	238	74	2	0	0	0	1	53	228	433
	HDD65	5090	1046	768	685	391	120	17	6	9	120	378	653	897
	CDD50	3056	0	4	18	135	374	589	676	692	401	142	24	1
	CDD65	709	0	0	0	2	26	156	217	236	70	2	0	0
	CDH74	6741	0	0	0	64	271	1386	2000	2293	679	48	0	0
	CDH80	2370	0	0	0	5	37	463	715	947	201	2	0	0
(14) Wind	WSAvg	4.4	3.6	4.2	4.6	5.1	4.9	4.5	4.4	4.7	4.6	4.0	3.8	3.9
(15) Precipitation	PrecAvg	27.3	1.5	1.3	1.6	2.5	3.2	3.4	3.3	2.2	2.4	2.2	1.7	1.9
	PrecMax	44.4	3.1	3.0	3.9	7.0	6.7	6.2	6.9	5.9	6.9	5.4	4.3	5.2
	PrecMin	14.3	0.2	0.2	0.0	0.8	0.7	1.1	1.2	0.5	0.0	0.0	0.0	0.0
	PrecStd	6.2	0.9	0.7	1.0	1.5	1.5	1.4	1.6	1.3	1.7	1.3	1.1	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	64.3	70.1	80.2	84.4	93.3	93.4	95.4	90.1	78.9	67.4	59.6
		MCWB	45.3	50.9	52.4	60.0	65.2	69.0	69.4	69.3	66.7	60.5	54.6	46.3
	2%	DB	49.0	58.3	64.9	75.1	80.1	88.6	90.0	90.5	85.3	74.1	62.4	53.7
		MCWB	42.1	47.7	50.3	59.1	63.3	69.1	69.1	67.8	64.1	59.2	52.8	45.3
	5%	DB	45.1	53.4	60.0	70.7	77.1	85.5	86.9	88.3	81.4	69.4	57.9	50.0
		MCWB	40.3	45.0	48.4	56.5	62.2	68.3	68.4	67.2	62.9	57.0	51.3	45.3
	10%	DB	41.4	49.5	56.1	66.3	74.0	82.2	84.0	85.5	77.5	64.9	53.6	45.8
		MCWB	38.1	42.6	45.9	54.3	60.3	66.6	67.7	66.9	62.2	55.2	48.9	41.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	52.6	53.7	61.9	67.7	73.1	72.9	73.1	69.3	61.7	56.7	49.4
		MCDB	53.6	61.6	67.9	75.8	79.8	86.6	85.1	85.9	85.4	74.7	64.4	52.9
	2%	WB	43.7	48.6	51.1	59.8	64.8	70.9	71.2	70.9	66.2	59.9	54.6	47.2
		MCDB	48.0	56.7	62.8	73.2	76.3	84.5	84.2	84.3	78.8	71.3	61.2	53.0
	5%	WB	41.1	46.0	49.0	57.6	63.2	69.6	70.1	69.3	64.5	58.2	52.2	44.7
		MCDB	44.2	52.6	58.5	68.2	74.2	82.5	82.8	82.8	76.3	67.6	56.6	49.9
	10%	WB	38.7	43.5	47.0	55.5	61.5	68.2	68.9	68.1	63.2	56.1	50.2	42.0
		MCDB	41.4	48.6	54.6	64.0	71.5	79.5	80.8	81.4	74.3	63.0	53.9	45.8
(35) Mean Daily Temperature Range	5% DB	MDBR	13.3	15.3	16.9	18.9	19.6	20.8	21.3	22.7	20.4	18.0	13.5	13.4
		MCDBR	19.6	22.6	25.7	27.3	24.7	25.6	25.3	26.8	26.7	26.4	22.4	20.0
		MCWBR	12.8	13.7	13.6	12.4	10.5	9.5	8.7	7.8	9.0	12.5	12.9	12.5
	5% WB	MCDBR	16.1	22.2	23.4	23.7	22.9	23.5	22.7	24.0	22.4	23.9	18.9	19.3
		MCWBR	11.1	13.6	12.8	11.3	10.6	9.5	8.8	8.5	8.4	11.5	11.2	12.2
(40) Clear-Sky Solar Irradiance	taub		0.324	0.355	0.392	0.450	0.428	0.433	0.444	0.463	0.419	0.381	0.356	0.327
	taud		2.327	2.251	2.212	2.064	2.198	2.221	2.197	2.138	2.228	2.325	2.342	2.352
	Ebn at Noon		246	258	264	257	268	266	261	251	252	246	231	232
	Edh at Noon		25	33	39	49	45	44	44	45	38	30	25	23
(44) All-Sky Solar Radiation	RadAvg		447	712	1085	1453	1784	1950	1972	1753	1276	847	479	365
	RadStd		59	104	118	148	148	150	141	124	109	108	57	51

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (73 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	-270	+133	+59

Nomenclature: See separate page