

PLOIESTI, Romania

WMO: 153770

Lat: 44.9558N

Lon: 25.9875E

Elev: 585

StdP: 14.39

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.7	13.7	3.4	6.7	11.2	9.6	9.2	15.8	25.8	33.3	18.2	35.5	2.3	20	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.4	91.4	69.5	88.8	69.1	86.4	68.6	73.6	86.2	71.9	83.7	70.5	82.1	4.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.7	111.5	79.1	68.1	105.5	77.3	66.6	100.1	75.8	37.5	86.1	36.0	83.8	34.8	82.1	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	14.1	11.9	DB	-0.3	96.1	6.9	3.3	-5.3	98.4	-9.3	100.3	-13.1	102.1	-18.1	104.5	(4)
			WB	-0.6	77.1	6.9	2.4	-5.6	78.8	-9.6	80.2	-13.5	81.6	-18.5	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.7	29.9	35.6	42.7	52.5	62.4	70.4	72.5	72.7	64.3	52.9	42.1	33.1	(6)
(7)		DBStd	16.69	8.12	8.57	7.59	7.14	5.95	5.09	4.65	5.39	7.20	6.93	7.94	8.30	(7)
(8)		HDD50	2162	623	406	243	56	3	0	0	0	49	258	524	(8)	
(9)		HDD65	5276	1088	824	693	375	116	14	4	6	102	377	688	989	(9)
(10)		CDD50	3141	0	2	15	132	388	611	698	705	430	140	20	0	(10)
(11)		CDD65	781	0	0	0	1	37	175	237	246	82	3	0	0	(11)
(12)		CDH74	7832	0	0	1	65	474	1667	2244	2494	830	57	0	0	(12)
(13)		CDH80	2807	0	0	0	7	93	548	834	1057	263	5	0	0	(13)
(14)	Wind	WSAvg	4.6	4.0	4.5	5.6	5.6	5.2	4.7	4.3	4.3	4.5	3.9	4.1	3.9	(14)
(15)	Precipitation	PrecAvg	26.1	1.4	1.1	1.5	2.1	3.0	3.5	3.0	2.2	2.3	2.2	1.7	1.9	(15)
(16)		PrecMax	36.9	3.0	3.3	3.2	6.3	6.9	6.9	6.7	8.8	4.8	5.4	3.9	4.6	(16)
(17)		PrecMin	14.1	0.2	0.1	0.0	0.7	0.6	1.9	0.9	0.7	0.5	0.1	0.1	0.0	(17)
(18)		PrecStd	5.6	0.8	0.8	0.9	1.4	1.5	1.3	1.5	1.6	1.3	1.3	1.1	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	65.6	72.1	80.5	86.9	91.8	93.6	95.1	91.1	79.7	69.1	57.3	(19)
(20)		MCWB	44.5	52.9	54.2	61.2	65.7	71.7	71.5	70.1	67.7	63.1	57.5	49.2	(20)	
(21)		2%	DB	47.6	58.5	65.3	74.9	82.5	88.5	90.5	91.8	86.3	74.3	63.1	51.8	(21)
(22)		MCWB	42.8	48.9	51.4	59.0	65.0	70.3	70.5	68.7	65.3	60.4	54.4	47.6	(22)	
(23)		5%	DB	43.4	52.8	61.0	70.6	79.3	85.8	87.7	89.2	82.7	70.0	57.7	47.5	(23)
(24)		MCWB	40.6	46.0	49.2	56.2	63.1	68.9	70.2	68.4	65.4	58.6	51.4	43.5	(24)	
(25)		10%	DB	40.1	47.6	56.6	66.9	75.9	83.1	85.0	86.2	78.7	65.5	53.3	43.6	(25)
(26)		MCWB	38.0	42.7	46.7	55.1	61.4	67.9	69.4	68.5	64.0	56.6	48.9	40.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	54.5	55.5	62.5	69.4	74.7	76.1	76.0	71.4	65.2	58.1	51.3	(27)
(28)		MCDWB	50.3	63.2	68.9	77.0	83.0	87.1	87.2	88.8	84.4	77.4	67.7	54.5	(28)	
(29)		2%	WB	43.5	49.7	52.5	60.2	67.0	72.4	73.7	73.3	69.1	61.8	55.4	47.4	(29)
(30)		MCDWB	46.2	57.7	64.2	73.0	79.1	85.1	85.7	86.2	81.6	71.3	62.3	52.2	(30)	
(31)		5%	WB	40.9	46.5	50.1	58.1	64.7	70.8	72.0	71.3	66.6	59.5	52.8	44.1	(31)
(32)		MCDWB	43.5	51.9	59.0	68.5	75.9	82.7	83.5	82.8	77.6	68.2	57.1	47.4	(32)	
(33)		10%	WB	38.2	43.6	47.8	56.1	62.7	69.3	70.5	69.8	64.7	57.5	50.0	41.3	(33)
(34)		MCDWB	40.2	47.1	54.9	65.0	73.4	80.7	81.5	81.8	76.2	64.1	52.8	43.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	14.5	16.7	19.1	20.4	21.2	21.2	21.5	22.4	21.6	19.0	14.3	14.7	(35)	
(36)		5% DB	MCDBR	19.1	26.5	29.4	29.4	27.0	25.7	25.7	26.5	28.0	27.5	23.6	21.0	(36)
(37)		MCWBR	14.0	17.2	16.7	14.7	11.4	10.2	9.7	9.0	10.9	14.1	14.7	15.0	(37)	
(38)		5% WB	MCDBR	17.4	24.8	26.0	25.8	24.4	23.8	23.0	24.0	24.6	25.1	21.4	19.8	(38)
(39)		MCWBR	13.2	16.8	15.3	13.5	11.9	10.7	10.7	11.0	11.1	13.7	13.7	14.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.366	0.404	0.459	0.434	0.440	0.452	0.468	0.425	0.392	0.363	0.336	(40)	
(41)		taud	2.312	2.224	2.173	2.044	2.191	2.213	2.188	2.132	2.217	2.288	2.318	2.325	(41)	
(42)		Ebn at Noon	241	253	259	254	266	264	259	249	250	241	227	226	(42)	
(43)		Edh at Noon	26	34	41	50	45	44	45	46	39	31	26	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	433	695	1067	1443	1793	1931	1960	1758	1279	843	470	357	(44)	
(45)		RadStd	58	96	114	150	146	146	141	114	107	102	54	50	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (64 neighbors)	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	-270	+131	+63

Nomenclature: See separate page