

URZICENI, Romania

WMO: 154020

Lat: 44.7217N

Lon: 26.6572E

Elev: 201

StdP: 14.59

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.2	16.8	6.7	7.8	14.2	11.7	10.1	19.4	36.3	27.9	31.1	28.4	6.8	50	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.0	92.6	70.7	90.2	70.0	87.7	69.2	74.0	87.8	72.4	85.5	71.0	83.8	4.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	110.2	80.1	68.2	104.4	77.9	66.8	99.4	76.2	37.6	87.4	36.1	85.6	34.9	84.0	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.9	18.2	14.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	29.5	36.1	43.8	52.4	63.8	71.6	73.7	73.8	65.3	53.1	42.6	34.6
	DBStd	16.86	7.75	8.30	8.38	7.70	5.71	5.12	4.49	5.02	6.76	6.86	7.88	7.23
	HDD50	2085	635	392	224	63	1	0	0	0	0	47	246	477
	HDD65	5111	1100	808	657	382	87	8	1	4	81	371	671	941
	CDD50	3348	0	4	32	134	430	647	734	739	459	143	25	1
	CDD65	898	0	0	0	3	52	205	269	277	90	2	0	0
	CDH74	9374	0	0	7	102	588	2049	2724	2923	938	42	1	0
	CDH80	3640	0	0	0	15	129	757	1117	1300	318	4	0	0
Wind	WSAvg	5.1	5.4	5.9	6.7	5.9	5.3	4.6	4.3	4.5	4.4	4.4	4.5	5.8
Precipitation	PrecAvg	22.1	1.3	0.9	1.3	1.8	2.7	3.0	2.4	1.5	2.1	1.9	1.4	1.6
	PrecMax	30.6	2.9	2.9	3.0	4.2	8.3	5.3	7.6	3.9	5.5	4.6	3.6	3.9
	PrecMin	12.2	0.1	0.0	0.1	0.3	0.8	1.1	0.2	0.4	0.1	0.2	0.1	0.0
	PrecStd	5.0	0.8	0.7	0.8	0.9	1.9	1.2	1.7	0.9	1.5	1.2	1.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	64.4	73.7	81.7	88.0	93.6	96.6	95.3	91.5	80.0	69.2	56.1
		MCWB	45.0	55.0	55.7	61.9	64.4	73.1	75.0	71.4	67.1	63.5	58.0	49.8
	2%	DB	45.7	57.0	67.7	76.4	83.3	90.3	92.2	92.5	87.2	73.9	62.9	51.6
		MCWB	41.9	49.3	53.3	59.7	64.3	71.4	71.4	69.8	66.0	61.1	54.8	48.2
	5%	DB	42.3	52.0	62.8	71.1	80.2	87.3	89.3	90.2	83.6	69.5	57.3	47.3
		MCWB	39.5	46.5	50.5	56.7	63.3	70.5	70.8	69.4	65.0	58.2	52.6	43.8
	10%	DB	39.3	47.7	58.1	67.2	77.0	84.5	86.3	87.3	79.5	65.4	53.4	43.4
		MCWB	37.4	43.5	48.1	55.3	61.9	68.9	69.8	68.7	64.0	55.9	50.2	40.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	54.6	57.4	63.6	68.7	76.3	76.0	75.2	70.4	65.6	59.3	52.5
		MCDB	50.0	64.2	70.2	78.6	81.4	89.7	91.8	90.4	84.4	78.6	68.3	54.9
	2%	WB	42.4	50.2	53.7	60.9	66.4	73.7	73.8	73.2	67.9	61.9	55.9	47.9
		MCDB	45.1	55.6	65.3	74.6	79.2	86.8	87.7	86.5	81.5	71.3	61.4	51.7
	5%	WB	40.0	46.8	51.3	58.6	64.7	72.0	72.3	71.5	66.5	59.6	53.8	44.5
		MCDB	42.0	51.5	61.5	69.6	76.5	84.6	85.2	85.5	79.8	68.2	57.4	47.6
	10%	WB	37.6	44.0	48.7	56.3	63.1	70.3	70.9	70.0	64.9	57.3	50.9	41.6
		MCDB	39.1	47.4	56.1	65.4	74.1	82.3	83.0	83.9	76.9	63.5	53.9	43.5
Mean Daily Temperature Range	5% DB	MDBR	11.8	14.3	18.0	20.5	21.3	21.3	22.0	23.2	22.2	18.7	13.1	11.1
		MCDBR	15.3	22.7	28.1	29.5	26.6	25.3	27.3	27.6	28.8	26.9	21.3	16.9
		MCWBR	11.0	14.9	15.2	14.8	10.9	9.7	9.5	9.5	11.0	14.1	12.9	12.2
	5% WB	MCDBR	14.2	21.1	26.3	26.5	23.7	23.8	23.9	24.9	25.5	24.4	19.0	17.4
		MCWBR	10.6	14.2	14.9	13.7	10.7	10.0	9.3	9.7	10.6	13.3	11.8	12.6
Clear-Sky Solar Irradiance	taub		0.343	0.374	0.407	0.457	0.431	0.437	0.450	0.464	0.427	0.394	0.368	0.346
	taud		2.300	2.218	2.181	2.058	2.212	2.228	2.201	2.152	2.218	2.290	2.315	2.312
	Ebn at Noon		238	251	259	255	267	265	260	251	250	241	226	223
	Edh at Noon		26	34	41	50	44	43	44	45	39	32	26	24
All-Sky Solar Radiation	RadAvg		425	690	1069	1474	1853	1988	2017	1808	1312	849	464	355
	RadStd		63	100	114	152	136	139	134	102	101	99	57	50

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (64 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	-245	+139	+74	

Nomenclature: See separate page