

URZICENI, Romania

WMO: 154020

Lat: 44.7217N

Lon: 26.6572E

Elev: 61

StdP: 100.59

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.0	(c) -8.4	(d) -14.1	(e) 1.1	(f) -9.9	(g) -11.3	(h) 1.4	(i) -7.0	(j) 16.2	(k) -2.3	(l) 13.9	(m) -2.0	(n) 3.0	(o) 50	(p) 0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.2	(c) 33.7	(d) 21.5	(e) 32.3	(f) 21.1	(g) 30.9	(h) 20.7	(i) 23.3	(j) 31.0	(k) 22.5	(l) 29.7	(m) 21.7	(n) 28.8	(o) 2.1	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 21.0	(b) 15.7	(c) 26.7	(d) 20.1	(e) 14.9	(f) 25.5	(g) 19.4	(h) 14.2	(i) 24.5	(j) 69.6	(k) 30.8	(l) 66.2	(m) 29.8	(n) 63.4	(o) 28.9	(p) 26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.2	(b) 8.1	(c) 6.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 10.2	(b) 8.1	(c) 6.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	-1.4	2.3	6.6	11.3	17.7	22.0	23.1	23.2	18.5	11.7	5.9	1.5		
	DBStd	9.37	4.31	4.61	4.65	4.28	3.17	2.84	2.49	2.79	3.76	3.81	4.38	4.01		
	HDD10.0	1158	353	218	124	35	1	0	0	0	0	26	137	265		
	HDD18.3	2839	611	449	365	212	48	4	1	2	45	206	373	523		
	CDD10.0	1860	0	2	18	74	239	359	408	411	255	79	14	1		
	CDD18.3	499	0	0	0	2	29	114	149	154	50	1	0	0		
	CDH23.3	5208	0	0	4	57	327	1138	1513	1624	521	23	1	0		
	CDH26.7	2022	0	0	0	8	72	421	621	722	177	2	0	0		
(14) Wind	WSAvg	2.3	2.4	2.6	3.0	2.6	2.4	2.1	1.9	2.0	2.0	2.0	2.0	2.6		
(15) Precipitation	PrecAvg	562	32	23	33	46	68	75	62	38	54	49	36	40		
	PrecMax	778	74	73	75	107	210	134	194	99	140	118	92	98		
	PrecMin	310	3	1	2	7	21	28	6	10	2	4	3	1		
	PrecStd	128	20	18	21	24	48	31	42	23	38	31	25	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	18.0	23.2	27.6	31.1	34.2	35.9	35.2	33.0	26.7	20.7	13.4		
		MCWB	7.2	12.8	13.2	16.6	18.0	22.8	23.9	21.9	19.5	17.5	14.5	9.9		
	2%	DB	7.6	13.9	19.8	24.6	28.5	32.4	33.4	33.6	30.7	23.3	17.1	10.9		
		MCWB	5.5	9.6	11.8	15.4	17.9	21.9	21.9	21.0	18.9	16.2	12.7	9.0		
	5%	DB	5.7	11.1	17.1	21.7	26.8	30.7	31.9	32.3	28.6	20.8	14.1	8.5		
		MCWB	4.2	8.1	10.3	13.7	17.4	21.4	21.5	20.8	18.3	14.5	11.5	6.6		
	10%	DB	4.0	8.7	14.5	19.6	25.0	29.1	30.1	30.7	26.4	18.6	11.9	6.3		
		MCWB	3.0	6.4	8.9	12.9	16.6	20.5	21.0	20.4	17.8	13.3	10.1	5.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	12.6	14.1	17.5	20.4	24.6	24.4	24.0	21.3	18.7	15.2	11.4		
		MCDB	10.0	17.9	21.2	25.9	27.5	32.1	33.2	32.5	29.1	25.9	20.2	12.7		
	2%	WB	5.8	10.1	12.0	16.0	19.1	23.2	23.2	22.9	19.9	16.6	13.3	8.8		
		MCDB	7.3	13.1	18.5	23.7	26.2	30.4	31.0	30.3	27.5	21.8	16.3	10.9		
	5%	WB	4.4	8.2	10.7	14.8	18.2	22.2	22.4	21.9	19.2	15.3	12.1	7.0		
		MCDB	5.6	10.8	16.4	20.9	24.7	29.2	29.5	29.7	26.6	20.1	14.1	8.6		
	10%	WB	3.1	6.7	9.3	13.5	17.3	21.3	21.6	21.1	18.3	14.1	10.5	5.3		
		MCDB	4.0	8.5	13.4	18.6	23.4	27.9	28.3	28.8	25.0	17.5	12.1	6.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	8.0	10.0	11.4	11.8	11.8	12.2	12.9	12.3	10.4	7.3	6.2		
		MCDBR	8.5	12.6	15.6	16.4	14.8	14.1	15.2	15.4	16.0	14.9	11.8	9.4		
	5% WB	MCWBR	6.1	8.3	8.4	8.2	6.1	5.4	5.3	5.3	6.1	7.9	7.2	6.8		
		MCWBR	7.9	11.7	14.6	14.7	13.2	13.2	13.3	13.9	14.1	13.5	10.6	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.343	0.374	0.407	0.457	0.431	0.437	0.450	0.464	0.427	0.394	0.368	0.346		
	taud		2.300	2.218	2.181	2.058	2.212	2.228	2.201	2.152	2.218	2.290	2.315	2.312		
	Ebn at Noon		750	791	817	804	842	836	819	790	787	760	713	704		
	Edh at Noon		83	108	128	157	139	137	140	142	122	100	82	75		
(44) All-Sky Solar Radiation	RadAvg		1.34	2.17	3.37	4.65	5.84	6.27	6.36	5.70	4.14	2.68	1.46	1.12		
	RadStd		0.20	0.32	0.36	0.48	0.43	0.44	0.42	0.32	0.32	0.31	0.18	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	-136	+77	+41

Nomenclature: See separate page