

DROBETA-TURNU SEVERIN, RomaniaWMO: **154100**Lat: **44.6264N**Lon: **22.6261E**Elev: **78**StdP: **100.39**Time Zone: **2.00 (EUE)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.9	(c) -7.4	(d) -13.8	(e) 1.1	(f) -7.1	(g) -11.1	(h) 1.5	(i) -5.1	(j) 12.1	(k) 1.3	(l) 10.5	(m) 1.1	(n) 1.3	(o) 10	(p) 0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.1	(c) 35.0	(d) 20.9	(e) 33.3	(f) 20.7	(g) 31.7	(h) 20.3	(i) 23.0	(j) 30.5	(k) 22.1	(l) 29.8	(m) 21.3	(n) 28.9	(o) 2.1	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 20.7	(b) 15.5	(c) 26.2	(d) 19.7	(e) 14.6	(f) 25.2	(g) 18.9	(h) 13.8	(i) 24.2	(j) 68.3	(k) 30.4	(l) 64.9	(m) 30.2	(n) 62.1	(o) 28.9	(p) 27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.0	6.4	-13.1	37.3	3.0	2.1	-15.2	38.8	-17.0	40.1	-18.7	41.3	-20.9	42.8
			-13.4	24.1	2.9	1.4	-15.6	25.0	-17.3	25.8	-18.9	26.6	-21.1	27.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	0.7	3.0	7.8	13.2	18.2	22.0	24.2	24.3	19.1	13.1	7.3	1.9		
	DBStd	9.17	4.36	4.86	4.32	3.49	3.25	3.19	2.87	2.97	3.62	3.98	3.92	4.14		
	HDD10.0	962	289	199	94	11	0	0	0	0	17	99	252			
	HDD18.3	2558	548	431	328	157	44	7	1	34	167	332	509			
	CDD10.0	2036	1	3	24	107	253	360	442	444	272	113	17	1		
	CDD18.3	591	0	0	0	3	39	117	184	187	57	4	0	0		
	CDH23.3	5777	0	0	1	49	354	1133	1886	1845	463	45	0	0		
	CDH26.7	2412	0	0	0	8	71	443	875	861	148	6	0	0		
(14) Wind	WSAvg	2.0	1.9	2.1	2.4	2.1	1.9	2.0	2.1	1.8	1.9	1.7	1.8	1.9		
(15) Precipitation	PrecAvg	686	46	43	42	61	69	70	68	45	66	56	53	67		
	PrecMax	1186	88	138	107	137	163	178	248	170	228	153	120	182		
	PrecMin	335	6	2	0	3	24	8	7	3	4	1	0	1		
	PrecStd	171	25	32	29	30	36	42	52	39	49	40	35	52		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	17.8	22.6	28.0	30.2	35.0	37.7	37.2	33.0	27.4	20.4	13.7		
		MCWB	7.9	10.2	12.0	16.6	18.4	21.3	20.6	21.2	19.5	17.0	13.6	8.7		
	2%	DB	10.7	14.8	19.8	24.5	28.6	33.0	35.1	35.1	30.4	24.3	17.0	10.6		
		MCWB	6.5	8.9	11.2	14.9	18.1	21.0	20.7	21.1	18.7	16.0	11.9	7.3		
	5%	DB	8.2	12.0	17.2	22.1	27.1	31.1	33.3	33.3	28.2	21.8	14.7	8.8		
		MCWB	5.2	7.3	9.8	13.5	17.6	20.6	20.8	20.7	17.9	15.1	11.2	6.1		
	10%	DB	6.3	9.6	14.9	20.0	25.4	29.4	31.5	31.4	26.0	19.3	13.0	7.3		
		MCWB	4.2	6.0	8.8	12.7	16.9	20.0	20.4	20.1	17.3	14.0	10.3	5.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	10.9	13.0	17.6	20.8	23.7	23.9	24.9	21.5	18.8	14.2	9.5		
		MCDB	13.0	16.3	20.3	25.3	27.8	31.1	31.7	32.3	29.3	23.4	17.9	12.6		
	2%	WB	7.0	9.3	11.6	15.9	19.4	22.5	22.7	23.1	19.7	16.8	13.0	7.9		
		MCDB	10.0	13.5	18.2	22.4	26.1	30.1	30.5	30.2	26.8	22.0	15.9	10.1		
	5%	WB	5.7	7.8	10.5	14.7	18.4	21.5	21.9	21.9	18.8	15.7	11.8	6.5		
		MCDB	7.8	10.9	16.3	20.2	25.0	28.9	29.7	29.8	25.6	20.7	14.1	8.3		
	10%	WB	4.4	6.5	9.4	13.5	17.5	20.6	21.2	21.0	18.0	14.5	10.7	5.4		
		MCDB	6.2	9.5	14.0	18.5	23.7	27.6	28.7	28.7	24.3	18.6	12.7	7.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.6	9.7	10.5	10.9	11.5	12.1	12.0	10.5	9.2	6.7	5.9		
		MCDBR	10.2	12.6	14.4	14.7	14.1	14.3	15.0	15.0	13.9	13.4	10.6	8.6		
	5% WB	MCWBR	6.6	7.3	7.2	6.6	5.6	5.1	4.6	4.5	4.9	6.1	6.1	5.6		
		MCWBR	9.1	11.0	12.8	12.7	12.6	13.2	13.1	13.3	12.1	12.1	8.9	7.6		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.375	0.415	0.479	0.459	0.451	0.465	0.485	0.449	0.407	0.375	0.344		
	taud		2.268	2.175	2.152	2.003	2.122	2.192	2.159	2.096	2.157	2.265	2.295	2.302		
	Ebn at Noon		747	788	808	785	816	824	806	771	765	747	704	706		
	Edh at Noon		86	113	132	166	152	142	146	150	130	103	84	76		
(44) All-Sky Solar Radiation	RadAvg		1.35	2.14	3.36	4.58	5.58	6.27	6.25	5.54	3.93	2.55	1.46	1.15		
	RadStd		0.19	0.30	0.45	0.51	0.47	0.55	0.43	0.52	0.36	0.35	0.21	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-160	+139	+74	(46)
(47) Regional (63 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-156	+106	+58	(47)

Nomenclature: See separate page