

CAMPIA TURZII, Romania

WMO: 154215

Lat: 46.502N

Lon: 23.886E

Elev: 330

StdP: 97.42

Time Zone: 2.00 (EUE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-11.1	-17.0	0.9	-14.5	-13.2	1.2	-10.4	9.5	1.6	8.2	0.5	0.8	330	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	32.2	20.1	30.8	19.8	29.0	19.2	21.7	28.7	21.0	28.1	20.1	26.9	3.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.5	24.9	18.2	13.7	23.6	17.9	13.4	23.1	65.2	29.0	62.3	27.9	58.9	27.0	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.0	5.6	-17.1	35.1	4.9	2.0	-20.7	36.5	-23.5	37.7	-26.3	38.9	-29.9	40.3		
			-16.6	23.3	4.6	0.9	-20.0	24.0	-22.7	24.5	-25.3	25.0	-28.6	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-2.3	0.3	5.7	11.4	15.9	19.4	21.1	21.2	16.1	10.2	4.5	-0.7
	DBStd	9.07	4.97	5.11	4.15	3.12	3.23	2.99	2.76	2.76	3.31	3.73	4.18	4.03
	HDD10.0	1359	382	271	140	19	2	0	0	0	1	44	169	331
	HDD18.3	3208	641	504	392	207	89	24	7	7	81	253	414	589
	CDD10.0	1465	0	0	7	62	183	282	344	347	186	50	5	0
	CDD18.3	271	0	0	0	1	12	56	92	96	14	1	0	0
	CDH23.3	3064	0	0	0	28	196	558	982	1051	236	13	0	0
	CDH26.7	1024	0	0	0	3	28	154	364	418	54	2	0	0
Wind	WSAvg	2.2	1.7	2.1	2.8	2.6	2.5	2.5	2.4	2.1	2.2	1.8	1.6	1.7
Precipitation	PrecAvg	537	22	18	25	44	64	90	85	49	54	43	32	30
	PrecMax	730	44	45	71	75	106	191	136	91	141	89	70	54
	PrecMin	345	7	7	5	4	21	18	16	3	6	1	0	4
	PrecStd	101	11	10	18	19	24	36	33	25	31	24	15	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	14.2	20.9	26.8	29.1	32.1	35.0	34.9	30.8	24.9	18.1	11.0
		MCWB	6.8	9.0	11.4	15.6	16.6	20.6	19.5	19.4	16.9	15.7	12.9	8.3
	2%	DB	7.1	11.1	18.0	23.1	27.1	30.1	32.2	32.9	28.1	22.1	15.0	8.0
		MCWB	5.7	7.6	10.0	14.2	17.0	20.4	20.1	20.2	16.9	14.6	11.4	6.7
	5%	DB	5.1	9.0	15.2	21.0	25.9	28.8	30.2	30.9	26.1	20.0	12.9	6.0
		MCWB	4.3	6.5	9.0	12.8	16.6	19.6	20.0	19.6	16.2	14.1	9.8	5.1
	10%	DB	3.6	7.0	13.0	19.0	23.2	26.9	28.4	29.0	24.0	17.2	11.0	4.2
		MCWB	2.8	5.4	7.8	11.8	16.0	19.0	19.3	19.4	16.1	12.3	8.7	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	9.7	12.5	16.3	19.6	22.7	22.3	23.0	19.0	16.7	13.5	8.5
		MCDB	8.9	13.5	19.0	24.3	26.4	29.7	29.5	31.0	27.0	23.2	17.0	10.5
	2%	WB	5.7	8.0	10.6	14.9	18.1	21.5	21.5	21.7	18.0	15.3	11.8	6.5
		MCDB	6.8	10.9	16.6	22.6	24.6	28.1	28.8	28.7	25.7	20.7	14.5	7.6
	5%	WB	4.2	6.6	9.4	13.6	17.1	20.3	20.8	20.9	17.1	14.2	10.5	4.9
		MCDB	5.0	8.4	14.7	19.5	23.7	26.4	28.1	28.1	23.9	19.0	12.6	5.7
	10%	WB	2.6	5.2	8.1	12.4	16.2	19.5	19.9	19.9	16.2	13.1	8.9	3.5
		MCDB	3.2	6.7	12.4	17.3	22.2	25.2	26.9	26.8	21.9	17.0	10.4	4.0
Mean Daily Temperature Range	5% DB	MDBR	6.5	8.0	11.0	12.6	12.3	12.2	13.1	13.8	13.1	12.1	8.6	5.4
		MCDBR	7.7	10.8	15.7	16.4	15.9	15.2	16.2	17.1	17.0	16.0	12.4	8.0
		MCWBR	6.2	7.5	8.9	8.4	7.2	6.5	6.2	6.4	7.3	9.1	8.6	6.3
	5% WB	MCDBR	7.5	10.2	14.4	14.6	14.2	13.3	14.2	14.6	14.5	14.7	11.2	7.5
		MCWBR	6.0	7.3	8.3	7.7	7.0	6.3	5.9	6.3	7.0	8.8	8.1	6.2
Clear-Sky Solar Irradiance	taub	0.312	0.338	0.379	0.427	0.412	0.409	0.427	0.433	0.394	0.363	0.339	0.313	
	taud	2.347	2.307	2.252	2.153	2.256	2.293	2.246	2.228	2.309	2.378	2.396	2.373	
	Ebn at Noon	773	823	838	828	855	858	835	813	814	785	734	726	
	Edh at Noon	75	95	117	141	132	128	132	130	109	88	72	66	
All-Sky Solar Radiation	RadAvg	1.24	2.06	3.19	4.35	5.30	5.81	5.71	5.26	3.75	2.57	1.46	0.96	
	RadStd	0.17	0.25	0.43	0.44	0.49	0.49	0.49	0.49	0.42	0.31	0.20	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (71 neighbors)		+0.74	N/A	N/A	+0.99	N/A	N/A	-149	-215	+92	+23

Nomenclature: See separate page