

SLOBOZIA, Romania

WMO: 154250

Lat: 44.5528N

Lon: 27.3836E

Elev: 52

StdP: 100.70

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.0	(c) -8.5	(d) -13.2	(e) 1.2	(f) -10.0	(g) -11.0	(h) 1.5	(i) -7.2	(j) 15.9	(k) -4.3	(l) 13.4	(m) -4.1	(n) 3.7	(o) 240	(p) 0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.7	(c) 33.8	(d) 21.0	(e) 32.5	(f) 20.6	(g) 31.1	(h) 20.2	(i) 23.0	(j) 29.9	(k) 22.2	(l) 29.1	(m) 21.5	(n) 28.3	(o) 3.4	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.8	25.5	20.2	14.9	24.7	19.4	14.3	24.0	68.4	29.8	65.4	29.3	62.8	28.1	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 10.9	(b) 9.2	(c) 7.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-1.6	3.1	6.7	11.1	17.0	21.9	23.5	23.7	18.9	12.2	5.9	1.5
	DBStd	9.43	4.63	4.70	4.48	4.10	3.12	2.93	2.50	2.85	3.81	4.42	4.71	3.68
	HDD10.0	1148	359	198	120	37	1	0	0	0	29	139	264	
	HDD18.3	2823	618	428	361	218	62	6	1	2	41	193	372	522
	CDD10.0	1893	0	3	17	69	219	358	418	424	267	99	17	1
	CDD18.3	525	0	0	0	1	22	113	161	167	58	3	0	0
	CDH23.3	5288	0	0	3	31	244	1043	1601	1752	568	45	1	0
	CDH26.7	2116	0	0	0	3	43	386	686	792	198	8	0	0
(14) Wind	WSAvg	3.4	3.9	4.0	3.9	3.9	3.2	3.0	2.9	3.0	2.9	3.1	3.1	3.8
(15) Precipitation	PrecAvg	496	31	20	31	33	58	68	46	40	50	40	35	40
	PrecMax	710	84	56	72	91	156	115	110	97	147	79	104	112
	PrecMin	320	3	1	0	4	11	13	7	9	1	3	0	3
	PrecStd	101	20	14	19	17	36	25	26	25	35	22	24	30
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	18.8	22.9	26.6	29.8	34.7	36.1	35.5	33.0	27.4	21.2	13.2
		MCWB	8.3	12.7	13.7	18.1	19.0	23.0	22.6	21.0	19.2	17.7	15.6	10.7
	2%	DB	8.2	14.6	19.5	23.5	27.7	32.3	33.7	33.7	30.7	24.0	17.0	10.5
		MCWB	6.3	9.9	12.3	16.1	18.4	21.5	21.1	20.7	18.6	16.1	13.5	8.5
	5%	DB	6.0	12.0	16.6	21.2	26.0	30.6	32.2	32.5	28.9	21.6	14.5	8.3
		MCWB	5.0	8.2	10.7	14.3	17.8	21.0	20.8	20.4	18.1	15.0	12.2	7.0
	10%	DB	4.1	9.6	13.9	19.1	24.2	28.8	30.6	31.0	26.7	19.3	12.6	6.3
		MCWB	3.2	7.2	9.1	13.2	16.6	20.4	20.5	20.0	17.7	14.1	10.9	4.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	13.2	14.8	18.8	21.2	24.0	24.5	23.9	21.3	18.6	15.9	11.2
		MCDB	10.4	18.3	21.7	26.0	27.7	32.6	32.7	31.1	27.4	25.9	20.1	13.5
	2%	WB	6.6	10.7	12.5	16.6	19.7	22.8	22.9	22.7	20.3	17.0	14.0	8.8
		MCDB	7.8	14.4	18.1	22.8	26.1	29.5	29.5	30.0	26.3	21.7	16.7	10.3
	5%	WB	5.0	8.8	11.0	15.2	18.6	22.0	22.1	21.8	19.4	15.8	12.7	7.3
		MCDB	5.9	11.4	15.8	20.7	24.3	29.0	28.8	28.8	25.6	20.9	14.3	8.7
	10%	WB	3.5	7.2	9.5	13.7	17.6	21.1	21.4	21.1	18.5	14.7	11.2	5.2
		MCDB	4.1	9.4	13.2	17.9	22.8	27.5	27.9	28.6	25.2	18.5	12.7	6.3
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.8	9.9	11.3	11.7	11.8	12.3	12.7	11.9	10.3	7.3	6.1
		MCDBR	8.1	12.5	15.3	15.3	14.4	14.5	15.2	14.8	15.2	14.3	10.5	9.1
	5% WB	MCWBR	6.4	8.2	8.8	8.7	6.4	5.5	4.7	4.7	5.4	7.1	6.5	7.0
		MCWBR	7.6	11.6	14.4	15.1	13.2	13.7	12.6	13.2	13.3	12.9	9.5	9.4
(40) Clear-Sky Solar Irradiance	taub	taub	0.344	0.373	0.406	0.459	0.433	0.437	0.450	0.463	0.430	0.392	0.366	0.346
		taud	2.296	2.223	2.184	2.049	2.207	2.228	2.200	2.153	2.211	2.304	2.325	2.316
	Ebn at Noon	Ebn at Noon	751	793	818	804	841	837	820	792	785	766	718	707
		Edh at Noon	84	108	128	159	140	137	140	142	123	99	82	75
(44) All-Sky Solar Radiation	RadAvg	1.33	2.15	3.36	4.72	5.97	6.44	6.52	5.83	4.23	2.69	1.48	1.12	
	RadStd	0.20	0.32	0.35	0.48	0.40	0.42	0.39	0.32	0.30	0.30	0.18	0.15	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-123	+70	+44

Nomenclature: See separate page