

SLATINA, Romania

WMO: 154340

Lat: 44.4422N

Lon: 24.3544E

Elev: 569

StdP: 14.40

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.9	16.4	9.3	9.0	13.3	13.6	11.2	18.0	26.9	37.4	22.1	29.9	2.9	90	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.2	92.7	70.0	90.3	69.4	87.6	68.5	74.6	85.2	72.5	84.3	71.0	82.8	4.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	119.4	79.9	69.1	109.0	76.6	67.3	102.3	75.4	38.5	84.1	36.5	83.8	35.1	82.9	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	16.9	13.5		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	29.7	37.7	45.2	52.8	62.8	70.9	73.3	74.0	65.1	53.6	41.9	34.7	(6)
	DBStd	16.49	8.56	7.90	7.69	7.26	5.49	5.12	4.41	5.14	6.43	7.57	7.77	6.46	(7)
	HDD50	2005	630	348	185	55	0	0	0	0	0	52	262	473	(8)
	HDD65	5029	1095	763	615	369	106	9	1	5	78	357	693	938	(9)
	CDD50	3305	0	4	36	138	398	627	723	743	454	163	19	0	(10)
	CDD65	856	0	0	0	2	39	186	259	283	83	4	0	0	(11)
	CDH74	9222	0	0	3	67	436	1908	2773	3098	869	68	0	0	(12)
	CDH80	3612	0	0	0	5	70	720	1132	1409	270	6	0	0	(13)
(14) Wind	WSAvg	4.5	4.0	4.7	5.4	6.0	5.1	3.9	4.1	4.3	4.6	3.9	4.0	4.2	(14)
(15) Precipitation	PrecAvg	22.7	1.4	1.1	1.5	2.0	2.4	2.7	2.7	1.8	2.1	1.9	1.5	1.6	(15)
	PrecMax	40.6	3.0	2.5	4.2	5.7	5.2	5.1	8.2	5.4	5.4	4.5	4.2	5.9	(16)
	PrecMin	11.6	0.2	0.1	0.2	0.5	0.4	0.7	0.7	0.1	0.0	0.0	0.0	0.0	(17)
	PrecStd	6.2	0.8	0.7	1.1	1.1	1.2	1.3	1.8	1.3	1.5	1.2	1.0	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	63.6	73.3	79.9	86.0	95.2	95.3	97.2	90.6	80.2	66.3	55.5	(19)
		MCWB	46.0	51.9	56.9	62.0	66.8	70.9	71.3	68.8	67.3	65.2	57.5	48.0	(20)
	2%	DB	47.1	57.6	68.0	75.2	82.2	90.4	92.1	93.1	86.2	75.3	60.7	50.8	(21)
		MCWB	43.2	50.2	54.3	59.6	65.3	70.2	70.8	69.0	65.3	61.5	53.9	45.4	(22)
	5%	DB	43.3	53.0	63.1	70.2	79.2	86.9	89.5	90.5	82.4	71.0	56.1	47.0	(23)
		MCWB	40.8	47.0	51.2	56.4	63.7	69.5	70.0	69.0	64.3	58.7	51.8	43.3	(24)
	10%	DB	40.3	49.0	58.9	66.4	75.8	83.9	86.4	87.8	78.6	66.9	52.6	43.9	(25)
		MCWB	38.2	44.8	49.0	55.0	62.1	68.5	68.9	68.5	63.8	57.2	49.5	41.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	54.7	60.0	63.1	70.7	75.3	77.1	79.7	71.9	67.3	59.0	49.2	(27)
		MCDB	51.4	61.7	69.5	77.5	82.3	87.8	89.1	87.9	84.0	78.1	66.4	53.7	(28)
	2%	WB	43.5	50.5	54.8	60.7	67.5	72.8	73.5	75.7	68.9	62.5	55.6	46.3	(29)
		MCDB	45.7	56.7	65.1	74.3	78.5	85.5	86.0	84.4	80.4	71.1	60.1	50.8	(30)
	5%	WB	41.1	47.8	52.2	58.4	65.2	71.2	71.9	72.8	66.5	60.3	53.0	44.0	(31)
		MCDB	43.2	52.1	61.8	68.4	75.2	83.0	84.3	82.7	76.9	69.3	55.9	47.0	(32)
	10%	WB	38.4	45.1	49.8	56.3	63.1	69.7	70.6	70.5	64.8	58.3	50.4	41.4	(33)
		MCDB	39.9	48.6	57.6	64.6	73.2	80.9	82.5	82.3	75.7	65.8	52.6	43.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	15.1	18.0	19.4	20.5	22.1	23.0	24.2	22.2	19.0	11.7	11.6	(35)
		MCDBR	16.5	22.5	27.3	27.0	25.6	27.1	27.6	28.5	27.9	27.5	18.9	17.8	(36)
		MCWBR	12.1	14.9	15.1	13.0	11.1	9.7	9.2	9.2	10.5	13.8	11.8	12.6	(37)
	5% WB	MCDBR	15.7	21.7	25.4	24.9	24.4	24.1	24.2	24.3	23.9	25.2	16.0	17.7	(38)
		MCWBR	11.8	14.6	14.6	12.4	11.4	10.4	9.3	11.3	10.5	13.2	10.5	12.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.335	0.365	0.401	0.458	0.435	0.439	0.452	0.470	0.430	0.391	0.365	0.338	(40)
	taud		2.311	2.234	2.198	2.052	2.189	2.214	2.186	2.129	2.206	2.306	2.326	2.331	(41)
	Ebn at Noon		243	255	262	255	266	265	259	249	249	243	229	228	(42)
	Edh at Noon		26	34	40	50	45	44	45	46	39	31	26	23	(43)
(44) All-Sky Solar Radiation	RadAvg		452	722	1111	1510	1859	2055	2066	1816	1315	852	475	368	(44)
	RadStd		68	114	126	146	138	144	132	125	107	112	63	53	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (68 neighbors)		+0.94	N/A	N/A	N/A	N/A	N/A	N/A	-270	+130	N/A	

Nomenclature: See separate page