

SLATINA, Romania

WMO: 154340

Lat: 44.4422N

Lon: 24.3544E

Elev: 173

StdP: 99.26

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-8.7	-12.6	1.3	-10.4	-10.2	1.6	-7.8	12.0	3.0	9.9	-1.1	1.3	90	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.5	33.7	21.1	32.4	20.8	30.9	20.3	23.7	29.6	22.5	29.0	21.6	28.2	2.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.1	26.6	20.6	15.6	24.8	19.6	14.6	24.1	71.8	29.0	67.0	28.8	63.7	28.3	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	7.6	6.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	-1.3	3.2	7.3	11.5	17.1	21.6	23.0	23.3	18.4	12.0	5.5	1.5
	DBStd	9.16	4.76	4.39	4.27	4.03	3.05	2.84	2.45	2.86	3.57	4.20	4.32	3.59
	HDD10.0	1114	350	193	103	31	0	0	0	0	0	29	146	263
	HDD18.3	2794	608	424	342	205	59	5	1	3	43	198	385	521
	CDD10.0	1836	0	2	20	77	221	348	402	413	252	91	11	0
	CDD18.3	476	0	0	0	1	22	103	144	157	46	2	0	0
	CDH23.3	5123	0	0	2	37	242	1060	1541	1721	483	38	0	0
	CDH26.7	2007	0	0	0	3	39	400	629	783	150	3	0	0
Wind	WSAvg	2.0	1.8	2.1	2.4	2.7	2.3	1.8	1.9	1.9	2.1	1.8	1.8	1.9
Precipitation	PrecAvg	577	36	29	38	51	61	68	68	45	53	47	37	41
	PrecMax	1031	75	64	106	144	132	129	208	136	137	114	107	149
	PrecMin	295	6	3	4	13	11	17	19	2	1	0	0	0
	PrecStd	157	20	19	28	27	31	34	45	33	38	30	25	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	17.6	22.9	26.6	30.0	35.1	35.2	36.2	32.6	26.8	19.1	13.0
		MCWB	7.8	11.1	13.9	16.7	19.3	21.6	21.8	20.5	19.6	18.5	14.2	8.9
	2%	DB	8.4	14.2	20.0	24.0	27.9	32.4	33.4	33.9	30.1	24.1	16.0	10.4
		MCWB	6.2	10.1	12.4	15.3	18.5	21.2	21.5	20.6	18.5	16.4	12.2	7.5
	5%	DB	6.3	11.7	17.3	21.2	26.2	30.5	32.0	32.5	28.0	21.7	13.4	8.4
		MCWB	4.9	8.4	10.7	13.5	17.6	20.9	21.1	20.6	17.9	14.9	11.0	6.3
	10%	DB	4.6	9.4	15.0	19.1	24.3	28.8	30.2	31.0	25.9	19.4	11.5	6.6
		MCWB	3.5	7.1	9.5	12.8	16.7	20.3	20.5	20.3	17.7	14.0	9.7	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	12.6	15.6	17.3	21.5	24.1	25.0	26.5	22.2	19.6	15.0	9.6
		MCDB	10.8	16.5	20.8	25.3	27.9	31.0	31.7	31.1	28.9	25.6	19.1	12.1
	2%	WB	6.4	10.3	12.7	16.0	19.7	22.7	23.1	24.3	20.5	17.0	13.1	7.9
		MCDB	7.6	13.7	18.4	23.5	25.8	29.7	30.0	29.1	26.9	21.7	15.6	10.5
	5%	WB	5.1	8.8	11.2	14.7	18.4	21.8	22.2	22.7	19.2	15.7	11.7	6.7
		MCDB	6.2	11.1	16.6	20.2	24.0	28.4	29.1	28.2	25.0	20.7	13.3	8.3
	10%	WB	3.6	7.3	9.9	13.5	17.3	21.0	21.4	21.4	18.2	14.6	10.2	5.2
		MCDB	4.4	9.2	14.2	18.1	22.9	27.2	28.0	27.9	24.3	18.8	11.5	6.5
Mean Daily Temperature Range	5% DB	MDBR	6.9	8.4	10.0	10.8	11.4	12.3	12.8	13.5	12.3	10.6	6.5	6.4
		MCDBR	9.2	12.5	15.1	15.0	14.2	15.1	15.3	15.8	15.5	15.3	10.5	9.9
		MCWBR	6.7	8.3	8.4	7.2	6.2	5.4	5.1	5.1	5.8	7.7	6.6	7.0
	5% WB	MCDBR	8.7	12.0	14.1	13.8	13.5	13.4	13.4	13.5	13.3	14.0	8.9	9.8
		MCWBR	6.6	8.1	8.1	6.9	6.4	5.8	5.2	6.3	5.8	7.3	5.8	7.0
Clear-Sky Solar Irradiance	taub	0.335	0.365	0.401	0.458	0.435	0.439	0.452	0.470	0.430	0.391	0.365	0.338	
	taud	2.311	2.234	2.198	2.052	2.189	2.214	2.186	2.129	2.206	2.306	2.326	2.331	
	Ebn at Noon	765	804	825	805	838	835	818	786	786	767	721	719	
	Edh at Noon	83	106	126	158	142	139	142	145	124	99	82	74	
All-Sky Solar Radiation	RadAvg	1.43	2.28	3.50	4.76	5.86	6.48	6.51	5.73	4.15	2.69	1.50	1.16	
	RadStd	0.21	0.36	0.40	0.46	0.44	0.45	0.42	0.39	0.34	0.35	0.20	0.17	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (68 neighbors)		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	-150	+72	N/A	

Nomenclature: See separate page