

FETESTI, Romania

WMO: 154440

Lat: 44.3914N

Lon: 27.8389E

Elev: 194

StdP: 14.59

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	15.7	6.5	7.7	12.5	12.2	10.3	19.2	27.7	30.1	26.3	25.9	11.8	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	92.1	70.5	89.9	69.7	87.2	69.2	74.8	85.9	73.0	84.0	71.5	82.7	6.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.8	118.5	78.0	69.8	110.4	76.9	68.3	104.7	75.4	38.4	86.8	36.7	84.0	35.4	82.8	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	18.4	15.4	3.8	96.7	6.3	3.8	-0.7	99.4	-4.4	101.7	-7.9	103.8	-12.4	106.5
			2.7	78.2	6.2	3.3	-1.8	80.6	-5.4	82.6	-8.9	84.4	-13.4	86.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.3	31.2	37.6	44.3	54.3	63.4	72.0	74.5	74.0	66.7	54.4	43.8	34.5
	DBStd	16.86	8.96	9.16	7.77	7.26	6.06	5.19	4.34	5.18	7.09	7.87	9.33	7.97
	HDD50	1948	584	355	209	40	1	0	0	0	0	45	232	482
	HDD65	4889	1049	768	643	327	102	8	1	4	69	337	636	945
	CDD50	3516	0	7	31	169	415	659	759	744	501	183	46	2
	CDD65	981	0	0	0	5	51	218	295	283	120	9	0	0
	CDH74	9266	0	1	5	84	557	1880	2791	2834	1022	90	2	0
	CDH80	3467	0	0	1	17	121	651	1103	1233	325	16	0	0
Wind	WSAvg	7.0	8.4	8.2	8.2	7.8	6.5	5.8	5.7	5.6	6.0	6.5	6.7	8.2
Precipitation	PrecAvg	19.4	1.3	0.8	1.4	1.5	2.0	2.3	1.9	1.7	2.0	1.4	1.4	1.5
	PrecMax	25.9	3.6	2.2	3.3	3.6	5.9	5.0	4.9	5.1	5.0	2.6	3.0	4.0
	PrecMin	10.9	0.2	0.1	0.0	0.1	0.4	0.9	0.4	0.2	0.2	0.1	0.0	0.2
	PrecStd	4.5	0.9	0.6	0.8	0.8	1.3	0.9	1.1	1.3	1.5	0.7	0.8	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	66.7	72.2	82.2	87.8	93.7	95.2	95.8	91.0	81.9	72.4	58.1
		MCWB	48.1	56.0	54.2	66.0	67.3	72.9	72.2	72.2	69.3	64.9	60.1	53.3
	2%	DB	49.0	59.7	66.6	75.5	83.1	89.6	91.6	92.3	86.8	75.7	66.0	52.2
		MCWB	45.5	51.5	53.4	60.9	66.3	70.7	70.6	70.1	66.8	61.6	58.4	49.6
	5%	DB	45.4	54.6	61.8	71.3	79.8	86.6	88.9	90.1	83.6	71.2	60.8	48.5
		MCWB	43.4	48.7	50.8	58.4	64.6	69.9	70.0	69.6	66.0	60.0	56.1	46.8
	10%	DB	42.5	49.6	57.1	67.5	76.6	83.6	86.0	87.1	80.2	66.8	56.7	44.9
		MCWB	41.1	45.5	48.6	56.1	63.6	68.6	69.9	69.1	65.7	58.1	53.5	43.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	57.2	57.8	66.5	72.7	76.9	82.7	76.5	73.4	67.3	62.3	54.3
		MCDB	52.3	65.2	69.0	80.8	78.3	89.7	83.4	88.3	80.7	76.6	69.0	58.1
	2%	WB	46.0	52.7	54.5	62.7	68.6	73.8	74.7	74.0	70.9	63.6	59.1	49.9
		MCDB	48.0	58.6	63.7	73.6	79.3	84.4	85.1	87.1	78.9	71.9	63.7	51.6
	5%	WB	43.6	49.3	51.9	59.8	66.5	71.9	72.7	72.2	69.1	61.5	56.9	47.1
		MCDB	45.3	54.0	60.4	69.4	77.3	83.1	83.4	84.5	77.1	69.4	61.0	48.7
	10%	WB	41.1	46.1	49.4	57.2	64.7	70.3	71.2	70.8	67.3	59.4	53.9	43.7
		MCDB	42.5	49.5	55.8	66.3	74.5	80.5	82.5	82.7	76.0	65.6	56.5	45.0
Mean Daily Temperature Range	5% DB	MDBR	11.2	14.2	17.6	19.9	20.7	20.3	20.7	21.8	21.1	18.0	12.8	11.8
		MCDBR	15.2	22.9	26.5	26.2	25.8	23.6	25.2	26.4	25.6	24.4	20.1	16.9
		MCWBR	11.6	14.9	14.9	13.2	10.3	8.7	8.0	8.6	9.3	11.5	11.8	13.2
	5% WB	MCDBR	14.3	21.7	24.4	24.2	23.3	22.2	22.7	23.1	21.4	22.0	18.2	16.2
		MCWBR	11.4	15.0	14.9	13.4	11.6	9.1	8.9	9.2	8.9	11.5	11.2	13.2
Clear-Sky Solar Irradiance	taub	0.344	0.373	0.406	0.453	0.428	0.432	0.445	0.456	0.427	0.390	0.365	0.345	
	taud	2.301	2.231	2.184	2.065	2.218	2.242	2.216	2.174	2.226	2.313	2.328	2.324	
	Ebn at Noon	239	252	260	257	268	267	261	253	251	244	229	226	
	Edh at Noon	27	34	41	49	44	43	44	44	39	31	26	24	
All-Sky Solar Radiation	RadAvg	423	679	1060	1507	1905	2066	2080	1859	1350	854	477	362	
	RadStd	62	97	108	153	123	130	117	102	98	88	58	48	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	-220	+160	+103

Nomenclature: See separate page