

FETESTI, Romania

WMO: 154440

Lat: 44.3914N

Lon: 27.8389E

Elev: 59

StdP: 100.62

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.6	-9.1	-14.1	1.1	-10.8	-11.0	1.5	-7.1	12.4	-1.0	11.7	-3.4	5.3	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	33.4	21.4	32.2	21.0	30.7	20.7	23.8	29.9	22.8	28.9	22.0	28.2	2.8	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	16.9	25.6	21.0	15.8	25.0	20.2	15.0	24.1	71.5	30.4	67.5	28.9	64.5	28.2	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.2	6.9	-15.7	36.0	3.5	2.1	-18.2	37.5	-20.2	38.7	-22.2	39.9	-24.7	41.4		
(5)			-16.3	25.7	3.5	1.8	-18.8	27.0	-20.8	28.1	-22.7	29.1	-25.2	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	-0.5	3.1	6.8	12.4	17.4	22.2	23.6	23.3	19.3	12.5	6.6	1.4		
	DBStd	9.37	4.98	5.09	4.32	4.03	3.36	2.88	2.41	2.88	3.94	4.37	5.18	4.43		
	HDD10.0	1082	324	197	116	22	1	0	0	0	0	25	129	268		
	HDD18.3	2716	583	427	357	182	57	4	1	2	38	187	353	525		
	CDD10.0	1953	0	4	17	94	231	366	422	413	278	102	26	1		
	CDD18.3	545	0	0	0	3	28	121	164	157	67	5	0	0		
	CDH23.3	5148	0	1	3	47	309	1044	1551	1574	568	50	1	0		
(13)	CDH26.7	1926	0	0	1	9	67	362	613	685	181	9	0	0		
(14)	Wind	WSAvg	3.1	3.8	3.7	3.7	3.5	2.9	2.6	2.5	2.7	2.9	3.0	3.7		
(15) Precipitation	PrecAvg	494	32	20	35	37	51	58	48	44	52	35	36	37		
	PrecMax	657	91	57	83	91	149	126	125	129	127	65	75	102		
	PrecMin	276	4	2	1	3	11	23	9	6	4	2	1	4		
	PrecStd	115	23	14	20	20	34	24	29	34	38	19	21	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	19.3	22.4	27.9	31.0	34.3	35.1	35.5	32.8	27.7	22.4	14.5		
		MCWB	8.9	13.3	12.4	18.9	19.6	22.7	22.3	22.3	20.7	18.3	15.6	11.9		
	2%	DB	9.5	15.4	19.2	24.2	28.4	32.0	33.1	33.5	30.5	24.3	18.9	11.2		
		MCWB	7.5	10.8	11.9	16.0	19.0	21.5	21.4	21.2	19.3	16.4	14.7	9.8		
	5%	DB	7.4	12.5	16.6	21.9	26.6	30.3	31.6	32.3	28.7	21.8	16.0	9.2		
		MCWB	6.3	9.3	10.4	14.7	18.1	21.1	21.1	20.9	18.9	15.6	13.4	8.2		
	10%	DB	5.8	9.8	13.9	19.7	24.8	28.7	30.0	30.6	26.8	19.3	13.7	7.2		
		MCWB	5.0	7.5	9.2	13.4	17.6	20.4	21.1	20.6	18.7	14.5	12.0	6.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	14.0	14.3	19.2	22.6	25.0	28.2	24.7	23.0	19.6	16.8	12.4		
		MCDB	11.3	18.4	20.6	27.1	25.7	32.1	28.5	31.3	27.1	24.8	20.5	14.5		
	2%	WB	7.8	11.5	12.5	17.1	20.3	23.2	23.7	23.3	21.6	17.6	15.0	9.9		
		MCDB	8.9	14.8	17.6	23.1	26.3	29.1	29.5	30.6	26.1	22.1	17.6	10.9		
	5%	WB	6.5	9.6	11.1	15.4	19.2	22.2	22.6	22.4	20.6	16.4	13.8	8.4		
		MCDB	7.4	12.2	15.8	20.8	25.2	28.4	28.5	29.2	25.1	20.8	16.1	9.3		
	10%	WB	5.1	7.8	9.7	14.0	18.2	21.3	21.8	21.6	19.6	15.2	12.1	6.5		
		MCDB	5.9	9.7	13.2	19.1	23.6	26.9	28.0	28.2	24.4	18.7	13.6	7.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.9	9.8	11.1	11.5	11.3	11.5	12.1	11.7	10.0	7.1	6.6		
		MCDBR	8.5	12.7	14.7	14.6	14.3	13.1	14.0	14.7	14.2	13.5	11.2	9.4		
		MCWBR	6.5	8.3	8.3	7.4	5.7	4.8	4.5	4.8	5.2	6.4	6.6	7.4		
	5% WB	MCDBR	8.0	12.1	13.6	13.5	12.9	12.3	12.6	12.8	11.9	12.2	10.1	9.0		
		MCWBR	6.4	8.3	8.3	7.5	6.4	5.0	4.9	5.1	5.0	6.4	6.2	7.3		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.373	0.406	0.453	0.428	0.432	0.445	0.456	0.427	0.390	0.365	0.345		
	taud		2.301	2.231	2.184	2.065	2.218	2.242	2.216	2.174	2.226	2.313	2.328	2.324		
	Ebn at Noon		754	796	820	810	845	842	824	798	790	770	722	711		
	Edh at Noon		84	107	128	156	138	136	138	139	122	98	82	75		
(44) All-Sky Solar Radiation	RadAvg		1.33	2.14	3.34	4.75	6.00	6.51	6.56	5.86	4.26	2.69	1.50	1.14		
	RadStd		0.20	0.31	0.34	0.48	0.39	0.41	0.37	0.32	0.31	0.28	0.18	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	N/A	-122	+89	+57

Nomenclature: See separate page