

BECHET, Romania

WMO: 154940

Lat: 43.7897N

Lon: 23.9442E

Elev: 122

StdP: 14.63

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	15.9	7.3	8.0	10.8	12.9	10.6	17.3	20.2	37.1	18.3	34.3	2.4	50	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.4	94.9	71.2	92.1	70.5	89.2	70.0	75.1	87.8	73.5	86.4	72.1	84.9	3.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.4	116.3	79.9	69.6	109.4	78.7	68.1	103.8	77.2	38.6	88.0	37.1	87.1	35.9	85.0	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	14.3	11.8		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	30.2	38.9	46.0	54.3	64.4	71.6	74.6	74.2	65.7	53.6	42.6	35.4
	DBStd	16.56	9.04	8.07	7.75	6.88	5.50	4.93	4.22	5.10	6.31	7.33	7.91	7.23
	HDD50	1885	613	318	169	37	0	0	0	0	0	49	245	454
	HDD65	4830	1078	732	590	325	77	6	0	5	68	359	673	917
	CDD50	3476	0	6	44	166	446	649	762	749	472	159	22	1
	CDD65	949	0	0	0	4	58	205	298	290	90	4	0	0
	CDH74	10468	0	0	15	119	677	2059	3196	3258	1056	87	1	0
	CDH80	4489	0	0	1	23	152	809	1460	1637	394	13	0	0
(14) Wind	WSAvg	3.6	3.5	4.0	4.2	4.7	3.7	3.3	3.5	3.0	3.3	3.3	2.9	4.0
(15) Precipitation	PrecAvg	21.2	1.4	1.1	1.5	1.9	2.6	2.4	2.2	1.1	2.0	2.0	1.3	1.7
	PrecMax	36.3	3.4	2.8	3.8	4.7	4.6	4.7	5.3	3.0	5.7	4.3	3.4	4.3
	PrecMin	12.2	0.2	0.0	0.3	0.6	0.5	0.4	0.4	0.2	0.1	0.2	0.0	0.0
	PrecStd	5.2	0.9	0.7	1.0	0.9	1.3	1.1	1.4	0.7	1.5	1.2	0.9	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	67.7	76.2	82.7	89.1	96.6	97.6	99.0	93.4	82.0	69.6	58.5
		MCWB	46.4	54.7	58.8	63.0	69.4	77.3	73.5	71.5	68.4	65.8	59.2	48.7
	2%	DB	49.2	60.6	69.9	77.1	84.4	91.7	94.2	95.2	88.0	76.2	62.5	53.2
		MCWB	43.4	51.5	55.6	62.0	67.4	72.0	71.8	70.2	65.9	62.5	54.8	47.1
	5%	DB	44.8	55.1	64.5	71.9	81.4	88.1	91.4	92.2	84.1	71.9	56.6	49.1
		MCWB	40.7	48.6	52.7	57.7	65.2	71.4	71.3	69.4	65.3	60.0	52.1	44.1
	10%	DB	41.2	50.6	59.6	67.9	78.0	84.6	88.1	89.2	80.0	67.3	52.6	45.0
		MCWB	38.6	45.7	50.2	56.2	63.6	69.9	70.5	69.4	65.0	58.4	49.5	41.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.2	56.1	60.3	65.3	75.0	80.0	77.2	75.4	71.2	69.6	59.1	50.4
		MCDB	53.3	66.3	73.4	79.9	85.8	90.1	92.2	90.8	85.8	79.6	68.2	56.0
	2%	WB	43.6	52.3	56.3	62.6	69.1	75.3	74.7	73.7	69.1	64.1	56.0	47.6
		MCDB	47.8	59.4	67.8	74.7	79.8	86.2	88.1	88.9	82.3	72.2	61.7	53.2
	5%	WB	40.9	48.9	53.6	60.0	66.6	73.4	73.1	72.3	67.2	61.5	53.2	44.9
		MCDB	43.8	54.3	62.9	70.5	77.5	84.3	86.4	86.8	79.2	70.5	56.9	48.8
	10%	WB	38.4	46.4	51.0	57.4	64.6	71.6	71.8	70.9	65.7	59.1	50.5	42.4
		MCDB	40.6	49.9	58.2	66.4	74.8	82.6	84.9	84.3	77.5	66.9	52.7	45.5
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	16.5	19.4	21.1	21.8	22.8	24.4	27.3	24.7	21.4	12.7	13.2
		MCDBR	20.1	25.3	30.5	30.1	28.0	28.1	30.5	33.0	32.7	31.3	21.8	20.6
		MCWBR	15.0	16.9	16.7	15.1	12.0	11.3	11.4	11.4	12.5	17.4	13.6	15.0
	5% WB	MCDBR	18.5	23.6	27.1	28.2	26.6	26.5	27.2	28.7	27.2	28.0	18.2	20.2
		MCWBR	13.6	16.1	15.4	14.7	12.1	12.2	11.0	11.2	11.3	16.3	11.6	14.7
(40) Clear-Sky Solar Irradiance	taub		0.346	0.374	0.414	0.472	0.451	0.451	0.463	0.478	0.444	0.403	0.371	0.347
	taud		2.293	2.216	2.165	2.018	2.153	2.191	2.163	2.116	2.174	2.281	2.323	2.316
	Ebn at Noon		240	253	258	252	262	262	257	248	246	241	229	227
	Edh at Noon		27	35	42	52	47	45	46	47	41	32	27	24
(44) All-Sky Solar Radiation	RadAvg		459	724	1089	1490	1827	2032	2056	1827	1323	857	489	377
	RadStd		70	101	119	158	151	141	128	135	106	112	68	53

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (51 neighbors)	+0.90	N/A	N/A	N/A	+0.67	N/A	N/A	-256	+128	N/A	

Nomenclature: See separate page