

BECHET, Romania

WMO: 154940

Lat: 43.7897N

Lon: 23.9442E

Elev: 37

StdP: 100.88

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-8.9	-13.7	1.1	-11.8	-10.6	1.5	-8.2	9.0	2.9	8.2	1.3	1.1	50	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	34.9	21.8	33.4	21.4	31.8	21.1	23.9	31.0	23.0	30.2	22.3	29.4	1.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.9	16.6	26.6	20.9	15.6	26.0	20.1	14.8	25.1	72.0	31.1	68.4	30.6	65.5	29.5	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.4	5.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	-1.0	3.8	7.8	12.4	18.0	22.0	23.7	23.4	18.7	12.0	5.9	1.9
	DBStd	9.20	5.02	4.49	4.31	3.82	3.06	2.74	2.34	2.84	3.50	4.07	4.39	4.02
	HDD10.0	1047	341	177	94	21	0	0	0	0	0	27	136	252
	HDD18.3	2683	599	407	328	181	43	3	0	3	38	199	374	509
	CDD10.0	1931	0	3	24	92	248	361	423	416	262	88	12	1
	CDD18.3	527	0	0	0	2	32	114	166	161	50	2	0	0
	CDH23.3	5816	0	0	8	66	376	1144	1776	1810	587	48	1	0
	CDH26.7	2494	0	0	1	13	84	449	811	909	219	7	0	0
Wind	WSAvg	1.6	1.6	1.8	1.9	2.1	1.7	1.5	1.6	1.4	1.5	1.5	1.3	1.8
Precipitation	PrecAvg	539	36	28	39	48	65	61	56	27	51	50	33	42
	PrecMax	921	87	70	96	120	117	119	134	75	146	110	87	109
	PrecMin	311	5	1	7	14	12	9	10	5	3	4	0	1
	PrecStd	131	22	18	26	24	32	28	35	19	38	31	22	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	19.9	24.5	28.2	31.7	35.9	36.4	37.2	34.1	27.8	20.9	14.7
		MCWB	8.0	12.6	14.9	17.2	20.8	25.2	23.1	21.9	20.2	18.8	15.1	9.3
	2%	DB	9.6	15.9	21.1	25.0	29.1	33.2	34.5	35.1	31.1	24.6	16.9	11.8
		MCWB	6.4	10.9	13.1	16.7	19.7	22.2	22.1	21.2	18.8	17.0	12.7	8.4
	5%	DB	7.1	12.8	18.0	22.2	27.4	31.2	33.0	33.5	29.0	22.1	13.7	9.5
		MCWB	4.8	9.2	11.5	14.3	18.4	21.9	21.8	20.8	18.5	15.6	11.1	6.7
	10%	DB	5.1	10.3	15.3	19.9	25.5	29.2	31.2	31.8	26.6	19.6	11.4	7.2
		MCWB	3.6	7.6	10.1	13.4	17.6	21.0	21.4	20.8	18.3	14.7	9.7	5.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	13.4	15.7	18.5	23.9	26.7	25.1	24.1	21.8	20.9	15.0	10.2
		MCDB	11.9	19.0	23.0	26.6	29.9	32.3	33.5	32.7	29.9	26.5	20.1	13.3
	2%	WB	6.4	11.3	13.5	17.0	20.6	24.1	23.7	23.1	20.6	17.8	13.3	8.7
		MCDB	8.8	15.2	19.9	23.7	26.6	30.1	31.2	31.6	28.0	22.3	16.5	11.8
	5%	WB	5.0	9.4	12.0	15.5	19.2	23.0	22.8	22.4	19.6	16.4	11.8	7.2
		MCDB	6.6	12.4	17.2	21.4	25.3	29.0	30.2	30.4	26.2	21.4	13.8	9.3
	10%	WB	3.6	8.0	10.6	14.1	18.1	22.0	22.1	21.6	18.7	15.1	10.3	5.8
		MCDB	4.8	10.0	14.6	19.1	23.8	28.1	29.4	29.1	25.3	19.4	11.5	7.5
Mean Daily Temperature Range	5% DB	MDBR	7.7	9.2	10.8	11.7	12.1	12.7	13.6	15.2	13.7	11.9	7.1	7.4
		MCDBR	11.1	14.1	16.9	16.7	15.6	15.6	17.0	18.4	18.2	17.4	12.1	11.4
		MCWBR	8.3	9.4	9.3	8.4	6.7	6.3	6.3	6.3	7.0	9.7	7.6	8.3
	5% WB	MCDBR	10.3	13.1	15.0	15.7	14.8	14.7	15.1	16.0	15.1	15.5	10.1	11.2
		MCWBR	7.6	8.9	8.6	8.2	6.7	6.8	6.1	6.2	6.3	9.0	6.5	8.2
Clear-Sky Solar Irradiance	taub	0.346	0.374	0.414	0.472	0.451	0.451	0.463	0.478	0.444	0.403	0.371	0.347	
	taud	2.293	2.216	2.165	2.018	2.153	2.191	2.163	2.116	2.174	2.281	2.323	2.316	
	Ebn at Noon	757	798	814	794	826	826	810	781	774	759	722	716	
	Edh at Noon	86	110	131	164	148	143	146	148	129	102	84	77	
All-Sky Solar Radiation	RadAvg	1.45	2.28	3.43	4.70	5.76	6.41	6.48	5.76	4.17	2.70	1.54	1.19	
	RadStd	0.22	0.32	0.37	0.50	0.48	0.45	0.40	0.42	0.33	0.35	0.21	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.50	N/A	N/A	N/A	+0.37	N/A	N/A	-142	+71	N/A

Nomenclature: See separate page