

PAGANELLA, Italy

WMO: 160220

Lat: 46.142N

Lon: 11.037E

Elev: 2129

StdP: 78.23

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.1	-13.1	-26.0	0.5	-6.4	-23.3	0.6	-7.3	16.5	-9.2	14.7	-9.1	8.2	0	0.777

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	18.7	13.4	17.3	12.7	16.1	12.2	14.5	17.2	13.6	16.1	12.8	15.3	3.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.3	12.4	15.8	12.5	11.7	14.9	11.7	11.1	14.1	48.3	17.2	45.5	16.2	43.0	15.3	18.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.4	10.6	DB	-16.5	21.1	2.4	1.9	-18.2	22.4	-19.7	23.6	-21.0	24.7	-22.8	26.1	(4)
(5)			WB	-17.4	16.5	2.2	0.9	-19.0	17.2	-20.3	17.7	-21.5	18.2	-23.1	18.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-4.5	-4.8	-2.4	0.4	5.0	9.6	11.5	11.2	7.1	3.8	-0.9	-3.7
	DBStd	7.02	4.18	4.45	4.16	3.57	3.73	3.86	3.02	3.16	3.39	3.77	4.24	4.22
	HDD10.0	2831	448	413	384	288	159	53	21	24	97	193	327	424
	HDD18.3	5686	707	647	642	538	412	262	212	221	336	450	577	683
	CDD10.0	188	0	0	0	0	6	42	67	62	11	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.1	4.8	4.6	4.4	4.1	4.1	3.7	3.6	3.7	3.4	3.7	4.5	5.0
Precipitation	PrecAvg	906	26	30	38	67	95	103	91	89	91	97	101	35
	PrecMax	1310	138	185	164	126	225	334	167	205	221	275	317	132
	PrecMin	527	1	8	7	27	32	16	22	22	0	0	25	4
	PrecStd	171	26	36	33	26	47	59	43	43	62	68	68	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	7.2	7.8	10.1	16.6	20.0	20.0	20.1	16.1	13.1	9.4	7.0
		MCWB	0.3	0.3	2.0	4.9	10.9	14.3	13.6	13.9	11.1	7.3	3.2	-0.2
	2%	DB	4.8	5.2	6.0	8.1	14.0	18.1	18.3	18.2	14.2	11.2	7.3	4.5
		MCWB	-0.7	-0.7	0.9	4.3	9.5	13.1	13.4	13.1	10.3	5.8	2.2	-1.5
	5%	DB	2.8	3.1	4.8	6.7	12.1	16.8	17.1	17.0	12.9	9.9	5.9	3.0
		MCWB	-2.1	-1.7	0.3	3.4	8.4	12.4	12.9	12.6	9.4	5.1	1.2	-2.2
	10%	DB	1.0	1.2	3.2	5.1	10.2	15.1	15.9	15.8	11.5	8.4	4.2	1.7
		MCWB	-2.7	-2.8	-0.4	2.6	7.0	11.4	12.2	12.2	8.7	4.8	0.8	-2.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	1.5	3.0	6.2	11.6	15.4	15.6	15.4	12.6	9.2	5.7	1.2
		MCDB	5.7	5.7	5.9	8.4	15.0	18.5	18.3	18.4	14.5	10.9	7.7	2.7
	2%	WB	0.0	0.0	1.9	5.1	10.0	14.0	14.4	14.2	11.3	8.0	3.7	0.2
		MCDB	2.2	3.1	4.5	7.3	13.1	16.7	17.0	16.9	13.2	9.2	5.5	1.5
	5%	WB	-0.9	-1.0	1.0	4.0	8.8	12.9	13.6	13.4	10.2	7.0	2.8	-0.4
		MCDB	0.9	1.8	3.3	5.7	11.5	15.6	16.0	15.9	11.8	8.0	4.0	1.0
	10%	WB	-1.8	-2.0	0.1	2.9	7.6	11.9	12.8	12.5	9.3	6.1	2.0	-1.2
		MCDB	0.2	0.5	2.3	4.7	9.9	14.6	15.2	14.9	10.8	7.3	3.0	0.4
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.0	4.5	4.6	5.7	6.4	6.4	5.8	5.0	4.2	3.5	3.7
		MCDBR	5.4	5.0	5.2	5.5	7.3	7.5	7.2	6.6	5.7	5.2	4.6	4.8
		MCWBR	3.6	3.4	3.7	3.8	5.1	5.4	5.3	5.0	4.7	4.2	3.3	3.2
	5% WB	MCDBR	4.2	4.4	4.7	5.1	7.0	7.1	6.9	6.2	5.3	4.3	3.5	3.8
		MCWBR	3.3	3.4	3.6	3.8	5.0	5.5	5.4	5.0	4.6	3.9	3.2	3.4
Clear-Sky Solar Irradiance	taub	0.229	0.250	0.287	0.326	0.334	0.347	0.340	0.333	0.316	0.297	0.260	0.230	
	taud	2.462	2.439	2.422	2.382	2.398	2.387	2.401	2.438	2.478	2.523	2.564	2.515	
	Ebn at Noon	911	948	948	932	932	917	918	914	905	876	864	875	
	Edh at Noon	64	82	97	112	114	116	113	105	92	76	59	55	
All-Sky Solar Radiation	RadAvg	1.57	2.47	3.74	4.53	5.15	5.89	5.99	5.17	3.95	2.55	1.55	1.31	
	RadStd	0.19	0.30	0.47	0.58	0.52	0.39	0.39	0.41	0.34	0.34	0.24	0.16	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (75 neighbors)		+0.36	N/A	N/A	+0.67	+0.37	N/A	N/A	-108	+66

Nomenclature: See separate page