

DOBBIAICO, Italy

WMO: 160330

Lat: 46.733N

Lon: 12.217E

Elev: 4022

StdP: 12.68

Time Zone: 1.00 (EUC)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.9	(c) 8.6	(d) -7.5	(e) 4.3	(f) 25.5	(g) -2.6	(h) 5.6	(i) 22.6	(j) 20.0	(k) 22.1	(l) 17.6	(m) 21.4	(n) 0.6	(o) 210	(p) 0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.8	(c) 79.0	(d) 57.3	(e) 76.6	(f) 56.8	(g) 73.5	(h) 55.9	(i) 63.1	(j) 70.8	(k) 61.3	(l) 68.9	(m) 59.8	(n) 67.4	(o) 1.7	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 60.6	(b) 91.9	(c) 65.7	(d) 58.9	(e) 86.1	(f) 64.3	(g) 57.1	(h) 80.9	(i) 62.5	(j) 30.7	(k) 70.3	(l) 29.4	(m) 68.5	(n) 28.2	(o) 67.4	(p) 69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	10.8	8.6	-0.7	82.9	4.7	2.0	-4.1	84.3	-6.9	85.5	-9.5	86.6	-13.0	88.1
			-1.3	65.5	4.6	2.1	-4.6	67.0	-7.3	68.3	-9.9	69.5	-13.2	71.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	24.6	28.2	36.2	43.0	52.1	58.4	61.5	60.6	52.5	44.7	34.8	26.2
	DBStd	14.47	7.02	7.46	7.33	6.21	5.75	5.99	4.85	5.11	5.90	6.58	7.12	7.24
	HDD50	3523	786	611	429	220	45	8	0	2	40	187	458	737
	HDD65	7841	1251	1031	894	660	402	208	128	153	375	630	907	1202
	CDD50	1204	0	0	0	10	109	259	357	330	116	23	0	0
	CDD65	46	0	0	0	0	1	9	20	16	0	0	0	0
	CDH74	492	0	0	0	0	19	123	184	162	4	0	0	0
	CDH80	36	0	0	0	0	1	8	12	15	0	0	0	0
Wind	WSAvg	1.5	1.4	1.8	2.0	2.2	1.7	1.6	1.5	1.1	1.3	1.5	1.2	1.3
Precipitation	PrecAvg	37.7	1.5	1.3	2.0	2.7	3.8	4.4	4.6	4.1	3.4	4.0	3.1	1.9
	PrecMax	49.1	4.8	7.6	3.9	6.4	7.2	9.0	7.7	6.3	8.3	11.9	8.4	4.4
	PrecMin	29.5	0.0	0.0	0.7	1.2	1.6	2.4	1.4	1.6	0.9	0.4	0.0	0.4
	PrecStd	5.6	1.0	1.3	0.9	1.3	1.3	1.5	1.5	1.2	1.6	2.7	2.5	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	51.6	59.2	67.4	76.9	81.0	82.0	82.3	73.6	65.3	52.2	43.0
		MCWB	37.0	37.2	42.3	47.6	54.9	56.2	59.5	59.5	55.8	51.4	44.5	39.4
	2%	DB	39.1	45.0	55.5	62.7	71.6	78.2	78.7	78.6	69.7	61.0	49.6	39.5
		MCWB	35.1	34.7	40.9	46.0	51.8	55.7	58.0	57.7	54.2	50.1	43.8	36.9
	5%	DB	36.2	41.3	51.9	59.1	68.0	74.9	75.6	75.1	66.4	57.5	46.6	37.4
		MCWB	33.3	33.5	39.1	44.2	50.6	55.2	57.2	57.5	53.6	49.0	42.2	35.0
	10%	DB	34.2	38.3	48.3	55.5	64.5	71.2	73.2	71.6	63.1	54.8	44.5	35.4
		MCWB	31.6	32.6	38.1	42.4	49.6	54.2	56.1	56.8	52.6	48.1	41.0	33.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.6	40.3	45.3	51.3	58.9	64.2	65.8	65.6	60.9	56.2	48.1	40.8
		MCDB	41.1	47.1	53.8	63.1	67.0	72.4	74.2	74.4	67.4	61.3	50.5	41.7
	2%	WB	35.8	36.5	43.0	48.3	56.0	61.4	63.1	63.0	58.7	53.0	45.4	37.7
		MCDB	37.8	41.0	50.6	56.9	65.0	68.9	70.8	70.5	64.8	57.7	47.8	38.7
	5%	WB	33.8	35.0	41.3	46.6	54.2	59.5	61.3	61.1	56.6	51.1	43.4	35.1
		MCDB	35.8	39.1	48.3	55.3	62.6	66.8	69.2	68.4	62.0	55.7	45.7	36.5
	10%	WB	31.9	33.5	39.5	44.9	52.7	57.6	59.7	59.6	54.9	49.0	41.3	33.2
		MCDB	34.1	37.4	45.9	52.0	60.2	64.7	67.8	66.8	60.2	53.5	43.7	34.6
Mean Daily Temperature Range	5% DB	MDBR	13.4	17.0	18.2	18.5	19.5	19.5	19.8	18.5	17.8	15.8	12.7	11.1
		MCDBR	13.2	20.1	24.1	25.3	25.6	25.7	24.2	24.1	21.4	19.9	14.6	10.1
		MCWBR	9.7	11.4	11.4	10.7	9.8	9.5	8.9	8.9	9.6	10.3	9.5	7.9
	5% WB	MCDBR	11.1	15.8	19.4	20.9	21.0	22.0	20.8	19.9	17.3	15.7	11.3	8.5
		MCWBR	9.0	9.9	10.6	10.0	9.4	9.4	9.0	9.1	9.3	9.2	8.4	7.4
Clear-Sky Solar Irradiance	taub		0.254	0.282	0.329	0.378	0.392	0.403	0.396	0.390	0.356	0.331	0.293	0.257
	taud		2.365	2.300	2.261	2.231	2.259	2.274	2.293	2.329	2.404	2.446	2.487	2.442
	Ebn at Noon		271	283	283	278	277	274	274	271	272	262	254	258
	Edh at Noon		22	30	36	41	42	41	40	37	31	26	20	19
All-Sky Solar Radiation	RadAvg		470	752	1109	1360	1555	1750	1780	1560	1175	789	463	394
	RadStd		52	96	135	182	185	146	139	155	134	95	82	53

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+2.47	+2.39	N/A	N/A	N/A	N/A
Regional (82 neighbors)	+0.76	N/A	N/A	+1.13	+0.74	+0.72	N/A	-216	+135	+49

Nomenclature: See separate page