

AVIANO, Italy

WMO: 160370

Lat: 46.030N

Lon: 12.599E

Elev: 410

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.8	25.2	8.5	8.6	35.1	13.5	11.1	33.3	17.5	44.1	14.5	41.9	4.9	20	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	91.1	73.5	88.0	72.5	85.8	71.6	76.8	85.9	75.0	83.9	73.3	82.1	6.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.0	128.8	81.3	72.0	120.1	79.2	70.2	113.0	77.5	40.5	86.2	38.8	84.0	37.1	82.2	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.4	13.6	11.5	17.9	94.8	4.0	3.2	14.9	97.1	12.6	99.0	10.3	100.7	7.4	103.0		
			16.5	80.5	3.7	1.5	13.8	81.6	11.6	82.4	9.5	83.3	6.8	84.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.4	39.3	40.9	48.3	55.2	63.7	69.9	74.2	73.7	65.9	57.3	48.1	39.7
	DBStd	13.71	5.26	5.52	5.12	5.85	5.30	5.70	5.19	5.15	5.02	5.85	6.30	5.93
	HDD50	1136	333	256	93	19	0	0	0	0	0	10	106	319
	HDD65	3982	797	673	519	297	88	18	2	4	48	247	506	783
	CDD50	3486	1	2	38	174	426	598	749	734	478	235	50	1
	CDD65	859	0	0	0	3	48	166	286	273	76	7	0	0
	CDH74	7123	0	0	0	26	339	1291	2614	2369	458	26	0	0
	CDH80	2377	0	0	0	2	66	392	965	878	73	1	0	0
Wind	WSAvg	5.1	4.5	5.3	5.7	6.0	5.6	5.3	5.2	5.1	4.8	4.6	4.7	4.4
Precipitation	PrecAvg	47.6	3.0	2.8	3.5	4.3	4.6	3.9	4.7	4.2	5.0	5.8	5.0	2.9
	PrecMax	61.2	13.8	12.1	8.6	10.8	10.9	7.4	8.3	7.3	10.2	16.8	13.7	7.7
	PrecMin	34.7	0.0	0.2	0.2	0.7	0.9	1.3	2.2	1.5	1.5	1.4	0.0	0.0
	PrecStd	7.1	2.9	2.9	2.4	2.4	2.2	1.7	1.4	1.7	2.2	3.7	4.0	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.6	61.2	68.4	77.1	86.2	91.3	95.2	94.9	85.9	77.1	64.2	55.1
		MCWB	48.9	49.2	54.0	60.9	68.7	74.0	75.0	73.1	70.8	63.3	55.8	50.6
	2%	DB	52.0	56.6	65.0	73.3	80.9	87.8	90.6	91.5	82.3	73.1	61.2	52.9
		MCWB	47.5	46.8	52.8	58.9	66.3	71.7	73.6	73.2	68.8	62.9	55.9	48.6
	5%	DB	49.9	53.4	62.2	70.1	77.3	84.5	88.0	88.0	79.1	69.8	59.3	50.4
		MCWB	45.2	45.7	51.4	57.4	64.6	70.5	73.1	72.6	67.3	62.2	55.6	46.8
	10%	DB	48.0	50.2	58.8	66.6	74.7	81.4	85.8	84.6	76.6	66.6	57.4	48.5
		MCWB	44.5	44.6	49.7	55.8	63.5	69.5	72.0	71.2	66.4	61.0	54.3	46.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	51.8	57.4	63.7	73.2	77.4	79.1	79.0	74.3	68.6	60.9	53.6
		MCDB	53.7	57.2	63.5	71.5	80.2	86.0	87.4	88.2	81.1	71.2	61.4	54.2
	2%	WB	49.3	49.6	55.0	60.8	69.3	74.3	77.2	76.4	71.5	66.5	58.9	50.4
		MCDB	50.6	53.6	61.6	69.5	77.5	83.6	86.1	86.0	78.2	69.1	59.6	51.4
	5%	WB	46.8	47.6	53.2	59.1	66.7	72.4	75.5	74.5	69.5	64.6	57.0	48.3
		MCDB	48.4	51.0	59.0	67.1	73.9	80.9	84.3	83.8	75.8	67.8	58.5	49.1
	10%	WB	44.9	45.8	51.7	57.4	64.6	70.7	73.7	72.7	67.7	62.4	55.1	46.6
		MCDB	46.5	49.0	55.9	64.2	71.9	78.6	82.4	81.7	73.4	65.6	57.0	47.8
Mean Daily Temperature Range	5% DB	MDBR	14.3	16.4	17.5	17.2	17.0	17.6	19.0	19.0	17.3	16.0	13.3	14.0
		MCDBR	16.9	20.9	23.9	22.6	21.6	21.0	21.1	22.5	20.4	18.7	14.3	15.1
		MCWBR	12.4	13.4	14.2	12.7	11.4	10.9	10.5	11.5	10.5	10.9	10.4	11.6
	5% WB	MCDBR	12.6	16.0	18.5	19.3	18.9	19.3	19.8	20.4	17.5	14.3	10.0	10.3
		MCWBR	10.6	11.7	12.2	11.9	11.8	11.0	11.2	12.0	10.4	10.2	8.7	9.3
Clear-Sky Solar Irradiance	taub	0.331	0.360	0.411	0.460	0.470	0.488	0.472	0.464	0.439	0.417	0.367	0.327	
	taud	2.384	2.293	2.164	2.066	2.090	2.091	2.145	2.183	2.215	2.231	2.323	2.414	
	Ebn at Noon	241	254	255	253	255	250	253	250	244	229	222	229	
	Edh at Noon	23	31	41	49	49	50	47	43	38	33	25	21	
All-Sky Solar Radiation	RadAvg	444	717	1101	1418	1709	1930	1964	1695	1246	794	458	384	
	RadStd	61	112	141	172	186	125	119	147	121	91	75	52	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (65 neighbors)	+0.76	N/A	N/A	+1.12	+0.67	+0.56	N/A	-216	+158	+79

Nomenclature: See separate page