

AVIANO, Italy

WMO: 160370

Lat: 46.030N

Lon: 12.599E

Elev: 125

StdP: 99.83

Time Zone: 1.00 (EUC)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.1	(c) -3.8	(d) -13.1	(e) 1.2	(f) 1.7	(g) -10.3	(h) 1.6	(i) 0.7	(j) 7.8	(k) 6.7	(l) 6.5	(m) 5.5	(n) 2.2	(o) 20	(p) 0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	32.8	23.0	31.1	22.5	29.9	22.0	24.9	30.0	23.9	28.8	22.9	27.9	2.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	18.4	27.4	22.2	17.2	26.2	21.2	16.1	25.3	76.3	30.1	72.3	28.9	68.5	27.9	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.3	(b) 6.1	(c) 5.1	(e) -7.9	(f) 34.9	(g) 2.2	(h) 1.8	(i) -9.5	(j) 36.2	(k) -10.8	(l) 37.2	(m) -12.1	(n) 38.2	(o) -13.7	(p) 39.5		
(a) 7.3	(b) 6.1	(c) 5.1	(e) -8.6	(f) 27.0	(g) 2.1	(h) 0.8	(i) -10.1	(j) 27.5	(k) -11.3	(l) 28.0	(m) -12.5	(n) 28.5	(o) -14.0	(p) 29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.6	4.0	5.0	9.0	12.9	17.6	21.1	23.4	23.2	18.8	14.0	9.0	4.3
	DBStd	7.62	2.92	3.06	2.84	3.25	2.94	3.17	2.88	2.86	2.79	3.25	3.50	3.29
	HDD10.0	631	185	142	52	11	0	0	0	0	0	6	59	177
	HDD18.3	2212	443	374	288	165	49	10	1	2	27	137	281	435
	CDD10.0	1937	1	1	21	97	237	332	416	408	266	131	28	1
	CDD18.3	477	0	0	0	2	27	92	159	152	42	4	0	0
	CDH23.3	3957	0	0	0	14	188	717	1452	1316	254	14	0	0
	CDH26.7	1321	0	0	0	1	37	218	536	488	41	1	0	0
Wind	WSAvg	2.3	2.0	2.3	2.6	2.7	2.5	2.4	2.3	2.3	2.2	2.0	2.1	2.0
Precipitation	PrecAvg	1210	76	70	89	108	118	100	120	107	127	147	128	73
	PrecMax	1554	351	308	218	274	278	189	210	185	259	426	348	195
	PrecMin	881	1	5	6	18	23	34	55	37	37	35	0	0
	PrecStd	180	73	74	62	61	56	42	36	43	56	94	101	61
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	16.2	20.2	25.0	30.1	33.0	35.1	34.9	30.0	25.1	17.9	12.8
		MCWB	9.4	9.6	12.2	16.0	20.4	23.3	23.9	22.8	21.6	17.4	13.2	10.3
	2%	DB	11.1	13.6	18.3	23.0	27.2	31.0	32.6	33.0	27.9	22.8	16.2	11.6
		MCWB	8.6	8.2	11.5	15.0	19.1	22.0	23.1	22.9	20.5	17.2	13.3	9.2
	5%	DB	9.9	11.9	16.8	21.1	25.2	29.2	31.1	31.1	26.2	21.0	15.1	10.2
		MCWB	7.3	7.6	10.8	14.1	18.1	21.4	22.8	22.5	19.6	16.8	13.1	8.2
	10%	DB	8.9	10.1	14.9	19.2	23.7	27.4	29.9	29.2	24.8	19.2	14.1	9.2
		MCWB	6.9	7.0	9.8	13.2	17.5	20.8	22.2	21.8	19.1	16.1	12.4	7.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	11.0	14.1	17.6	22.9	25.2	26.1	26.1	23.5	20.3	16.1	12.0
		MCDB	12.1	14.0	17.5	22.0	26.8	30.0	30.8	31.2	27.3	21.8	16.3	12.3
	2%	WB	9.6	9.8	12.8	16.0	20.7	23.5	25.1	24.7	22.0	19.2	14.9	10.2
		MCDB	10.4	12.0	16.4	20.8	25.3	28.7	30.1	30.0	25.7	20.6	15.3	10.8
	5%	WB	8.2	8.7	11.8	15.1	19.3	22.4	24.2	23.6	20.8	18.1	13.9	9.1
		MCDB	9.1	10.5	15.0	19.5	23.3	27.1	29.1	28.8	24.4	19.9	14.7	9.5
	10%	WB	7.2	7.7	10.9	14.1	18.1	21.5	23.2	22.6	19.9	16.9	12.8	8.1
		MCDB	8.1	9.5	13.3	17.9	22.1	25.9	28.0	27.6	23.0	18.7	13.9	8.8
Mean Daily Temperature Range	5% DB	MDBR	7.9	9.1	9.7	9.6	9.5	9.8	10.5	10.5	9.6	8.9	7.4	7.8
		MCDBR	9.4	11.6	13.3	12.6	12.0	11.7	11.7	12.5	11.3	10.4	8.0	8.4
		MCWBR	6.9	7.4	7.9	7.0	6.3	6.1	5.8	6.4	5.8	6.0	5.8	6.4
	5% WB	MCDBR	7.0	8.9	10.3	10.7	10.5	10.7	11.0	11.3	9.7	7.9	5.6	5.7
		MCWBR	5.9	6.5	6.8	6.6	6.5	6.1	6.2	6.7	5.8	5.7	4.9	5.1
Clear-Sky Solar Irradiance	taub	0.331	0.360	0.411	0.460	0.470	0.488	0.472	0.464	0.439	0.417	0.367	0.327	
	taud	2.384	2.293	2.164	2.066	2.090	2.091	2.145	2.183	2.215	2.231	2.323	2.414	
	Ebn at Noon	759	801	804	798	804	789	797	787	769	721	699	721	
	Edh at Noon	74	98	128	155	156	157	147	136	121	104	79	65	
All-Sky Solar Radiation	RadAvg	1.40	2.26	3.47	4.47	5.39	6.08	6.19	5.34	3.93	2.50	1.44	1.21	
	RadStd	0.19	0.35	0.44	0.54	0.59	0.40	0.37	0.46	0.38	0.29	0.23	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (65 neighbors)		+0.42	N/A	N/A	+0.62	+0.37	+0.31	N/A	-120	+88	+44

Nomenclature: See separate page