

AOSTA POLLEIN, ItalyWMO: **160540**Lat: **45.735N**Lon: **7.351E**Elev: **1811**StdP: **13.76**Time Zone: **1.00 (EUC)**Period: **86-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.3	15.2	N/A	N/A	N/A	N/A	N/A	N/A	20.5	47.9	17.9	49.2	5.8	250	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	87.9	N/A	85.4	N/A	82.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	12.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	19.2	16.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	34.2	37.6	45.9	51.3	60.0	65.8	69.8	69.7	62.3	53.9	42.6	33.0
	DBStd	14.33	8.04	6.90	6.64	5.41	5.20	5.18	4.51	4.42	5.26	5.15	7.18	8.11
	HDD50	1842	495	350	160	46	3	0	0	0	0	22	235	531
	HDD65	5084	956	768	592	410	167	50	11	12	110	344	671	993
	CDD50	2669	5	2	33	87	312	475	613	612	369	144	14	3
	CDD65	435	0	0	0	0	12	75	159	159	29	1	0	0
	CDH74	4543	0	0	5	25	168	870	1611	1545	309	10	0	0
	CDH80	1234	0	0	0	1	17	231	488	441	55	1	0	0
Wind	WSAvg	4.5	2.5	3.3	5.5	5.9	5.6	5.7	6.0	5.0	3.8	2.7	5.0	2.5
Precipitation	PrecAvg	39.9	3.5	3.1	2.8	3.2	4.1	3.4	3.1	3.0	2.8	3.2	4.3	3.6
	PrecMax	56.2	9.4	9.5	9.0	5.6	8.6	7.1	6.5	5.4	7.3	9.1	13.7	13.7
	PrecMin	27.8	0.3	0.2	0.2	0.5	1.5	1.1	1.2	0.9	0.4	0.4	0.9	0.0
	PrecStd	6.5	2.7	2.5	2.1	1.6	2.1	1.5	1.3	1.3	1.7	1.9	3.1	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.5	63.2	72.8	78.0	82.3	90.4	91.7	91.0	85.3	74.7	66.9	59.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	56.0	56.9	67.1	72.7	78.2	85.2	88.4	87.2	81.0	71.2	60.8	53.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.5	53.0	62.7	68.7	75.2	82.2	85.5	84.9	77.9	68.0	57.3	48.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	45.9	49.2	58.7	64.6	72.3	79.1	82.8	82.3	74.9	64.7	53.8	44.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	18.2	19.8	20.4	19.8	20.8	21.9	23.6	23.5	22.0	19.6	18.3	15.6
		MCDBR	23.6	27.5	28.4	29.0	26.3	28.8	27.8	26.6	27.2	27.0	23.8	17.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.277	0.308	0.364	0.418	0.436	0.444	0.432	0.419	0.397	0.365	0.315	0.275	
	taud	2.301	2.219	2.109	2.064	2.116	2.157	2.198	2.245	2.281	2.333	2.373	2.342	
	Ebn at Noon	262	273	271	265	265	263	264	263	258	249	245	250	
	Edh at Noon	25	33	43	49	48	47	44	41	36	30	23	22	
All-Sky Solar Radiation	RadAvg	502	777	1121	1398	1600	1911	1939	1689	1312	851	504	419	
	RadStd	57	99	144	174	135	153	147	117	103	97	75	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (81 neighbors)		N/A	N/A	N/A	N/A	+0.65	+0.47	N/A	N/A	+101	+32

Nomenclature: See separate page