

AOSTA POLLEIN, ItalyWMO: **160540**Lat: **45.735N**Lon: **7.351E**Elev: **552**StdP: **94.87**Time Zone: **1.00 (EUC)**Period: **86-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-10.9	-9.3	N/A	N/A	N/A	N/A	N/A	N/A	9.2	8.8	8.0	9.6	2.6	250	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	31.1	N/A	29.6	N/A	28.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.6	7.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	1.2	3.1	7.7	10.7	15.5	18.8	21.0	21.0	16.8	12.2	5.9	0.5		
	DBStd	7.96	4.47	3.83	3.69	3.01	2.89	2.88	2.50	2.45	2.92	2.86	3.99	4.51		
	HDD10.0	1023	275	194	89	26	2	0	0	0	0	12	131	295		
	HDD18.3	2824	531	427	329	228	93	28	6	7	61	191	373	552		
	CDD10.0	1483	3	1	18	48	173	264	341	340	205	80	8	2		
	CDD18.3	242	0	0	0	0	7	42	88	88	16	1	0	0		
	CDH23.3	2524	0	0	3	14	93	483	895	858	172	6	0	0		
	CDH26.7	686	0	0	0	1	9	128	271	245	31	1	0	0		
(14) Wind	WSAvg	2.0	1.1	1.5	2.5	2.6	2.5	2.6	2.7	2.3	1.7	1.2	2.2	1.1		
(15) Precipitation	PrecAvg	1014	88	78	70	82	103	86	80	75	71	81	108	92		
	PrecMax	1427	238	241	229	142	218	180	165	138	185	231	349	348		
	PrecMin	705	8	4	6	13	38	28	30	22	10	11	23	0		
	PrecStd	165	69	64	54	40	53	38	33	32	42	49	79	75		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	17.3	22.7	25.5	27.9	32.4	33.2	32.8	29.6	23.7	19.4	15.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	13.3	13.8	19.5	22.6	25.7	29.6	31.3	30.7	27.2	21.8	16.0	12.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	10.3	11.7	17.0	20.4	24.0	27.9	29.7	29.4	25.5	20.0	14.1	9.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	7.7	9.5	14.8	18.1	22.4	26.2	28.2	28.0	23.8	18.2	12.1	7.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	11.0	11.3	11.0	11.6	12.1	13.1	13.1	12.2	10.9	10.2	8.7		
		MCDBR	13.1	15.3	15.8	16.1	14.6	16.0	15.5	14.8	15.1	15.0	13.2	9.8		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.277	0.308	0.364	0.418	0.436	0.444	0.432	0.419	0.397	0.365	0.315	0.275		
	taud		2.301	2.219	2.109	2.064	2.116	2.157	2.198	2.245	2.281	2.333	2.373	2.342		
	Ebn at Noon		827	861	853	836	834	828	832	829	814	786	772	788		
	Edh at Noon		78	104	135	155	152	147	139	128	113	93	74	68		
(44) All-Sky Solar Radiation	RadAvg		1.58	2.45	3.53	4.41	5.04	6.02	6.11	5.33	4.14	2.68	1.59	1.32		
	RadStd		0.18	0.31	0.46	0.55	0.43	0.48	0.46	0.37	0.33	0.30	0.23	0.18		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (81 neighbors)	N/A	N/A	N/A	N/A	+0.36	+0.26	N/A	N/A	+56	+18	(47)

Nomenclature: See separate page