

BRESCIA GHEDI, Italy

WMO: 160880

Lat: 45.432N

Lon: 10.268E

Elev: 333

StdP: 14.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	24.2	7.1	8.0	42.9	13.8	11.2	39.6	18.6	45.1	15.1	44.4	2.4	40	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	92.1	71.8	89.8	70.9	87.7	69.9	76.8	84.2	75.0	82.5	73.4	81.8	4.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.0	132.8	79.0	73.0	124.1	78.2	71.1	116.0	76.9	40.4	84.6	38.7	82.9	37.2	81.5	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	13.4	11.1	DB	17.1	95.5	3.7	2.6	14.4	97.3	12.2	98.9	10.2	100.4	7.5	102.3	(4)
(5)			WB	16.4	79.6	3.6	3.6	13.8	82.1	11.7	84.2	9.7	86.2	7.1	88.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.7	36.3	40.2	48.5	56.0	65.1	72.6	76.3	75.2	67.2	57.7	46.6	37.6	
	DBStd	15.10	4.89	5.23	5.78	5.47	5.51	5.66	4.31	4.92	5.19	5.73	6.14	5.57	
	HDD50	1337	427	277	95	12	0	0	0	0	0	8	133	385	
	HDD65	4123	891	696	513	274	68	8	0	2	36	234	551	850	
	CDD50	3775	0	1	48	190	467	677	815	781	516	247	32	1	
	CDD65	1085	0	0	0	3	70	235	350	318	101	8	0	0	
	CDH74	10153	0	0	3	57	656	2219	3473	2989	724	32	0	0	
	CDH80	3729	0	0	0	4	151	800	1406	1207	159	2	0	0	
Wind	WSAvg	4.2	3.3	3.9	4.8	5.1	5.0	4.6	4.3	4.1	4.1	3.6	4.0	3.2	
Precipitation	PrecAvg	35.3	2.6	2.3	2.6	2.6	3.3	3.2	2.9	3.4	2.7	3.6	3.7	2.2	
	PrecMax	49.8	6.1	5.0	6.3	4.6	5.9	7.1	7.0	7.2	8.2	11.7	6.1	3.7	
	PrecMin	24.3	0.2	0.0	0.0	1.1	0.4	0.4	0.6	0.4	0.2	0.0	1.1	0.8	
	PrecStd	7.1	1.8	1.4	1.8	1.1	1.9	1.9	1.9	2.0	2.4	3.1	1.6	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	61.2	70.8	80.0	88.2	93.5	94.5	96.2	88.1	77.5	63.3	53.9	
		MCWB	46.4	49.3	52.8	59.1	65.4	73.1	74.2	71.5	68.1	63.7	58.5	48.8	
	2%	DB	49.7	56.3	66.6	75.1	84.1	90.9	91.5	92.7	84.3	73.6	59.8	50.3	
		MCWB	43.8	45.9	52.4	57.0	63.6	70.7	73.0	70.9	66.6	62.2	55.1	47.0	
	5%	DB	46.7	53.3	63.5	71.7	80.6	87.9	89.5	89.5	81.2	70.7	57.5	48.1	
		MCWB	42.8	44.8	50.9	56.1	62.3	69.3	71.3	70.9	64.9	61.3	54.3	45.2	
	10%	DB	44.4	49.9	60.1	68.0	77.3	84.6	87.5	86.4	78.5	67.7	55.4	46.1	
		MCWB	41.2	43.6	49.8	54.8	61.0	68.3	70.4	69.6	63.4	59.8	52.7	44.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	51.5	57.3	62.6	70.9	79.4	78.8	78.6	73.8	68.3	61.3	51.3
			MCDB	50.5	57.0	63.7	70.3	76.7	86.4	86.7	83.7	78.7	71.1	62.0	52.5
2%		WB	46.1	49.0	55.3	60.4	68.2	75.7	76.7	76.3	71.0	65.6	57.1	47.9	
		MCDB	47.5	53.7	61.4	68.8	75.2	82.5	84.9	83.7	77.1	70.6	58.6	49.2	
5%		WB	43.7	46.7	53.5	58.6	66.1	73.5	75.0	74.5	69.1	63.7	55.2	45.9	
		MCDB	45.3	50.5	59.9	66.6	74.1	82.6	83.1	81.9	75.4	68.1	57.0	47.0	
10%		WB	41.7	44.9	51.7	57.0	64.1	71.5	73.4	72.8	67.4	61.9	53.3	44.3	
		MCDB	43.2	47.9	57.6	64.4	73.0	79.5	82.0	81.2	73.7	65.5	55.0	45.4	
Mean Daily Temperature Range	5% DB	MDBR	13.3	16.8	19.1	19.0	19.2	19.1	19.9	19.6	18.6	15.4	12.0	12.0	
		MCDBR	17.8	23.6	25.7	25.5	24.0	22.3	21.5	22.8	22.2	19.5	13.9	15.1	
		MCWBR	12.6	14.4	12.7	10.4	8.7	8.5	8.1	8.3	8.1	9.7	10.1	11.1	
	5% WB	MCDBR	13.9	18.9	20.4	21.4	21.0	20.5	19.8	19.7	18.7	15.3	11.0	10.8	
		MCWBR	11.2	13.0	11.5	10.2	9.2	9.5	9.0	9.5	8.8	9.1	8.9	9.2	
Clear-Sky Solar Irradiance	taub		0.350	0.380	0.427	0.463	0.461	0.487	0.468	0.456	0.447	0.434	0.379	0.343	
	taud		2.372	2.254	2.128	2.064	2.121	2.096	2.157	2.202	2.193	2.179	2.298	2.397	
	Ebn at Noon		235	248	251	253	258	251	254	252	242	224	219	225	
	Edh at Noon		24	33	43	49	48	49	46	43	40	35	26	22	
All-Sky Solar Radiation	RadAvg		452	707	1123	1428	1767	2023	2072	1765	1308	787	465	385	
	RadStd		70	105	150	158	161	110	115	115	88	114	71	51	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)		+0.61	N/A	N/A	+1.08	N/A	N/A	N/A	N/A	+117	+16

Nomenclature: See separate page