

TREVISO SANT'ANGELO, Italy

WMO: 160990

Lat: 45.648N

Lon: 12.194E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	26.6	10.5	9.4	36.3	15.8	12.3	36.8	15.8	43.1	13.2	40.4	1.6	20	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	92.6	73.8	89.8	73.2	87.6	72.1	77.8	86.4	76.0	84.7	74.4	83.1	5.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.3	133.1	82.5	73.4	124.5	80.7	71.6	116.9	79.4	41.3	84.9	39.4	84.3	37.8	83.1	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.1	11.5	9.5	DB	20.2	95.5	4.1	3.0	17.2	97.7	14.7	99.4	12.4	101.1	9.4	103.2
			WB	19.0	80.1	4.1	2.3	16.1	81.7	13.7	83.1	11.3	84.4	8.4	86.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	39.0	41.9	49.3	56.8	65.4	72.7	76.7	76.1	67.3	58.6	49.3	40.6
	DBStd	14.33	4.95	5.23	5.51	5.67	5.37	5.59	4.55	5.34	5.19	5.56	6.16	5.52
	HDD50	1044	343	230	77	10	0	0	0	0	0	6	85	293
	HDD65	3733	807	648	485	251	62	8	0	1	35	209	471	756
	CDD50	3924	1	2	56	214	476	682	828	810	518	272	63	2
	CDD65	1139	0	0	0	5	73	240	363	346	103	9	0	0
	CDH74	9929	0	0	0	49	552	2021	3466	3214	607	20	0	0
	CDH80	3627	0	0	0	3	124	688	1367	1325	120	0	0	0
(14) Wind	WSAvg	3.1	2.3	3.0	3.6	3.7	3.6	3.5	3.5	3.4	3.0	2.5	2.5	2.3
(15) Precipitation	PrecAvg	37.7	2.0	2.0	2.4	3.4	3.9	3.6	3.1	3.0	3.7	4.0	4.0	2.6
	PrecMax	65.9	10.2	9.4	10.6	5.8	8.8	7.2	8.2	6.1	7.1	7.6	8.2	6.4
	PrecMin	26.0	0.0	0.0	0.0	0.1	1.1	1.1	1.6	0.7	1.1	0.3	0.9	0.2
	PrecStd	9.6	2.1	2.4	2.3	1.5	2.1	1.5	1.4	1.5	1.9	2.1	1.9	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	61.1	70.2	78.8	87.8	93.5	94.9	95.8	86.5	76.7	67.4	56.0
		MCWB	49.9	49.4	54.6	61.4	68.5	73.2	75.1	75.1	69.4	65.4	59.8	50.9
	2%	DB	51.8	57.0	66.3	75.0	83.7	89.7	91.5	93.3	83.6	73.4	62.8	53.7
		MCWB	46.0	47.3	53.6	59.3	67.1	73.1	74.5	73.5	69.0	63.3	57.9	49.2
	5%	DB	49.6	53.7	62.7	71.6	80.2	86.4	89.5	90.0	80.5	70.1	60.7	51.4
		MCWB	45.2	45.9	52.2	57.9	65.2	71.2	73.5	73.1	67.8	62.1	56.6	47.2
	10%	DB	46.7	50.4	59.3	68.0	76.8	84.1	87.5	87.4	77.2	67.7	58.5	48.6
		MCWB	43.5	45.2	50.3	56.8	63.8	70.1	72.5	72.2	65.9	60.7	54.7	45.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.6	52.1	58.0	63.7	72.4	77.6	80.9	79.5	74.1	69.0	62.1	54.2
		MCDB	54.4	58.3	65.1	72.7	81.4	86.9	89.6	88.2	80.7	72.9	64.8	55.3
	2%	WB	48.5	49.9	55.8	61.3	69.3	75.4	78.4	77.4	71.8	66.4	59.6	50.9
		MCDB	49.6	53.1	62.2	70.1	78.3	85.2	86.4	86.4	78.4	70.1	61.8	52.3
	5%	WB	46.3	48.1	54.0	59.7	67.3	73.6	76.3	75.8	70.0	64.2	57.5	48.2
		MCDB	47.9	51.7	60.0	68.0	76.2	82.3	84.6	84.7	76.8	68.0	59.8	49.5
	10%	WB	44.2	46.3	52.2	58.2	65.5	72.1	74.5	74.1	68.3	62.1	55.4	46.4
		MCDB	45.8	49.2	57.3	65.7	73.8	80.7	83.0	83.2	74.9	65.7	57.7	48.2
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	15.6	17.2	17.3	17.5	17.6	18.3	18.6	17.4	15.3	12.9	13.2
		MCDBR	16.7	20.8	22.7	23.0	22.4	20.2	19.9	21.4	20.2	18.3	14.6	15.7
		MCWBR	11.4	12.5	12.0	10.3	9.1	8.2	7.9	7.6	8.7	9.8	9.5	10.7
	5% WB	MCDBR	11.8	15.9	18.2	19.2	19.1	18.8	18.7	19.6	17.3	14.2	11.2	10.7
		MCWBR	9.5	10.8	10.9	10.2	9.6	8.9	9.0	9.0	9.5	9.0	8.5	8.5
(40) Clear-Sky Solar Irradiance	taub		0.348	0.375	0.422	0.465	0.471	0.492	0.475	0.465	0.448	0.430	0.381	0.343
	taud		2.383	2.290	2.166	2.078	2.115	2.106	2.161	2.203	2.214	2.218	2.305	2.411
	Ebn at Noon		235	250	252	252	255	250	252	250	242	225	217	224
	Edh at Noon		24	32	41	49	49	49	46	43	39	34	26	21
(44) All-Sky Solar Radiation	RadAvg		432	705	1112	1460	1789	2031	2065	1768	1290	798	460	376
	RadStd		69	115	146	163	174	113	110	136	102	94	66	50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)		+0.76	N/A	N/A	N/A	+0.63	N/A	-207	+149	+68

Nomenclature: See separate page