

VENEZIA TESSERA MARCO POLO, Italy

WMO: 161050

Lat: 45.505N

Lon: 12.352E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	28.4	12.0	10.1	31.8	16.0	12.4	34.3	22.8	39.2	19.9	39.0	5.4	350	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	89.0	74.6	86.4	73.4	84.4	72.4	77.8	84.7	76.0	83.4	74.5	81.9	7.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.4	133.1	81.9	73.6	125.0	80.8	71.8	117.6	79.7	41.0	85.0	39.4	83.3	38.0	82.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	17.5	14.4	22.1	92.5	3.9	2.6	19.3	94.4	17.0	96.0	14.8	97.4	12.0	99.4
			19.9	80.4	3.9	1.5	17.1	81.5	14.8	82.4	12.7	83.3	9.9	84.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	39.2	41.4	48.2	55.9	64.4	71.7	75.5	74.8	66.9	58.6	49.3	40.7
	DBStd	13.85	4.89	5.01	5.22	5.07	4.86	5.11	4.21	4.52	4.82	5.41	6.02	5.42
	HDD50	1059	335	243	93	9	0	0	0	0	0	5	83	291
	HDD65	3801	799	661	519	274	71	8	0	1	35	208	472	753
	CDD50	3727	1	1	39	187	445	652	791	769	507	270	62	3
	CDD65	994	0	0	0	2	51	209	327	305	92	8	0	0
	CDH74	7684	0	0	0	5	222	1503	2911	2624	410	9	0	0
	CDH80	2042	0	0	0	0	26	340	853	779	44	0	0	0
Wind	WSAvg	5.9	4.6	5.6	6.2	6.5	6.5	6.5	6.4	6.1	6.2	5.5	5.4	5.1
Precipitation	PrecAvg	35.7	2.0	2.1	2.4	3.5	3.8	3.5	3.0	3.0	3.8	4.0	3.5	2.6
	PrecMax	66.9	10.6	11.4	11.3	6.0	8.6	7.8	8.1	6.6	6.8	8.6	7.2	6.0
	PrecMin	25.3	0.0	0.2	0.1	0.1	1.1	0.7	1.1	0.6	1.0	0.4	0.9	0.3
	PrecStd	9.9	2.2	2.6	2.4	1.5	2.1	1.8	1.4	1.6	1.9	2.2	1.8	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	57.5	66.3	73.8	83.5	89.6	91.7	91.8	84.1	75.0	64.6	56.0
		MCWB	50.8	48.5	54.5	60.2	69.1	74.1	77.0	74.6	70.7	66.4	59.2	52.0
	2%	DB	51.4	53.8	62.4	71.2	79.1	86.1	88.3	89.4	80.9	71.8	62.2	53.2
		MCWB	47.4	47.1	52.7	59.5	67.5	73.1	74.4	74.6	69.7	64.5	58.1	48.9
	5%	DB	48.5	51.6	59.3	68.0	76.6	84.0	86.4	86.4	78.6	69.6	60.1	50.3
		MCWB	45.2	46.1	51.4	58.0	65.6	71.8	73.4	73.8	68.7	63.5	56.5	46.2
	10%	DB	46.6	49.6	57.0	65.5	73.6	81.6	84.5	84.3	76.3	67.4	57.5	48.4
		MCWB	43.5	45.4	50.6	56.9	63.7	70.9	72.5	72.7	67.6	62.1	53.9	45.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	51.3	56.6	64.0	72.8	78.1	79.9	79.5	74.6	69.0	61.5	53.9
		MCDB	54.0	55.3	61.8	70.6	79.4	84.0	86.6	85.7	80.2	71.6	63.9	55.7
	2%	WB	48.8	49.1	54.8	61.2	69.3	75.7	77.9	77.7	72.5	66.9	59.2	49.9
		MCDB	49.8	51.8	59.6	67.2	76.0	83.0	85.1	84.7	77.8	70.0	61.4	51.7
	5%	WB	46.2	47.3	53.3	59.4	67.2	73.8	76.0	76.0	70.7	65.0	57.1	47.2
		MCDB	47.6	50.0	57.6	65.3	74.1	81.0	83.4	83.6	76.1	68.4	59.5	49.3
	10%	WB	44.0	45.7	51.9	57.9	65.3	72.1	74.5	74.4	68.8	63.0	54.8	45.6
		MCDB	45.6	48.2	55.8	63.7	71.8	79.5	82.0	82.1	74.5	66.4	57.5	47.7
Mean Daily Temperature Range	5% DB	MDBR	11.1	12.8	14.0	13.7	13.7	14.2	15.4	15.8	14.8	13.0	11.0	11.0
		MCDBR	13.0	15.8	17.6	17.3	16.8	16.1	16.7	17.5	16.8	14.5	11.6	12.7
		MCWBR	9.6	10.8	10.8	9.6	8.7	8.4	8.5	9.3	9.3	9.2	8.6	9.3
	5% WB	MCDBR	9.4	12.7	14.9	14.8	15.1	15.1	15.7	16.4	15.1	12.1	9.3	9.6
		MCWBR	7.9	9.5	10.0	9.2	9.2	9.0	9.1	9.9	9.8	8.7	7.9	7.9
Clear-Sky Solar Irradiance	taub	0.355	0.382	0.427	0.461	0.466	0.485	0.470	0.460	0.444	0.433	0.387	0.349	
	taud	2.374	2.282	2.162	2.101	2.142	2.137	2.186	2.228	2.235	2.217	2.292	2.402	
	Ebn at Noon	233	248	251	253	257	252	254	251	244	225	215	222	
	Edh at Noon	24	32	41	48	47	48	45	42	38	34	26	22	
All-Sky Solar Radiation	RadAvg	416	692	1104	1485	1840	2086	2117	1808	1305	800	455	366	
	RadStd	71	121	146	160	174	109	106	137	100	89	62	50	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (41 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-212	+160	+90

Nomenclature: See separate page