

TRIESTE, Italy

WMO: 161100

Lat: 45.677N

Lon: 13.755E

Elev: 11

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.2	32.2	3.4	6.5	34.5	8.6	8.5	37.5	33.2	32.4	30.4	34.4	16.2	60	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	89.6	74.4	87.4	74.1	85.5	73.2	78.1	86.2	76.3	84.9	74.5	83.4	4.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	132.9	85.2	73.3	123.7	83.5	71.2	115.2	81.8	41.4	86.3	39.7	85.1	38.0	83.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.4	23.1	19.4	25.6	94.9	4.0	4.0	22.7	97.8	20.3	100.1	18.0	102.4	15.1	105.3		
			21.0	81.2	3.2	2.4	18.7	82.9	16.8	84.4	15.0	85.7	12.7	87.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.9	43.5	44.6	50.6	57.5	65.7	72.8	77.2	77.0	69.1	61.3	53.1	45.8
	DBStd	13.10	5.18	5.56	5.27	5.23	4.99	5.34	4.58	5.02	5.28	5.56	6.04	5.70
	HDD50	617	208	160	56	5	0	0	0	0	0	3	38	147
	HDD65	3085	666	571	447	232	51	6	0	1	20	139	358	594
	CDD50	4247	7	10	74	229	486	683	844	838	574	353	131	18
	CDD65	1239	0	0	0	6	72	239	379	374	144	24	1	0
	CDH74	8993	0	0	0	18	252	1598	3332	3193	579	21	0	0
	CDH80	2490	0	0	0	1	26	359	1016	1006	81	1	0	0
Wind	WSAvg	5.6	6.7	6.8	5.7	4.7	4.2	4.3	4.7	4.8	5.9	6.0	6.2	6.9
Precipitation	PrecAvg	39.7	2.5	2.7	2.7	3.1	3.1	3.5	2.5	3.5	4.2	3.9	4.4	3.3
	PrecMax	60.6	6.8	9.6	7.8	7.1	9.3	6.9	7.0	12.4	11.4	12.6	12.4	9.4
	PrecMin	24.9	0.0	0.0	0.0	0.0	0.3	0.0	0.4	0.2	0.0	0.0	0.1	0.0
	PrecStd	8.5	1.6	2.1	1.8	1.6	1.9	1.6	1.7	2.5	2.5	2.9	2.4	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	59.4	66.5	76.6	83.4	89.8	93.1	93.7	85.5	76.8	68.6	61.0
		MCWB	53.7	50.0	53.0	58.3	67.9	74.5	74.5	72.6	71.7	65.0	61.1	55.1
	2%	DB	55.1	56.0	62.5	71.5	79.4	86.3	89.6	89.8	82.3	73.3	65.8	57.2
		MCWB	50.6	48.5	52.0	58.8	67.1	73.5	74.3	74.4	69.5	64.4	59.2	52.1
	5%	DB	52.2	53.8	59.5	68.1	76.8	84.1	87.4	87.7	80.0	71.0	63.3	54.8
		MCWB	48.1	48.0	50.7	57.3	65.3	72.5	74.4	74.3	68.6	63.4	57.9	50.1
	10%	DB	50.3	51.8	57.5	65.6	74.2	81.9	85.5	85.6	77.3	68.7	61.0	53.0
		MCWB	46.6	46.5	50.4	56.1	63.7	70.9	73.5	73.3	66.9	61.9	56.2	48.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.4	53.4	56.3	63.4	72.8	78.0	81.0	80.4	75.8	68.7	62.8	56.6
		MCDB	57.7	55.6	61.7	70.9	79.5	85.5	88.9	88.0	82.4	73.2	66.7	59.5
	2%	WB	51.7	51.1	54.6	60.6	69.3	75.6	78.1	78.2	72.7	66.6	60.3	53.6
		MCDB	54.2	53.8	59.2	67.7	76.9	84.4	86.4	86.5	79.8	70.8	64.0	55.8
	5%	WB	49.5	49.5	53.2	58.8	66.8	73.5	76.2	76.4	70.4	65.0	58.8	51.4
		MCDB	51.3	52.3	57.5	65.5	74.6	82.3	85.0	85.2	77.2	69.2	62.3	53.5
	10%	WB	47.8	47.7	51.9	57.2	64.7	71.6	74.3	74.5	68.4	63.3	57.3	49.8
		MCDB	49.6	50.7	56.2	63.4	72.5	80.7	83.4	83.7	75.2	67.4	60.6	51.9
Mean Daily Temperature Range	5% DB	MDBR	8.0	8.9	10.8	11.4	12.7	13.1	13.7	13.2	12.1	10.0	8.6	8.2
		MCDBR	9.9	10.7	12.9	15.3	15.0	14.7	15.0	14.8	13.8	11.3	10.0	10.3
		MCWBR	7.6	8.0	8.7	9.2	9.7	10.7	11.0	10.6	9.1	7.7	7.2	8.2
	5% WB	MCDBR	7.2	8.9	10.8	12.8	13.9	13.8	14.1	13.8	12.6	9.8	8.0	8.0
		MCWBR	6.6	7.8	8.4	9.2	10.2	11.1	11.7	11.6	10.0	7.9	6.3	7.6
Clear-Sky Solar Irradiance	taub	0.344	0.369	0.417	0.461	0.465	0.476	0.465	0.456	0.440	0.419	0.376	0.340	
	taud	2.401	2.320	2.196	2.101	2.140	2.159	2.198	2.238	2.247	2.270	2.336	2.430	
	Ebn at Noon	237	252	254	253	257	254	255	252	245	230	220	226	
	Edh at Noon	23	31	40	48	47	47	44	41	37	32	25	21	
All-Sky Solar Radiation	RadAvg	414	683	1077	1440	1775	2014	2042	1758	1258	785	445	361	
	RadStd	66	119	146	166	177	118	114	155	120	88	64	50	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.83	N/A	N/A	+1.24	+0.76	N/A	-137	-214	+166	+110

Nomenclature: See separate page