

GENOVA SESTRI, Italy

WMO: 161200

Lat: 44.412N

Lon: 8.842E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	3.0	-12.5	1.3	6.0	-9.9	1.6	6.3	12.3	7.7	11.4	7.5	6.6	40	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	30.2	22.8	29.1	23.2	28.1	23.0	26.0	27.9	25.2	27.4	24.3	26.9	3.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.4	27.3	24.2	19.2	26.8	23.2	18.0	26.2	80.5	28.0	76.6	27.4	73.1	26.9	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.7	8.7	DB	0.0	33.1	1.8	1.8	-1.3	34.5	-2.4	35.5	-3.4	36.5	-4.7	37.9	(4)
(5)			WB	-3.1	26.6	1.7	1.3	-4.3	27.6	-5.3	28.3	-6.2	29.1	-7.4	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	9.0	9.6	12.1	14.7	18.4	22.1	24.7	25.0	21.7	17.8	13.3	10.1	(6)	
	DBStd	6.18	2.80	2.82	2.42	2.35	2.34	2.43	2.00	2.05	2.26	2.66	2.94	3.05	(7)	
	HDD10.0	146	53	36	11	1	0	0	0	0	0	1	8	37	(8)	
	HDD18.3	1316	289	244	194	111	27	1	0	0	2	40	152	255	(9)	
	CDD10.0	2549	21	25	74	142	261	364	457	464	350	242	107	40	(10)	
	CDD18.3	679	0	0	0	3	29	116	199	206	103	23	0	0	(11)	
	CDH23.3	3944	0	0	0	6	63	503	1453	1557	350	12	0	0	(12)	
	CDH26.7	680	0	0	0	1	6	62	264	311	37	0	0	0	(13)	
(14) Wind	WSAvg	4.1	5.1	4.6	4.0	3.8	3.5	3.2	3.3	3.3	3.8	4.4	5.0	5.1	(14)	
(15) Precipitation	PrecAvg	1110	108	95	106	80	78	54	29	78	109	164	108	80	(15)	
	PrecMax	1654	364	308	257	265	197	214	95	210	438	497	369	220	(16)	
	PrecMin	719	5	14	17	2	7	6	0	0	6	7	0	0	(17)	
	PrecStd	240	89	78	67	60	53	49	28	61	93	130	77	57	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	17.1	20.1	24.0	27.1	30.1	32.0	32.9	30.0	24.8	20.1	17.2	(19)	
		MCWB	10.7	10.6	11.6	14.9	18.8	22.7	21.9	22.4	20.7	19.1	15.5	12.4	(20)	
	2%	DB	14.9	15.0	17.9	21.1	25.0	28.2	30.0	30.5	27.5	23.2	19.1	16.0	(21)	
		MCWB	11.6	10.9	11.0	14.4	18.5	22.5	23.6	22.4	20.4	18.6	15.5	12.6	(22)	
	5%	DB	14.0	14.1	16.2	19.8	23.4	27.1	29.0	29.1	26.2	22.2	18.2	15.1	(23)	
		MCWB	11.3	10.9	11.8	14.1	17.8	22.1	23.6	23.3	20.7	18.4	15.0	11.9	(24)	
	10%	DB	13.2	13.4	15.2	18.2	22.1	26.0	28.1	28.2	25.2	21.3	17.2	14.2	(25)	
		MCWB	10.4	10.5	11.7	13.7	17.5	21.7	23.2	23.4	20.3	17.8	14.3	11.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	13.9	15.3	17.2	21.2	25.6	27.2	27.0	24.5	21.9	17.8	15.3	(27)	
		MCDB	15.0	14.7	16.3	20.0	23.6	27.8	28.8	28.4	25.8	22.9	19.0	16.3	(28)	
	2%	WB	12.9	12.9	14.2	16.2	20.2	24.4	25.9	26.2	23.3	20.6	16.7	13.8	(29)	
		MCDB	14.1	14.2	15.6	19.0	23.0	26.9	28.1	27.9	25.3	22.0	18.3	15.3	(30)	
	5%	WB	12.0	12.1	13.4	15.4	19.3	23.2	25.0	25.5	22.3	19.7	15.7	12.8	(31)	
		MCDB	13.5	13.5	15.1	18.0	22.2	25.9	27.5	27.5	24.9	21.4	17.6	14.6	(32)	
	10%	WB	11.0	11.2	12.7	14.8	18.4	22.3	24.1	24.6	21.5	18.6	14.8	11.8	(33)	
		MCDB	13.0	13.0	14.6	17.2	21.3	25.1	27.0	27.0	24.3	20.9	17.0	13.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.4	5.5	5.4	5.3	5.2	5.3	5.5	5.8	5.2	5.0	5.1	(35)	
		MCDBR	5.9	6.0	6.7	7.2	7.3	6.4	6.2	6.5	6.8	5.6	5.4	5.7	(36)	
	5% WB	MCWBR	5.0	5.2	5.2	4.9	5.0	5.1	5.2	5.1	4.9	4.1	4.3	4.7	(37)	
		MCWBR	4.7	4.6	4.9	5.4	5.4	5.1	5.0	4.7	5.1	4.4	4.6	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.338	0.361	0.403	0.441	0.444	0.460	0.449	0.442	0.428	0.408	0.367	0.334	(40)	
		taud	2.443	2.366	2.260	2.173	2.214	2.214	2.255	2.286	2.292	2.319	2.395	2.470	(41)	
	Edn at Noon	Edn at Noon	775	818	825	822	831	817	821	813	791	751	727	743	(42)	
		Edh at Noon	74	94	119	140	139	140	133	124	114	98	77	66	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.52	2.30	3.62	4.73	5.85	6.72	6.93	5.91	4.42	2.61	1.57	1.29	(44)	
	RadStd	RadStd	0.19	0.34	0.47	0.43	0.47	0.34	0.35	0.33	0.28	0.36	0.21	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	-2.16	N/A	-0.92	-1.20	N/A	N/A	N/A	N/A	
(47)	Regional (33 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+78	+36	(47)

Nomenclature: See separate page