

MONTE CIMONE, Italy

WMO: 161340

Lat: 44.1936N

Lon: 10.7000E

Elev: 2173

StdP: 77.80

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.1	-12.0	-24.0	0.6	-4.6	-20.8	0.8	-4.1	28.5	-7.7	26.5	-6.8	17.5	20	0.945

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	19.2	13.5	18.0	12.9	16.9	12.0	14.7	17.7	13.7	16.8	12.9	15.9	3.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	12.6	16.4	12.4	11.7	15.5	11.4	11.0	14.6	49.2	17.7	46.2	16.9	43.4	16.0	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 25.7	22.5	20.2		DB	-15.5	21.7	2.7	2.0	-17.4	23.2	-19.0	24.3	-20.6	25.5	-22.6	26.9
(5)				WB	-16.0	16.8	2.6	1.6	-17.9	17.9	-19.4	18.8	-20.8	19.7	-22.7	20.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.7	-2.9	-3.6	-1.4	0.9	5.3	9.9	12.4	12.3	7.7	4.9	0.7	-2.3		
	DBStd	6.81	3.96	4.31	3.88	3.25	3.42	3.96	3.27	3.24	3.50	3.84	4.22	4.24		
	HDD10.0	2551	401	382	354	274	151	51	15	14	84	162	281	381		
	HDD18.3	5347	659	615	613	524	404	253	184	188	319	418	531	639		
	CDD10.0	247	0	0	0	0	5	48	90	86	16	2	1	0		
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	8.1	10.0	9.6	9.2	8.5	7.7	6.4	5.8	5.8	7.3	8.1	9.3	9.7		
(15) Precipitation	PrecAvg	778	56	46	55	51	56	62	55	75	80	85	81	55		
	PrecMax	1082	165	133	173	136	136	143	154	158	224	247	214	106		
	PrecMin	436	3	6	1	2	16	20	6	0	7	11	5	2		
	PrecStd	180	40	34	40	29	31	29	39	43	57	69	58	30		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	8.2	8.7	10.3	15.8	19.7	21.0	21.2	17.0	13.7	12.7	8.8		
		MCWB	1.3	1.9	2.9	5.9	9.8	13.4	15.2	13.8	11.7	7.5	4.3	0.6		
	2%	DB	5.1	5.1	6.2	8.2	13.2	17.9	19.2	19.1	15.1	11.9	9.3	6.7		
		MCWB	0.1	0.2	1.7	4.7	8.4	12.8	13.9	13.0	10.9	6.6	3.8	0.1		
	5%	DB	3.5	3.1	4.9	6.9	11.6	16.6	18.1	17.9	13.5	10.7	7.4	4.4		
		MCWB	-1.0	-0.7	1.3	4.0	7.7	11.8	13.3	12.4	9.8	6.0	2.9	-0.6		
	10%	DB	1.9	1.4	3.3	5.2	10.0	15.2	16.8	16.5	12.1	9.5	5.8	2.6		
		MCWB	-1.3	-1.1	0.6	2.5	6.9	10.6	11.9	11.9	8.7	5.8	2.8	-0.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	2.5	4.1	7.1	10.9	15.7	16.8	15.4	13.1	10.1	6.7	2.8		
		MCDB	5.2	5.7	6.5	9.5	13.9	17.9	19.0	18.2	15.3	11.6	8.8	4.2		
	2%	WB	1.2	1.2	2.8	5.5	9.4	14.1	15.0	14.2	11.7	8.9	5.5	1.9		
		MCDB	2.9	3.2	4.7	7.6	12.0	16.6	18.1	17.6	14.1	10.1	7.0	3.0		
	5%	WB	0.4	0.4	2.0	4.1	8.2	12.8	13.9	13.4	10.6	8.0	4.5	1.1		
		MCDB	1.8	1.9	3.9	6.0	10.7	15.7	17.0	16.7	12.6	9.3	6.1	2.3		
	10%	WB	-0.5	-0.5	1.0	3.1	7.2	11.5	13.0	12.5	9.6	7.1	3.5	0.3		
		MCDB	0.9	0.8	2.6	4.7	9.5	14.3	16.1	15.6	11.4	8.3	5.0	1.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	3.8	3.8	3.6	4.1	4.5	4.8	4.5	3.9	3.8	3.4	3.6		
		MCDBR	4.5	4.8	4.8	4.6	5.5	5.5	5.9	5.6	5.1	4.8	4.7	4.5		
	5% WB	MCWBR	3.4	3.8	4.5	4.9	6.0	6.8	6.6	6.0	6.3	5.2	4.6	3.5		
		MCWBR	3.5	3.8	4.1	4.2	5.1	5.1	5.1	5.0	4.6	4.0	3.7	3.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.253	0.268	0.294	0.312	0.314	0.322	0.317	0.311	0.302	0.297	0.275	0.252		
		taud	2.577	2.532	2.476	2.438	2.452	2.447	2.460	2.492	2.508	2.534	2.561	2.596		
	Ebn at Noon	Ebn at Noon	905	943	951	953	955	945	946	943	929	892	863	873		
		Edh at Noon	62	78	95	107	109	110	108	100	91	77	63	56		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.47	2.29	3.53	4.65	5.79	6.64	6.85	5.89	4.32	2.65	1.56	1.27		
	RadStd	RadStd	0.20	0.33	0.51	0.47	0.53	0.38	0.38	0.37	0.26	0.34	0.20	0.16		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+1.02	N/A	N/A	N/A	N/A	N/A	-336	-388	N/A	N/A	(46)
(47) Regional (24 neighbors)		+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+71	N/A	(47)

Nomenclature: See separate page