

IMPERIA, Italy

WMO: 161500

Lat: 43.884N

Lon: 8.029E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 95-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	38.7	41.1	3.6	6.6	48.1	9.9	9.1	46.6	25.8	52.2	21.9	51.3	7.2	340	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	83.2	72.6	81.5	72.5	80.1	72.1	78.2	80.6	76.7	79.1	75.4	77.9	8.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	142.6	80.0	75.9	135.6	78.6	74.5	129.2	77.4	41.7	80.8	40.2	79.4	38.9	78.0	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	18.8	16.3		DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	50.0	50.7	53.9	56.8	64.2	71.1	73.5	74.8	69.1	63.6	55.8	51.5
	DBStd	9.74	4.04	3.95	3.74	4.40	4.34	4.19	3.52	3.09	3.71	4.16	4.70	4.59
	HDD50	145	49	35	12	3	0	0	0	0	0	0	10	36
	HDD65	2303	464	399	345	250	66	4	0	0	8	74	275	418
	CDD50	4277	50	56	132	206	440	632	729	768	573	423	185	83
	CDD65	962	0	0	0	3	41	186	264	303	132	32	1	0
	CDH74	3872	0	0	0	1	86	681	1206	1623	261	14	0	0
	CDH80	280	0	0	0	0	1	43	86	143	7	0	0	0
(14) Wind	WSAvg	6.3	6.4	6.3	6.2	6.7	6.3	6.2	6.4	5.9	6.1	6.3	6.4	6.6
(15) Precipitation	PrecAvg	27.7	2.3	1.7	2.0	2.7	1.6	1.0	0.7	0.7	2.9	3.6	5.1	3.6
	PrecMax	48.4	10.9	7.7	8.7	6.9	4.9	4.9	2.5	3.2	8.9	9.0	16.0	10.1
	PrecMin	14.5	0.0	0.0	0.2	0.4	0.2	0.0	0.0	0.0	0.0	0.8	0.6	0.0
	PrecStd	7.4	2.4	1.7	1.9	1.9	1.1	1.0	0.7	0.7	2.6	2.0	3.8	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	63.9	66.4	72.5	79.7	83.7	84.4	88.0	80.9	75.6	68.9	63.0
		MCWB	49.9	49.5	50.6	57.2	60.8	74.0	68.8	69.0	67.4	64.4	56.2	51.6
	2%	DB	58.8	59.7	63.0	68.7	76.4	81.4	82.4	83.8	78.6	73.6	65.7	60.9
		MCWB	50.4	48.6	50.8	56.7	61.3	74.6	70.6	74.4	69.0	65.5	58.2	51.3
	5%	DB	57.4	57.9	60.9	66.2	73.5	79.7	80.9	82.0	76.8	71.6	64.0	59.2
		MCWB	50.6	50.1	51.8	56.9	63.1	73.8	70.7	73.9	68.1	65.0	57.5	52.0
	10%	DB	56.1	56.4	59.4	63.6	71.0	78.0	79.4	80.3	75.2	69.8	62.5	57.8
		MCWB	50.1	50.4	52.0	56.0	62.2	71.9	70.9	73.5	66.8	63.6	56.4	51.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	56.7	59.1	65.0	70.3	79.1	78.6	80.9	74.6	69.9	63.8	59.0
		MCDB	58.4	59.8	60.0	66.7	72.6	81.4	80.9	82.8	77.4	72.0	65.9	59.5
	2%	WB	55.8	54.8	57.3	62.1	67.8	77.4	76.9	79.0	72.2	68.4	62.0	56.9
		MCDB	56.8	56.2	58.9	64.3	70.2	79.7	79.4	81.6	75.4	71.1	63.9	58.3
	5%	WB	53.9	53.5	56.0	59.9	65.9	76.0	75.6	77.2	71.0	66.8	60.1	55.2
		MCDB	55.5	55.5	57.9	62.3	69.3	78.3	77.9	79.6	74.2	69.6	62.2	57.2
	10%	WB	52.1	52.2	54.8	58.0	64.5	74.4	74.3	75.7	69.8	65.3	58.3	53.4
		MCDB	54.4	54.9	57.1	60.7	68.0	76.8	77.0	78.5	73.2	68.3	60.8	56.1
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.7	8.8	8.6	8.8	9.1	8.9	8.6	9.0	7.8	8.2	7.8
		MCDBR	8.5	10.0	10.2	10.7	10.6	10.0	9.8	9.1	9.5	9.3	8.9	8.4
		MCWBR	7.1	8.5	8.4	7.7	7.5	7.9	9.0	8.7	8.2	7.8	7.1	7.4
	5% WB	MCDBR	7.7	8.5	8.5	9.3	8.7	9.0	8.9	8.1	8.3	8.2	7.6	7.5
		MCWBR	7.2	8.2	7.8	7.6	7.7	7.3	8.0	8.0	7.4	7.7	6.9	7.1
(40) Clear-Sky Solar Irradiance	taub		0.336	0.360	0.402	0.441	0.445	0.457	0.449	0.441	0.427	0.407	0.365	0.332
	taud		2.445	2.371	2.267	2.176	2.223	2.237	2.268	2.300	2.307	2.326	2.400	2.467
	Ebn at Noon		249	261	263	261	264	260	261	259	252	240	233	239
	Edh at Noon		24	30	38	44	44	43	42	39	36	31	25	21
(44) All-Sky Solar Radiation	RadAvg		525	791	1207	1570	1901	2180	2226	1927	1448	917	562	455
	RadStd		54	95	128	120	139	108	105	85	86	89	61	56

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page