

CAPO MELE, Italy

WMO: 161530

Lat: 43.957N

Lon: 8.170E

Elev: 725

StdP: 14.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.0	39.0	-2.4	5.0	45.8	3.4	6.7	48.2	45.3	49.6	39.4	45.0	20.7	0	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	86.8	71.3	84.4	71.0	82.5	70.7	77.4	81.9	75.8	80.4	74.2	79.0	10.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.1	140.3	80.2	74.4	132.0	78.8	72.6	124.3	77.3	41.4	81.9	39.7	80.5	38.2	79.1	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
36.2	30.5	26.1	33.1	91.2	3.8	3.0	30.3	93.3	28.1	95.1	26.0	96.8	23.3	99.0
			26.6	79.8	2.9	2.7	24.5	81.8	22.9	83.3	21.3	84.8	19.2	86.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	48.8	49.2	53.0	57.2	63.9	70.7	75.8	76.5	70.6	63.9	56.2	51.0
	DBStd	10.77	4.07	4.44	4.49	4.62	4.63	4.84	3.94	3.91	4.41	4.62	4.79	4.82
	HDD50	214	69	59	23	3	0	0	0	0	0	1	11	48
	HDD65	2416	502	444	373	237	76	6	0	8	72	264	434	
	CDD50	4401	31	35	115	220	431	621	800	821	619	433	197	78
	CDD65	1131	0	0	0	4	41	178	335	356	177	39	1	0
	CDH74	5684	0	0	0	6	90	753	2050	2234	519	32	0	0
	CDH80	1106	0	0	0	0	5	124	415	506	56	0	0	0
Wind	WSAvg	11.0	11.8	12.0	12.3	11.8	10.6	9.7	9.3	9.3	10.4	11.3	12.1	11.9
Precipitation	PrecAvg	27.7	2.3	1.7	2.0	2.7	1.6	1.0	0.7	0.7	2.9	3.6	5.1	3.6
	PrecMax	48.4	10.9	7.7	8.7	6.9	4.9	4.9	2.5	3.2	8.9	9.0	16.0	10.1
	PrecMin	14.5	0.0	0.0	0.2	0.4	0.2	0.0	0.0	0.0	0.8	0.6	0.0	0.0
	PrecStd	7.4	2.4	1.7	1.9	1.9	1.1	1.0	0.7	0.7	2.6	2.0	3.8	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	62.2	67.9	73.6	80.3	87.9	89.0	91.5	84.8	77.4	69.4	63.0
		MCWB	49.0	47.7	51.9	57.6	61.5	71.0	71.3	70.5	67.8	62.2	55.4	50.7
	2%	DB	57.5	59.0	64.1	69.5	76.6	83.4	86.2	87.6	81.0	74.1	66.0	60.4
		MCWB	48.5	48.7	52.0	56.7	60.8	69.1	72.6	70.3	67.1	62.7	55.5	50.0
	5%	DB	55.6	56.9	61.1	66.6	73.6	80.7	84.3	84.6	78.9	71.8	63.8	58.5
		MCWB	48.4	48.2	51.3	55.9	60.6	68.9	71.8	71.2	66.6	62.1	55.2	49.5
	10%	DB	53.8	55.0	59.0	64.3	71.3	78.5	82.3	82.6	77.0	69.8	61.6	56.8
		MCWB	46.9	47.3	50.6	54.4	60.9	68.5	71.4	71.2	65.6	61.4	54.3	49.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.5	55.3	59.4	63.8	69.8	77.3	79.9	79.2	75.7	69.3	61.8	56.9
		MCDB	56.6	57.7	61.6	67.4	72.8	81.8	83.7	83.8	78.9	71.9	64.0	59.3
	2%	WB	53.2	52.9	56.7	60.9	67.1	74.5	77.9	77.2	72.8	67.4	59.7	54.7
		MCDB	55.1	55.4	59.4	64.5	70.9	78.9	82.1	82.1	76.7	70.2	62.4	57.5
	5%	WB	51.2	51.3	55.0	59.0	65.1	72.5	76.1	75.6	70.8	65.5	58.2	53.1
		MCDB	53.5	53.8	57.6	63.0	69.1	77.3	80.5	80.7	75.2	69.2	61.3	56.2
	10%	WB	49.5	50.0	53.5	57.2	63.4	70.6	74.4	74.1	69.1	63.7	56.8	51.6
		MCDB	52.0	52.3	56.2	61.9	67.6	75.6	79.1	79.1	73.7	67.8	60.2	54.9
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.0	9.8	9.8	10.1	10.4	10.7	10.8	10.3	9.0	8.3	7.9
		MCDBR	9.7	11.1	12.3	12.5	12.6	12.0	12.5	12.9	12.3	11.1	9.9	9.5
		MCWBR	9.0	9.8	9.7	9.1	9.2	9.6	10.0	10.1	9.2	8.6	8.4	8.7
	5% WB	MCDBR	8.2	9.1	9.9	10.5	10.3	10.1	10.8	10.8	9.9	8.9	7.7	7.9
		MCWBR	8.5	9.2	9.0	9.6	9.5	9.6	9.5	9.5	8.8	8.3	7.6	8.2
Clear-Sky Solar Irradiance	taub	0.330	0.354	0.394	0.432	0.434	0.447	0.439	0.432	0.417	0.399	0.358	0.326	
	taud	2.454	2.381	2.279	2.189	2.238	2.249	2.280	2.309	2.316	2.333	2.406	2.474	
	Ebn at Noon	251	264	266	264	267	263	264	261	255	243	236	241	
	Edh at Noon	23	30	37	44	43	43	41	39	36	31	24	21	
All-Sky Solar Radiation	RadAvg	516	779	1196	1562	1900	2176	2226	1922	1443	904	551	446	
	RadStd	54	96	131	120	139	108	106	88	86	92	61	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+1.51	+1.94	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page