

CAPO MELE, Italy

WMO: 161530

Lat: 43.957N

Lon: 8.170E

Elev: 221

StdP: 98.70

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.2	3.9	-19.1	0.7	7.7	-15.9	1.0	9.0	20.2	9.8	17.6	7.2	9.2	0	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	30.4	21.8	29.1	21.7	28.0	21.5	25.2	27.7	24.3	26.9	23.5	26.1	4.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	20.0	26.8	23.5	18.9	26.0	22.6	17.8	25.2	78.5	27.7	74.5	26.9	71.1	26.1	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.2	13.6	11.7	DB	0.6	32.9	2.1	1.7	-0.9	34.1	-2.2	35.1	-3.3	36.0	-4.9	37.2	
			WB	-3.0	26.6	1.6	1.5	-4.1	27.6	-5.1	28.5	-6.0	29.4	-7.1	30.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	9.3	9.5	11.6	14.0	17.7	21.5	24.3	24.7	21.5	17.7	13.5	10.5
	DBStd	5.98	2.26	2.47	2.50	2.57	2.57	2.69	2.19	2.17	2.45	2.56	2.66	2.68
	HDD10.0	119	38	33	13	2	0	0	0	0	0	1	6	27
	HDD18.3	1342	279	247	207	132	42	3	0	0	4	40	147	241
	CDD10.0	2445	17	19	64	122	239	345	444	456	344	241	109	43
	CDD18.3	628	0	0	0	2	23	99	186	198	98	22	1	0
	CDH23.3	3158	0	0	0	3	50	418	1139	1241	288	18	0	0
	CDH26.7	614	0	0	0	0	3	69	231	281	31	0	0	0
Wind	WSAvg	4.9	5.3	5.4	5.5	5.3	4.7	4.3	4.2	4.1	4.7	5.1	5.4	5.3
Precipitation	PrecAvg	704	58	43	50	69	40	25	17	17	73	92	129	91
	PrecMax	1229	278	195	222	176	124	124	64	82	226	228	406	256
	PrecMin	368	0	0	6	9	6	0	1	0	0	20	15	1
	PrecStd	188	61	43	49	49	27	26	17	19	67	52	96	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	16.8	19.9	23.1	26.9	31.0	31.7	33.1	29.3	25.2	20.8	17.2
		MCWB	9.4	8.7	11.1	14.2	16.4	21.7	21.9	21.4	19.9	16.8	13.0	10.4
	2%	DB	14.2	15.0	17.8	20.9	24.8	28.6	30.1	30.9	27.2	23.4	18.9	15.8
		MCWB	9.1	9.3	11.1	13.7	16.0	20.6	22.6	21.3	19.5	17.1	13.0	10.0
	5%	DB	13.1	13.8	16.2	19.2	23.1	27.1	29.0	29.2	26.1	22.1	17.6	14.7
		MCWB	9.1	9.0	10.7	13.3	15.9	20.5	22.1	21.8	19.2	16.7	12.9	9.7
	10%	DB	12.1	12.8	15.0	17.9	21.8	25.8	27.9	28.1	25.0	21.0	16.4	13.8
		MCWB	8.3	8.5	10.3	12.4	16.0	20.3	21.9	21.8	18.7	16.3	12.4	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	12.9	15.2	17.7	21.0	25.2	26.6	26.2	24.3	20.7	16.6	13.8
		MCDB	13.7	14.3	16.5	19.7	22.6	27.7	28.7	28.8	26.0	22.2	17.8	15.2
	2%	WB	11.8	11.6	13.7	16.0	19.5	23.6	25.5	25.1	22.7	19.7	15.4	12.6
		MCDB	12.8	13.0	15.2	18.1	21.6	26.0	27.8	27.8	24.9	21.2	16.9	14.2
	5%	WB	10.7	10.7	12.8	15.0	18.4	22.5	24.5	24.2	21.5	18.6	14.6	11.7
		MCDB	12.0	12.1	14.2	17.2	20.6	25.2	27.0	27.0	24.0	20.7	16.3	13.4
	10%	WB	9.7	10.0	11.9	14.0	17.5	21.4	23.6	23.4	20.6	17.6	13.8	10.9
		MCDB	11.1	11.3	13.5	16.6	19.8	24.2	26.2	26.2	23.1	19.9	15.7	12.7
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.0	5.4	5.5	5.6	5.8	5.9	6.0	5.7	5.0	4.6	4.4
		MCDBR	5.4	6.2	6.9	7.0	7.0	6.7	7.0	7.2	6.8	6.2	5.5	5.3
		MCWBR	5.0	5.4	5.4	5.0	5.1	5.3	5.6	5.6	5.1	4.8	4.7	4.8
	5% WB	MCDBR	4.6	5.1	5.5	5.8	5.7	5.6	6.0	6.0	5.5	5.0	4.3	4.4
		MCWBR	4.7	5.1	5.0	5.3	5.3	5.3	5.3	5.3	4.9	4.6	4.2	4.5
Clear-Sky Solar Irradiance	taub	0.330	0.354	0.394	0.432	0.434	0.447	0.439	0.432	0.417	0.399	0.358	0.326	
	taud	2.454	2.381	2.279	2.189	2.238	2.249	2.280	2.309	2.316	2.333	2.406	2.474	
	Ebn at Noon	791	831	838	832	841	829	831	824	804	765	744	760	
	Edh at Noon	74	93	117	139	136	135	130	122	112	97	77	66	
All-Sky Solar Radiation	RadAvg	1.63	2.46	3.77	4.92	5.99	6.86	7.02	6.06	4.55	2.85	1.74	1.41	
	RadStd	0.17	0.30	0.41	0.38	0.44	0.34	0.33	0.28	0.27	0.29	0.19	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	+0.84	+1.08	N/A	N/A	N/A	N/A
Regional (26 neighbors)		+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page