

MONTE ARGENTARIO, Italy

WMO: 161680

Lat: 42.387N

Lon: 11.170E

Elev: 2071

StdP: 13.63

Time Zone: 1.00 (EUC)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 28.5	(c) 31.5	(d) 3.8	(e) 7.2	(f) 40.2	(g) 10.1	(h) 9.9	(i) 40.2	(j) 40.9	(k) 41.3	(l) 36.1	(m) 41.2	(n) 17.7	(o) 20	(p) 0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 14.8	(c) 89.8	(d) 65.8	(e) 86.4	(f) 65.3	(g) 84.0	(h) 64.9	(i) 72.7	(j) 78.0	(k) 71.1	(l) 76.5	(m) 69.6	(n) 75.3	(o) 5.9	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	126.1	73.9	69.8	118.5	72.8	68.0	111.3	71.1	37.7	78.9	36.4	78.5	35.1	74.8	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 35.3	(b) 30.3	(c) 26.8	(e) 25.3	(f) 95.2	(g) 2.7	(h) 2.7	(i) 23.3	(j) 97.2	(k) 21.7	(l) 98.8	(m) 20.2	(n) 100.3	(o) 18.3	(p) 102.3		
			DB													
			WB													
				21.3	76.4	2.6	1.8	19.4	77.7	18.0	78.8	16.5	79.8	14.7	81.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	43.4	43.9	48.2	53.5	62.2	70.1	75.1	75.4	66.8	59.8	51.1	44.9
	DBStd	12.73	4.88	5.43	5.54	5.60	5.78	6.47	5.04	5.62	5.19	4.89	5.52	5.19
	HDD50	731	208	176	98	24	0	0	0	0	0	3	52	170
	HDD65	3535	670	592	522	348	128	22	1	1	39	169	418	625
	CDD50	3626	3	4	41	128	377	602	777	788	504	308	84	10
	CDD65	953	0	0	0	2	39	174	313	324	92	9	0	0
	CDH74	5386	0	0	0	3	133	971	1940	2041	287	11	0	0
	CDH80	1645	0	0	0	0	17	269	609	701	49	0	0	0
Wind	WSAvg	11.1	12.4	12.8	12.0	11.8	10.3	9.7	8.7	8.7	9.7	11.0	12.9	13.9
Precipitation	PrecAvg	24.1	2.2	1.9	2.0	1.9	1.5	0.9	0.4	0.6	2.6	3.1	3.9	2.9
	PrecMax	36.4	5.6	4.4	5.7	3.1	4.8	5.7	2.7	3.2	7.2	6.4	13.7	10.8
	PrecMin	14.3	0.0	0.1	0.0	0.7	0.2	0.0	0.0	0.0	0.2	0.1	0.4	0.1
	PrecStd	6.3	1.6	1.2	1.3	0.7	1.1	1.1	0.7	0.8	1.9	1.6	2.6	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	57.5	64.7	72.9	82.2	90.0	93.0	95.2	85.6	75.0	64.4	56.7
		MCWB	45.8	46.0	51.2	54.9	61.9	65.6	66.0	66.6	64.7	60.2	56.2	49.6
	2%	DB	52.0	53.9	61.0	68.2	77.3	86.4	89.5	91.0	80.6	70.1	61.1	54.0
		MCWB	47.8	44.7	49.0	53.5	59.3	64.8	66.0	65.9	63.4	59.5	57.1	50.8
	5%	DB	50.4	51.8	57.8	64.5	73.7	82.8	86.1	86.4	77.0	67.9	59.2	53.2
		MCWB	47.5	45.1	47.3	51.7	58.1	63.8	65.8	65.4	61.5	59.2	55.8	50.4
	10%	DB	49.7	50.0	55.1	61.2	70.8	79.3	82.8	83.8	73.7	65.8	57.4	51.7
		MCWB	47.2	45.0	46.0	50.1	56.5	62.1	65.1	65.1	61.9	59.1	54.7	49.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	51.8	54.2	58.2	65.0	72.2	75.2	75.0	72.1	66.8	61.2	54.9
		MCDB	52.3	52.7	61.0	66.3	74.6	79.7	80.3	80.7	73.8	68.1	61.6	55.1
	2%	WB	50.4	50.0	52.0	55.6	62.4	69.5	72.7	72.9	69.6	64.8	59.2	53.3
		MCDB	50.9	51.4	55.7	62.7	71.5	76.9	79.3	77.4	72.6	66.2	59.9	53.6
	5%	WB	49.6	48.4	50.6	54.0	60.5	67.6	70.8	71.4	67.9	63.2	57.4	51.9
		MCDB	50.2	49.5	53.2	59.7	68.6	75.6	77.2	76.0	70.7	64.9	58.2	52.3
	10%	WB	48.0	47.2	49.7	52.7	59.0	65.6	69.1	69.9	66.2	61.8	55.7	50.2
		MCDB	48.8	48.3	52.0	58.2	65.8	74.2	75.6	75.2	70.0	63.6	56.8	50.8
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.7	10.2	11.6	13.3	14.4	15.3	14.8	12.5	8.9	7.5	7.2
		MCDBR	7.9	10.7	13.6	15.2	16.6	16.7	17.7	17.5	15.8	11.6	8.6	7.4
		MCWBR	8.0	9.3	10.5	10.9	11.4	11.9	11.4	11.2	10.9	9.2	7.9	7.4
	5% WB	MCDDBR	5.8	7.6	9.6	12.7	14.1	14.6	14.6	13.2	10.8	8.0	6.4	5.7
		MCWBR	7.0	8.3	8.8	10.7	11.3	12.6	13.6	12.9	10.4	7.9	7.5	7.2
Clear-Sky Solar Irradiance	taub		0.307	0.322	0.349	0.376	0.382	0.379	0.374	0.373	0.364	0.353	0.334	0.308
	taud		2.536	2.490	2.424	2.361	2.381	2.421	2.433	2.449	2.471	2.496	2.496	2.542
	Ebn at Noon		268	281	284	283	283	283	283	281	276	265	253	257
	Edh at Noon		22	27	33	37	37	36	36	34	31	27	23	20
All-Sky Solar Radiation	RadAvg		557	861	1256	1682	2057	2331	2373	2067	1532	1014	619	497
	RadStd		54	79	138	112	157	107	101	95	77	84	55	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (23 neighbors)	+0.43	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	+142	N/A

Nomenclature: See separate page