

MONTE ARGENTARIO, Italy

WMO: 161680

Lat: 42.387N

Lon: 11.170E

Elev: 631

StdP: 93.97

Time Zone: 1.00 (EUC)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.0	(c) -0.3	(d) -15.6	(e) 1.0	(f) 4.6	(g) -12.2	(h) 1.4	(i) 4.6	(j) 18.3	(k) 5.2	(l) 16.1	(m) 5.1	(n) 7.9	(o) 20	(p) 0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.2	(c) 32.1	(d) 18.8	(e) 30.2	(f) 18.5	(g) 28.9	(h) 18.3	(i) 22.6	(j) 25.5	(k) 21.7	(l) 24.7	(m) 20.9	(n) 24.0	(o) 2.7	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.0	18.0	23.3	21.0	16.9	22.6	20.0	15.9	21.7	69.9	26.1	66.7	25.8	63.7	23.8	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	13.6	12.0	-3.7	35.1	1.5	1.5	-4.8	36.2	-5.7	37.1	-6.5	37.9	-7.6	39.1
			-6.0	24.7	1.4	1.0	-7.0	25.4	-7.8	26.0	-8.6	26.5	-9.6	27.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	6.3	6.6	9.0	11.9	16.8	21.2	23.9	24.1	19.3	15.5	10.6	7.1
	DBStd	7.07	2.71	3.02	3.08	3.11	3.21	3.59	2.80	3.12	2.88	2.72	3.07	2.88
	HDD10.0	406	116	98	54	13	0	0	0	0	0	2	29	94
	HDD18.3	1964	372	329	290	193	71	12	1	1	22	94	232	347
	CDD10.0	2014	2	2	23	71	209	334	432	438	280	171	47	6
	CDD18.3	529	0	0	0	1	22	97	174	180	51	5	0	0
	CDH23.3	2992	0	0	0	2	74	539	1078	1134	159	6	0	0
	CDH26.7	914	0	0	0	0	9	149	338	389	27	0	0	0
Wind	WSAvg	5.0	5.5	5.7	5.3	5.3	4.6	4.3	3.9	3.9	4.3	4.9	5.8	6.2
Precipitation	PrecAvg	613	57	48	52	47	39	22	11	16	65	80	100	74
	PrecMax	924	141	112	144	80	122	144	68	81	184	162	347	274
	PrecMin	362	1	2	0	17	4	1	0	0	4	3	9	2
	PrecStd	161	41	31	34	19	29	29	17	20	48	41	67	62
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	14.2	18.2	22.7	27.9	32.2	33.9	35.1	29.8	23.9	18.0	13.7
		MCWB	7.7	7.8	10.7	12.7	16.6	18.7	18.9	19.2	18.2	15.6	13.5	9.8
	2%	DB	11.1	12.2	16.1	20.1	25.1	30.2	31.9	32.8	27.0	21.2	16.2	12.2
		MCWB	8.8	7.0	9.5	12.0	15.2	18.2	18.9	18.9	17.4	15.3	13.9	10.4
	5%	DB	10.2	11.0	14.3	18.1	23.2	28.2	30.1	30.2	25.0	20.0	15.1	11.8
		MCWB	8.6	7.3	8.5	10.9	14.5	17.7	18.8	18.5	16.4	15.1	13.2	10.2
	10%	DB	9.8	10.0	12.9	16.2	21.5	26.3	28.2	28.8	23.2	18.8	14.1	10.9
		MCWB	8.5	7.2	7.8	10.0	13.6	16.7	18.4	18.4	16.6	15.1	12.6	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	11.0	12.3	14.5	18.4	22.4	24.0	23.9	22.3	19.3	16.2	12.7
		MCDB	11.3	11.5	16.1	19.1	23.7	26.5	26.8	27.0	23.2	20.0	16.4	12.8
	2%	WB	10.2	10.0	11.1	13.1	16.9	20.8	22.6	22.7	20.9	18.2	15.1	11.9
		MCDB	10.5	10.8	13.1	17.1	21.9	25.0	26.3	25.2	22.5	19.0	15.5	12.0
	5%	WB	9.8	9.1	10.3	12.2	15.9	19.8	21.5	21.9	20.0	17.4	14.1	11.0
		MCDB	10.1	9.7	11.8	15.4	20.3	24.2	25.1	24.4	21.5	18.3	14.6	11.3
	10%	WB	8.9	8.4	9.8	11.5	15.0	18.7	20.6	21.1	19.0	16.6	13.2	10.1
		MCDB	9.3	9.1	11.1	14.6	18.8	23.4	24.2	24.0	21.1	17.6	13.8	10.5
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.8	5.7	6.4	7.4	8.0	8.5	8.2	6.9	5.0	4.2	4.0
		MCDBR	4.4	5.9	7.6	8.5	9.2	9.3	9.8	9.7	8.8	6.4	4.8	4.1
		MCWBR	4.4	5.2	5.8	6.1	6.3	6.6	6.3	6.2	6.0	5.1	4.4	4.1
	5% WB	MCDBR	3.2	4.2	5.3	7.1	7.8	8.1	8.1	7.4	6.0	4.5	3.6	3.2
		MCWBR	3.9	4.6	4.9	5.9	6.3	7.0	7.5	7.1	5.8	4.4	4.2	4.0
Clear-Sky Solar Irradiance	taub	0.307	0.322	0.349	0.376	0.382	0.379	0.374	0.373	0.364	0.353	0.334	0.308	
	taud	2.536	2.490	2.424	2.361	2.381	2.421	2.433	2.449	2.471	2.496	2.496	2.542	
	Ebn at Noon	845	885	896	892	892	893	893	885	869	835	799	810	
	Edh at Noon	70	85	103	118	118	114	112	107	97	84	73	64	
All-Sky Solar Radiation	RadAvg	1.76	2.71	3.96	5.30	6.49	7.35	7.48	6.52	4.83	3.20	1.95	1.57	
	RadStd	0.17	0.25	0.43	0.35	0.49	0.34	0.32	0.30	0.24	0.27	0.17	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		+0.24	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	+79	N/A

Nomenclature: See separate page