

FIRENZE PERETOLA, Italy

WMO: 161700

Lat: 43.810N

Lon: 11.205E

Elev: 144

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.5	29.5	13.8	11.1	37.0	17.4	13.3	37.9	21.1	42.2	18.1	43.5	2.1	80	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.7	96.4	71.2	93.3	70.7	91.0	70.1	75.2	87.8	73.6	86.5	72.3	85.0	8.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.6	117.3	80.4	69.8	110.0	79.4	68.1	103.8	78.5	38.6	88.4	37.2	87.0	36.0	85.0	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.5	13.3	21.6	100.4	2.9	3.1	19.5	102.6	17.8	104.5	16.2	106.2	14.1	108.5		
(5)			20.6	77.2	2.7	2.3	18.6	78.8	17.0	80.2	15.5	81.4	13.5	83.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	44.1	46.0	51.7	57.9	65.4	73.4	78.0	78.1	70.1	62.2	52.6	45.2		
	DBStd	13.26	5.94	5.89	5.33	4.81	4.83	5.24	4.19	4.49	5.10	5.43	6.39	6.60		
	HDD50	604	197	132	46	4	0	0	0	0	0	1	47	177		
	HDD65	2984	647	531	413	217	54	4	0	0	13	118	372	615		
	CDD50	4427	15	21	98	240	477	701	869	871	602	380	126	27		
	CDD65	1330	0	0	0	3	66	254	404	406	165	32	0	0		
	CDH74	13451	0	0	4	83	643	2544	4399	4336	1303	138	1	0		
	CDH80	5869	0	0	0	5	154	1055	2124	2120	400	11	0	0		
	WSAvg	4.7	3.9	4.8	5.5	5.1	5.1	5.2	5.4	5.1	4.8	4.1	4.0	3.9		
	PrecAvg	33.3	2.7	2.8	3.0	2.6	2.6	2.0	1.5	2.5	2.9	3.1	4.6	3.1		
(15) Precipitation	PrecMax	45.4	7.0	7.5	6.9	7.2	5.0	4.1	6.8	5.1	6.9	8.9	9.3	7.2		
	PrecMin	19.8	0.2	0.0	0.0	0.6	0.0	0.1	0.0	0.0	0.0	0.3	0.4	0.2		
	PrecStd	8.0	1.6	1.9	1.9	1.6	1.5	1.0	1.7	1.5	1.8	2.4	2.4	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	64.1	73.5	80.4	88.1	96.3	98.9	100.6	91.9	80.9	70.9	62.8		
		MCWB	53.4	51.8	55.5	61.3	66.8	72.4	70.7	71.1	69.1	64.7	61.6	55.7		
	2%	DB	58.1	60.6	68.2	76.6	84.3	93.1	96.2	96.8	88.2	77.4	66.6	59.8		
		MCWB	51.9	50.8	53.8	59.7	65.7	71.2	70.9	71.1	68.1	64.8	59.0	54.4		
	5%	DB	55.6	57.6	64.8	72.6	80.6	89.7	93.2	93.5	84.4	75.0	64.4	57.3		
		MCWB	50.0	49.6	53.1	58.0	64.3	69.9	70.5	70.8	66.9	63.3	57.6	52.5		
	10%	DB	53.5	55.6	62.2	69.4	77.2	86.3	90.0	90.5	81.0	71.8	62.2	55.1		
		MCWB	48.8	49.1	52.1	56.8	62.6	69.0	69.9	70.1	65.7	62.5	56.7	50.6		
	0.4%	WB	55.7	54.9	58.4	63.9	69.6	76.3	76.7	77.7	72.8	69.1	63.5	57.7		
		MCDB	59.2	59.6	66.5	75.4	82.5	91.0	89.6	90.4	83.6	75.8	68.5	60.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	53.2	53.0	56.3	61.2	67.3	73.7	74.6	75.5	70.9	67.3	60.5	55.5		
		MCDB	56.6	57.2	63.9	72.3	80.0	87.6	87.8	87.7	81.7	73.7	64.8	59.0		
	5%	WB	51.7	51.5	54.9	59.3	65.6	71.8	73.2	73.9	69.4	65.4	58.9	53.6		
		MCDB	54.9	55.9	61.7	69.4	77.4	85.3	86.7	85.9	80.0	71.7	63.4	56.6		
	10%	WB	49.9	50.1	53.4	57.7	63.9	70.0	72.0	72.5	67.8	63.7	57.3	51.5		
		MCDB	52.4	54.3	60.2	66.8	74.7	83.0	85.2	84.5	78.0	69.9	61.2	54.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.3	15.8	17.5	19.4	20.2	21.7	22.7	23.1	20.1	17.2	14.3	13.6		
		MCDBR	15.8	19.5	23.9	26.6	26.3	26.6	27.2	27.7	25.2	20.6	16.0	14.8		
		MCWBR	10.5	11.7	12.4	12.8	11.5	9.7	8.8	8.9	9.1	9.5	9.5	9.9		
		MCDBR	12.2	14.8	18.3	22.3	22.7	23.6	22.9	22.5	20.5	16.3	13.7	11.8		
	5% WB	MCWBR	9.0	9.7	10.2	11.4	10.4	9.8	8.7	8.7	8.6	8.1	8.7	8.7		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.368	0.406	0.433	0.438	0.444	0.434	0.427	0.414	0.405	0.375	0.342		
	taud		2.420	2.328	2.230	2.181	2.208	2.237	2.270	2.305	2.320	2.320	2.345	2.440		
	Ebn at Noon		245	258	261	264	266	264	265	263	256	241	228	234		
	Edh at Noon		24	31	39	44	44	43	42	39	36	31	26	22		
(44) All-Sky Solar Radiation	RadAvg		472	730	1113	1485	1848	2125	2197	1895	1381	872	511	409		
	RadStd		59	102	161	142	171	120	123	121	79	96	58	50		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+2.00	-1.51	-1.75	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+126	N/A

Nomenclature: See separate page