

AREZZO, Italy

WMO: 161720

Lat: 43.4597N

Lon: 11.8456E

Elev: 817

StdP: 14.27

Time Zone: 1.00 (EUC)

Period: 00-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.8	26.4	12.0	10.4	39.4	15.8	12.6	37.2	20.9	47.5	19.0	46.9	0.3	100	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.5	95.1	68.7	91.8	68.1	89.4	67.3	72.8	86.0	71.0	84.3	69.6	82.9	6.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.0	109.7	77.5	67.0	102.4	75.9	65.4	96.6	74.5	36.9	85.3	35.3	84.5	34.1	82.7	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	15.3	12.5	DB	18.1	98.7	3.7	3.6	15.4	101.3	13.2	103.4	11.1	105.4	8.4	108.0
			WB	17.4	74.9	3.9	1.6	14.7	76.1	12.4	77.1	10.2	78.0	7.4	79.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	40.8	42.3	48.3	54.7	61.6	69.5	74.7	74.2	66.3	58.1	49.0	42.1
	DBStd	13.17	5.80	5.85	5.83	5.08	4.86	5.48	4.42	4.47	5.46	5.44	6.49	6.41
	HDD50	982	291	220	99	15	0	0	0	0	0	7	96	254
	HDD65	3820	750	635	517	309	129	19	1	1	48	219	481	711
	CDD50	3493	5	5	46	157	359	585	766	750	488	258	65	9
	CDD65	856	0	0	0	1	23	153	302	286	86	5	0	0
	CDH74	10325	0	0	0	58	443	1826	3693	3365	901	39	0	0
	CDH80	4461	0	0	0	3	101	715	1784	1602	252	4	0	0
	WSAvg	3.0	2.9	3.7	4.2	3.1	3.0	2.9	3.2	2.9	2.7	2.1	2.4	2.6
	PrecAvg	30.3	2.6	2.4	2.6	2.4	2.4	1.9	1.6	1.9	2.5	3.1	3.4	3.1
(15) Precipitation	PrecMax	43.5	5.7	6.9	4.8	5.8	6.9	5.0	4.4	5.5	8.2	8.5	6.4	6.3
	PrecMin	19.9	0.0	0.0	0.1	0.6	0.2	0.7	0.0	0.0	0.1	0.0	0.6	0.2
	PrecStd	6.7	1.6	2.0	1.5	1.6	1.7	1.1	1.1	1.5	1.9	2.2	1.7	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	57.7	60.5	70.2	79.1	87.7	93.7	98.5	100.1	90.8	77.4	68.1	60.1	
	0.4% MCWB	52.1	51.1	52.8	58.3	64.4	68.6	69.0	69.5	65.6	61.3	58.1	54.7	
	2% DB	55.4	56.8	66.6	75.2	82.5	91.1	95.1	95.4	86.4	74.1	64.3	57.1	
	2% MCWB	50.5	47.8	52.0	56.4	63.0	68.1	69.3	68.1	64.8	62.1	57.2	51.9	
	5% DB	53.1	54.0	63.3	71.4	78.8	87.8	91.9	92.1	82.5	71.4	61.5	54.5	
	5% MCWB	48.5	47.4	51.2	55.6	61.4	67.7	68.4	68.0	64.2	61.0	55.8	49.9	
	10% DB	50.2	51.9	60.3	67.8	75.3	84.1	89.4	88.8	79.0	68.4	59.1	51.9	
	10% MCWB	46.4	46.6	50.2	54.1	59.6	65.9	67.9	66.7	62.8	59.6	54.4	48.0	
	0.4% WB	53.4	52.4	57.1	60.7	66.5	73.4	75.1	74.6	72.6	66.7	62.0	55.6	
	0.4% MCDB	56.6	56.8	66.0	72.1	80.8	85.5	88.2	89.7	79.2	72.1	65.2	59.0	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	51.5	50.5	54.7	58.5	64.6	70.7	72.9	72.5	69.1	64.7	58.5	53.2	
	2% MCDB	54.4	54.0	61.4	70.0	78.5	84.9	87.2	86.1	77.6	69.9	61.8	56.2	
	5% WB	49.5	49.1	53.0	56.9	63.0	68.9	71.1	70.7	67.2	63.0	56.6	50.9	
	5% MCDB	52.1	52.4	59.5	67.9	76.0	83.3	85.0	83.7	77.0	68.3	60.5	53.4	
	10% WB	47.3	47.5	51.4	55.3	61.1	67.1	69.7	69.2	65.4	61.3	54.9	49.0	
	10% MCDB	49.4	50.9	57.7	64.9	72.1	80.6	83.9	82.2	75.5	66.8	58.7	51.2	
(35) Mean Daily Temperature Range	MDBR	13.8	15.3	18.7	21.8	23.0	23.8	26.5	26.7	22.6	18.7	15.1	13.7	
	5% DB MCDBR	15.0	18.0	26.4	30.3	30.3	29.4	31.4	32.4	27.7	22.0	16.9	15.2	
	5% DB MCWBR	10.6	11.4	13.7	14.0	12.9	10.8	10.3	10.4	10.6	11.5	10.9	10.9	
	5% WB MCDBR	11.1	13.7	19.4	25.3	26.5	26.9	27.3	26.5	22.5	16.9	13.8	12.0	
	5% WB MCWBR	8.9	9.7	11.3	13.2	12.8	11.3	10.9	10.8	10.7	10.6	10.3	9.6	
(40) Clear-Sky Solar Irradiance	taub	0.333	0.354	0.389	0.422	0.426	0.428	0.417	0.413	0.400	0.386	0.360	0.331	
	taud	2.439	2.354	2.269	2.193	2.221	2.260	2.293	2.322	2.338	2.363	2.376	2.455	
	Ebn at Noon	251	264	268	267	269	268	270	267	261	248	236	240	
	Edh at Noon	24	30	38	44	44	43	41	38	35	30	25	22	
(44) All-Sky Solar Radiation	RadAvg	477	729	1094	1463	1818	2109	2192	1897	1364	884	524	418	
	RadStd	59	100	162	146	179	117	125	130	81	89	56	52	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	N/A

Nomenclature: See separate page