

FUCINO, Italy

WMO: 162270

Lat: 41.9783N

Lon: 13.6053E

Elev: 2136

StdP: 13.60

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.2	23.2	16.7	13.8	28.0	20.2	16.4	28.2	19.2	36.2	17.1	37.9	1.2	60	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.7	90.7	62.9	87.5	62.7	85.0	62.9	72.5	79.7	71.0	79.8	69.5	79.2	6.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.5	121.4	76.2	68.3	112.6	75.8	66.2	104.4	75.1	37.7	79.5	36.3	79.8	34.9	79.4	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	13.8	11.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	38.3	41.0	44.7	52.2	60.1	66.0	70.3	69.8	62.2	55.6	45.8	38.9		
	DBStd	12.76	6.09	5.81	5.39	6.59	5.30	5.65	4.12	4.40	5.71	5.95	6.40	5.81		
	HDD50	1378	367	256	175	54	1	0	0	0	1	19	158	347		
	HDD65	4555	829	673	629	385	166	54	7	11	121	293	577	810		
	CDD50	2767	3	2	11	119	315	479	630	614	366	194	31	3		
	CDD65	470	0	0	0	1	16	83	172	160	36	2	0	0		
	CDH74	6812	0	0	2	83	383	1204	2365	2106	584	84	1	0		
	CDH80	2165	0	0	0	2	48	344	858	778	131	4	0	0		
(14) Wind	WSAvg	2.9	2.6	3.3	3.6	3.2	2.9	2.6	2.9	2.8	2.8	2.6	2.3	2.9		
(15) Precipitation	PrecAvg	35.0	3.1	2.7	3.1	3.1	2.2	1.4	1.2	1.2	2.9	4.3	5.3	4.5		
	PrecMax	46.6	9.1	5.7	8.3	5.4	4.4	4.0	2.8	3.3	5.8	9.3	12.9	9.5		
	PrecMin	23.0	0.1	0.4	0.0	1.4	0.6	0.2	0.0	0.1	1.1	0.3	1.5	0.1		
	PrecStd	6.6	2.2	1.5	1.9	1.2	1.0	0.9	0.7	0.9	1.4	2.5	2.8	2.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.6	65.0	70.9	79.7	84.1	91.4	95.5	94.5	87.9	79.8	69.8	57.8		
		MCWB	52.3	52.4	56.3	60.6	62.8	65.9	66.6	63.9	61.6	64.1	56.5	50.4		
	2%	DB	55.9	59.9	67.0	76.6	81.1	87.2	90.9	90.5	84.2	76.2	65.2	54.8		
		MCWB	49.6	49.9	53.4	60.1	62.1	63.4	62.2	62.2	61.6	61.7	54.3	49.3		
	5%	DB	51.7	56.4	63.1	73.2	78.6	84.3	87.2	87.6	81.3	73.6	61.5	52.0		
		MCWB	47.1	48.7	51.6	58.7	62.0	63.1	62.8	62.7	62.2	61.0	52.3	47.7		
	10%	DB	48.4	52.8	58.2	68.3	75.5	81.0	84.6	84.6	77.9	69.8	57.5	48.8		
		MCWB	45.4	46.9	49.3	55.9	60.3	62.8	63.4	62.6	61.7	58.3	50.6	46.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	56.4	59.6	63.9	70.8	73.9	73.6	74.5	72.1	67.9	62.7	52.9		
		MCDB	60.4	64.6	70.4	74.2	77.0	81.2	79.0	79.3	77.3	75.2	68.0	55.8		
	2%	WB	52.3	52.5	56.1	62.1	67.7	71.8	72.0	72.2	69.9	65.8	57.1	51.0		
		MCDB	57.2	58.3	64.8	74.2	76.7	80.6	80.1	79.9	77.1	73.7	63.3	54.8		
	5%	WB	49.5	50.5	53.2	60.2	65.3	69.7	70.6	70.3	67.8	63.9	53.5	49.4		
		MCDB	54.0	57.2	61.9	71.9	75.5	79.2	80.3	80.2	77.2	71.8	59.9	53.1		
	10%	WB	47.7	48.7	51.0	58.1	62.8	67.5	68.9	68.3	64.8	61.5	51.7	48.1		
		MCDB	51.2	55.2	60.4	68.0	72.3	77.1	79.8	79.1	74.1	68.9	59.8	51.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.1	21.7	23.4	24.8	25.2	26.4	28.7	28.7	26.0	26.0	20.1	15.1		
		MCDBR	23.1	29.2	34.5	34.4	30.0	30.6	32.1	33.2	32.0	32.1	27.2	18.9		
	5% WB	MCWBR	18.4	19.4	24.6	20.2	12.7	10.8	10.0	10.0	11.4	19.6	17.2	14.7		
		MCWBR	22.9	24.8	32.4	30.6	26.2	26.3	27.1	27.5	26.9	29.0	25.2	15.5		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.343	0.384	0.425	0.431	0.428	0.418	0.417	0.403	0.376	0.350	0.319		
	taud		2.434	2.331	2.230	2.129	2.158	2.215	2.252	2.263	2.288	2.342	2.360	2.431		
	Ebn at Noon		262	271	271	267	269	269	271	267	262	255	245	250		
	Edh at Noon		25	32	40	47	47	44	43	41	37	31	26	23		
(44) All-Sky Solar Radiation	RadAvg		545	789	1149	1495	1816	2103	2204	1944	1396	973	609	493		
	RadStd		63	88	145	124	167	117	133	137	78	98	66	65		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-142	+236	+122

Nomenclature: See separate page