

PESCARA, ItalyWMO: **162300**Lat: **42.432N**Lon: **14.181E**Elev: **48**StdP: **14.67**Time Zone: **1.00 (EUC)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.9	31.4	19.2	14.5	37.0	21.6	16.3	36.9	24.7	58.4	20.9	56.7	4.8	200	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	91.6	73.2	89.4	72.7	87.3	72.5	77.2	86.2	75.6	84.8	74.2	83.6	8.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.8	130.8	82.6	72.9	122.4	81.5	71.2	115.3	80.8	40.7	86.5	39.1	84.7	37.7	83.9	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	19.9	16.1	13.2	24.4	98.4	2.7	4.5	22.4	101.6	20.8	104.2	19.3	106.7	17.3	110.0	
(5)				22.8	80.2	2.6	2.0	20.9	81.6	19.4	82.7	18.0	83.8	16.1	85.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.4	44.5	45.6	50.3	56.1	63.4	71.4	75.6	75.1	68.5	61.1	53.6	46.5
	DBStd	12.17	5.30	6.06	5.72	4.77	4.72	5.18	4.17	3.97	5.10	4.94	6.00	5.56
	HDD50	573	187	148	62	7	0	0	0	0	0	1	30	138
	HDD65	3078	636	542	456	270	87	9	0	0	22	137	344	575
	CDD50	3999	16	26	72	189	415	642	792	779	554	346	139	29
	CDD65	1031	0	0	1	3	37	201	327	314	126	17	4	1
	CDH74	10311	0	1	11	20	300	2034	3694	3200	944	90	16	1
	CDH80	3558	0	0	2	1	44	634	1470	1179	217	11	0	0
Wind	WSAvg	5.2	4.9	5.5	5.9	5.5	5.2	5.3	5.5	5.1	5.1	4.6	4.6	5.1
Precipitation	PrecAvg	27.4	2.2	2.0	2.5	2.3	1.4	1.7	1.4	2.0	2.4	2.8	3.0	3.4
	PrecMax	38.1	6.2	5.1	6.1	8.7	7.0	7.0	4.3	6.1	8.7	7.0	7.0	13.5
	PrecMin	14.3	0.0	0.2	0.4	0.1	0.1	0.1	0.0	0.0	0.5	0.2	0.5	0.2
	PrecStd	5.6	1.7	1.3	1.5	2.2	1.3	1.7	1.2	1.5	2.0	1.8	1.7	2.7
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	68.0	74.9	77.0	84.3	91.7	95.3	96.9	90.3	81.4	76.7
MCWB			53.5	53.7	58.6	60.7	68.3	72.2	74.4	72.3	70.3	64.8	61.3	56.7
2%		DB	61.9	63.9	68.4	71.9	80.4	88.7	91.8	91.1	84.6	76.4	71.0	64.6
		MCWB	50.7	51.7	54.9	59.1	67.2	71.9	73.7	73.0	70.3	64.5	58.9	53.4
5%		DB	57.6	60.4	64.6	69.6	77.1	86.1	89.7	88.2	82.2	73.4	66.6	60.2
		MCWB	48.8	50.3	53.3	58.2	65.2	71.4	73.0	73.3	69.9	63.7	57.5	50.7
10%		DB	53.9	57.1	62.0	66.6	74.8	83.9	87.5	86.2	79.1	71.2	64.1	56.8
		MCWB	46.8	49.0	52.5	56.6	63.9	70.9	72.6	72.8	68.3	62.8	56.5	49.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.7	55.3	59.3	63.8	71.0	78.1	79.5	79.9	75.6	69.5	63.0	57.8
		MCDB	64.5	62.5	69.6	71.2	80.1	85.5	88.2	86.8	82.3	74.9	69.1	69.0
	2%	WB	52.0	53.0	56.5	61.4	68.7	75.4	77.1	77.3	73.1	67.3	60.9	54.5
		MCDB	60.1	60.3	64.5	69.0	77.5	83.9	87.1	85.9	80.7	73.0	67.6	62.2
	5%	WB	49.9	51.5	54.9	59.6	66.9	73.6	75.5	75.6	71.3	65.6	59.3	52.3
		MCDB	55.9	58.3	61.9	66.7	74.8	82.5	85.7	84.4	79.1	71.1	65.6	58.5
	10%	WB	48.1	49.9	53.4	58.0	65.1	71.9	74.0	74.2	69.5	63.9	57.4	50.4
		MCDB	53.3	55.8	60.3	64.7	72.6	81.7	84.3	83.3	77.4	69.2	63.1	55.3
Mean Daily Temperature Range	5% DB	MDBR	16.1	16.8	17.6	17.9	18.2	19.5	19.8	19.7	18.5	16.8	15.9	16.4
		MCDBR	21.7	21.7	23.2	22.3	22.3	23.0	23.7	23.4	21.8	20.8	19.3	20.8
		MCWBR	14.3	13.2	13.4	12.6	12.7	12.1	12.9	12.7	12.3	12.8	12.1	13.3
	5% WB	MCDBR	18.6	18.4	19.9	19.1	19.7	20.6	21.0	20.4	19.4	18.0	16.3	17.7
		MCWBR	13.3	12.5	13.1	12.4	12.3	12.0	12.5	12.4	12.2	12.4	11.3	12.7
Clear-Sky Solar Irradiance	taub	0.343	0.367	0.401	0.444	0.449	0.446	0.440	0.440	0.424	0.398	0.371	0.342	
	taud	2.434	2.346	2.260	2.155	2.200	2.255	2.280	2.289	2.318	2.363	2.381	2.442	
	Ebn at Noon	251	262	266	262	264	264	264	260	255	247	236	239	
	Edh at Noon	25	31	38	46	45	43	41	40	36	31	26	23	
All-Sky Solar Radiation	RadAvg	514	764	1160	1514	1854	2099	2166	1912	1385	938	587	462	
	RadStd	65	84	123	135	143	114	111	118	82	90	60	64	