

PESCARA, Italy

WMO: 162300

Lat: 42.432N

Lon: 14.181E

Elev: 15

StdP: 101.15

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.7	-0.3	-7.1	2.1	2.8	-5.8	2.3	2.7	11.1	14.6	9.4	13.7	2.2	200	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	33.1	22.9	31.9	22.6	30.7	22.5	25.1	30.1	24.2	29.3	23.5	28.7	3.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	18.7	28.1	22.7	17.5	27.5	21.8	16.5	27.1	76.8	30.3	73.1	29.3	69.9	28.8	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.9	7.2	5.9	DB	-4.2	36.9	1.5	2.5	-5.3	38.7	-6.2	40.1	-7.0	41.5	-8.1	43.3	
			WB	-5.1	26.8	1.4	1.1	-6.2	27.5	-7.0	28.2	-7.8	28.8	-8.8	29.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	6.9	7.6	10.2	13.4	17.4	21.9	24.2	24.0	20.3	16.2	12.0	8.0
	DBStd	6.76	2.94	3.37	3.18	2.65	2.62	2.88	2.31	2.21	2.83	2.74	3.33	3.09
	HDD10.0	318	104	82	34	4	0	0	0	0	0	1	17	77
	HDD18.3	1710	353	301	253	150	48	5	0	0	12	76	191	319
	CDD10.0	2222	9	14	40	105	231	357	440	433	308	192	77	16
	CDD18.3	573	0	0	1	2	21	112	182	174	70	9	2	1
	CDH23.3	5728	0	1	6	11	167	1130	2052	1778	524	50	9	1
	CDH26.7	1977	0	0	1	1	24	352	817	655	121	6	0	0
Wind	WSAvg	2.3	2.2	2.5	2.6	2.4	2.3	2.4	2.5	2.3	2.3	2.0	2.1	2.3
Precipitation	PrecAvg	695	56	52	64	58	36	43	36	51	61	72	76	87
	PrecMax	968	158	129	155	221	178	179	109	156	220	178	178	342
	PrecMin	363	1	5	9	3	3	2	0	0	13	4	12	4
	PrecStd	143	42	32	37	55	32	42	31	38	51	46	44	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	20.0	23.8	25.0	29.1	33.1	35.2	36.1	32.4	27.4	24.8	21.3
		MCWB	11.9	12.0	14.8	16.0	20.2	22.3	23.6	22.4	21.3	18.2	16.3	13.7
	2%	DB	16.6	17.7	20.2	22.2	26.9	31.5	33.2	32.8	29.2	24.7	21.7	18.1
		MCWB	10.4	11.0	12.7	15.0	19.5	22.2	23.2	22.8	21.3	18.1	14.9	11.9
	5%	DB	14.2	15.8	18.1	20.9	25.0	30.0	32.0	31.2	27.9	23.0	19.2	15.7
		MCWB	9.3	10.2	11.8	14.6	18.4	21.9	22.8	23.0	21.1	17.6	14.2	10.4
	10%	DB	12.2	13.9	16.7	19.2	23.8	28.8	30.9	30.1	26.2	21.8	17.8	13.8
		MCWB	8.2	9.4	11.4	13.7	17.7	21.6	22.6	22.7	20.2	17.1	13.6	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	12.9	15.2	17.6	21.7	25.6	26.4	26.6	24.2	20.8	17.2	14.3
		MCDB	18.0	16.9	20.9	21.8	26.7	29.7	31.2	30.4	27.9	23.8	20.6	20.6
	2%	WB	11.1	11.6	13.6	16.3	20.4	24.1	25.0	25.2	22.9	19.6	16.1	12.5
		MCDB	15.6	15.7	18.1	20.6	25.3	28.8	30.6	30.0	27.1	22.8	19.8	16.8
	5%	WB	9.9	10.8	12.7	15.3	19.4	23.1	24.2	24.2	21.8	18.6	15.1	11.3
		MCDB	13.3	14.6	16.6	19.3	23.8	28.1	29.8	29.1	26.2	21.7	18.7	14.7
	10%	WB	8.9	9.9	11.9	14.5	18.4	22.2	23.3	23.4	20.8	17.7	14.1	10.2
		MCDB	11.8	13.2	15.7	18.2	22.6	27.6	29.0	28.5	25.2	20.7	17.3	12.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.3	9.8	10.0	10.1	10.8	11.0	10.9	10.3	9.3	8.9	9.1
		MCDBR	12.1	12.0	12.9	12.4	12.4	12.8	13.2	13.0	12.1	11.6	10.7	11.6
		MCWBR	7.9	7.3	7.5	7.0	7.1	6.7	7.2	7.0	6.8	7.1	6.7	7.4
	5% WB	MCDBR	10.3	10.2	11.0	10.6	10.9	11.4	11.7	11.3	10.8	10.0	9.0	9.9
		MCWBR	7.4	6.9	7.3	6.9	6.8	6.7	6.9	6.9	6.8	6.9	6.3	7.1
Clear-Sky Solar Irradiance	taub	0.343	0.367	0.401	0.444	0.449	0.446	0.440	0.440	0.424	0.398	0.371	0.342	
	taud	2.434	2.346	2.260	2.155	2.200	2.255	2.280	2.289	2.318	2.363	2.381	2.442	
	Ebn at Noon	790	825	837	825	831	832	833	821	805	779	743	755	
	Edh at Noon	78	99	121	145	142	135	130	125	114	97	82	72	
All-Sky Solar Radiation	RadAvg	1.62	2.41	3.66	4.77	5.84	6.62	6.83	6.03	4.37	2.96	1.85	1.46	
	RadStd	0.21	0.27	0.39	0.43	0.45	0.36	0.35	0.37	0.26	0.28	0.19	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-127	-233	+148	N/A
(47)	Regional (19 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-79	+131	+68

Nomenclature: See separate page