

TERMOLI, Italy

WMO: 162320

Lat: 42.004N

Lon: 14.996E

Elev: 144

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.1	39.6	21.5	16.2	43.9	25.4	19.5	45.5	49.4	42.8	45.7	42.9	21.5	280	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	90.8	76.8	88.3	77.2	86.4	76.8	82.5	86.6	80.9	85.4	79.3	84.1	7.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.2	163.2	85.7	79.5	153.9	84.7	77.7	144.8	83.5	46.6	87.1	44.8	85.4	43.0	84.0	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
39.2	32.3	27.6	DB	34.2	98.9	2.1	3.7	32.6	101.5	31.4	103.6	30.2	105.7	28.7	108.3
			WB	30.1	85.3	0.8	2.6	29.5	87.1	29.0	88.6	28.6	90.1	27.9	92.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	49.7	49.9	54.4	59.8	66.9	75.2	80.4	79.8	73.3	65.9	58.2	51.7
	DBStd	12.02	4.96	5.60	5.56	4.44	4.71	5.65	4.36	3.86	5.13	4.76	5.28	4.72
	HDD50	193	66	62	21	2	0	0	0	0	0	0	8	34
	HDD65	2101	475	422	333	164	33	3	0	0	4	46	209	412
	CDD50	5251	56	60	156	295	525	756	943	925	699	494	254	88
	CDD65	1684	0	0	3	7	93	309	478	460	253	75	6	0
	CDH74	13221	0	0	16	18	215	2187	4881	4403	1372	122	7	0
	CDH80	3870	0	0	3	3	19	567	1652	1319	299	8	0	0
(14) Wind	WSAvg	10.4	12.8	13.2	11.6	9.5	9.3	8.1	8.1	8.4	10.0	10.8	11.2	12.6
(15) Precipitation	PrecAvg	17.0	1.5	1.1	1.2	1.4	1.1	0.9	0.9	0.9	2.0	2.0	2.2	1.9
	PrecMax	25.3	5.0	2.7	2.6	2.4	2.9	4.0	5.2	3.7	4.9	6.1	5.6	4.6
	PrecMin	9.5	0.0	0.1	0.0	0.3	0.2	0.0	0.1	0.1	0.6	0.0	0.5	0.3
	PrecStd	3.7	1.1	0.6	0.6	0.6	0.7	0.9	1.0	0.8	1.0	1.5	1.2	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.0	67.6	73.8	75.6	82.5	91.7	95.7	95.9	91.2	80.5	73.8	67.8
		MCWB	53.4	53.4	61.4	58.6	70.7	72.2	73.7	70.0	69.7	67.1	63.9	59.7
	2%	DB	61.9	62.6	67.7	71.6	78.6	87.8	91.2	89.7	86.4	77.1	69.7	62.9
		MCWB	54.1	53.3	58.8	59.1	70.2	77.2	78.7	77.7	74.1	67.9	61.4	55.0
	5%	DB	59.1	59.5	64.3	68.4	76.4	85.7	89.3	87.8	83.0	74.9	67.5	60.6
		MCWB	52.6	52.1	56.5	59.8	68.9	76.5	78.2	77.6	73.5	66.8	60.5	54.2
	10%	DB	57.0	57.3	61.6	66.3	73.8	83.2	87.1	86.0	80.7	72.3	64.8	58.3
		MCWB	51.5	51.1	55.2	59.5	67.1	74.9	77.5	77.1	72.1	66.1	59.0	53.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	56.9	63.1	66.8	74.8	83.2	85.4	84.2	80.0	72.8	67.3	60.2
		MCDB	61.8	62.1	68.5	70.7	78.5	86.4	89.4	87.3	84.5	76.9	71.2	65.5
	2%	WB	55.4	54.9	60.1	63.8	72.2	80.7	83.1	81.9	77.6	70.2	64.0	57.5
		MCDB	59.5	60.1	65.0	67.3	76.5	84.9	87.6	85.8	83.0	74.1	67.5	60.4
	5%	WB	53.5	53.4	58.2	61.9	70.0	78.8	81.3	80.5	75.4	68.8	61.8	55.6
		MCDB	58.1	58.1	62.6	65.6	74.5	83.5	86.0	85.1	80.7	72.7	65.6	59.0
	10%	WB	51.9	52.0	56.4	60.2	68.3	76.4	79.4	78.9	73.3	67.2	59.8	53.7
		MCDB	55.7	56.2	60.7	64.2	73.1	81.3	84.4	83.8	78.7	71.1	64.0	57.7
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	8.5	9.2	9.9	9.8	10.1	10.0	10.2	9.8	9.0	8.6	7.9
		MCDBR	11.9	12.2	12.9	13.4	11.6	12.0	12.1	12.0	12.1	11.7	11.2	10.6
	5% WB	MCWBR	9.0	8.6	9.5	10.0	10.3	11.3	14.2	12.9	10.5	8.9	8.7	8.5
		MCWBR	10.3	10.5	11.1	11.1	10.4	10.5	10.7	10.0	10.5	10.2	10.2	9.0
(40) Clear-Sky Solar Irradiance	taub		0.341	0.364	0.395	0.437	0.437	0.434	0.432	0.431	0.417	0.391	0.367	0.341
		taud	2.454	2.368	2.284	2.175	2.239	2.289	2.301	2.310	2.340	2.395	2.405	2.456
	Ebn at Noon		253	264	268	264	267	268	267	263	258	251	239	242
		Edh at Noon	24	31	38	45	43	42	41	39	35	30	26	23
(44) All-Sky Solar Radiation	RadAvg		531	783	1199	1590	1954	2191	2245	1984	1434	979	613	478
	RadStd		65	83	120	133	136	113	112	120	82	89	57	64

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.77	N/A	N/A	N/A	N/A	-1.24	N/A	-185	+281	+135

Nomenclature: See separate page