

TERMOLI, Italy

WMO: 162320

Lat: 42.004N

Lon: 14.996E

Elev: 44

StdP: 100.80

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	4.2	-5.8	2.3	6.6	-3.7	2.8	7.5	22.1	6.0	20.4	6.0	9.6	280	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	32.7	24.9	31.3	25.1	30.2	24.9	28.1	30.3	27.2	29.7	26.3	29.0	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	23.3	29.8	26.4	22.0	29.3	25.4	20.7	28.6	90.6	30.6	86.3	29.7	82.2	28.9	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	14.4	12.3	1.2	37.1	1.2	2.0	0.4	38.6	-0.3	39.8	-1.0	40.9	-1.8	42.4		
			-1.0	29.6	0.5	1.4	-1.4	30.6	-1.6	31.5	-1.9	32.3	-2.3	33.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	9.8	10.0	12.4	15.4	19.4	24.0	26.9	26.6	22.9	18.9	14.6	11.0
	DBStd	6.68	2.75	3.11	3.09	2.46	2.61	3.14	2.42	2.14	2.85	2.65	2.93	2.62
	HDD10.0	107	37	34	12	1	0	0	0	0	0	0	4	19
	HDD18.3	1167	264	234	185	91	18	2	0	0	2	26	116	229
	CDD10.0	2917	31	33	87	164	292	420	524	514	388	274	141	49
	CDD18.3	936	0	0	2	4	52	172	266	256	141	42	3	0
	CDH23.3	7345	0	0	9	10	119	1215	2712	2446	762	68	4	0
	CDH26.7	2150	0	0	2	2	11	315	918	733	166	4	0	0
Wind	WSAvg	4.7	5.7	5.9	5.2	4.2	4.2	3.6	3.6	3.8	4.5	4.8	5.0	5.6
Precipitation	PrecAvg	433	38	27	30	35	27	23	23	23	52	51	56	47
	PrecMax	643	126	69	66	61	73	102	133	94	125	154	141	118
	PrecMin	241	1	2	0	8	5	1	3	2	16	1	13	8
	PrecStd	94	28	16	16	15	17	22	25	20	25	37	31	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	19.8	23.2	24.2	28.1	33.1	35.4	35.5	32.9	27.0	23.2	19.9
		MCWB	11.9	11.9	16.3	14.8	21.5	22.3	23.1	21.1	20.9	19.5	17.7	15.4
	2%	DB	16.6	17.0	19.8	22.0	25.9	31.0	32.9	32.0	30.2	25.0	21.0	17.2
		MCWB	12.3	11.8	14.9	15.1	21.2	25.1	26.0	25.4	23.4	19.9	16.3	12.8
	5%	DB	15.1	15.3	18.0	20.2	24.7	29.9	31.8	31.0	28.3	23.8	19.7	15.9
		MCWB	11.5	11.2	13.6	15.5	20.5	24.7	25.6	25.3	23.0	19.4	15.9	12.3
	10%	DB	13.9	14.0	16.4	19.0	23.2	28.5	30.6	30.0	27.0	22.4	18.2	14.6
		MCWB	10.8	10.6	12.9	15.3	19.5	23.8	25.3	25.0	22.3	18.9	15.0	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	13.8	17.3	19.3	23.8	28.4	29.7	29.0	26.7	22.6	19.6	15.7
		MCDB	16.6	16.7	20.3	21.5	25.8	30.2	31.9	30.7	29.2	24.9	21.8	18.6
	2%	WB	13.0	12.7	15.6	17.6	22.3	27.1	28.4	27.7	25.3	21.2	17.8	14.2
		MCDB	15.3	15.6	18.4	19.6	24.7	29.4	30.9	29.9	28.3	23.4	19.7	15.8
	5%	WB	12.0	11.9	14.5	16.6	21.1	26.0	27.4	27.0	24.1	20.4	16.6	13.1
		MCDB	14.5	14.5	17.0	18.7	23.6	28.6	30.0	29.5	27.0	22.6	18.6	15.0
	10%	WB	11.1	11.1	13.5	15.7	20.2	24.7	26.3	26.1	23.0	19.6	15.5	12.0
		MCDB	13.2	13.4	15.9	17.9	22.8	27.4	29.1	28.8	26.0	21.7	17.8	14.3
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.7	5.1	5.5	5.5	5.6	5.5	5.7	5.5	5.0	4.8	4.4
		MCDBR	6.6	6.8	7.2	7.5	6.4	6.7	6.7	6.7	6.5	6.2	5.9	
		MCWBR	5.0	4.8	5.3	5.6	5.7	6.3	7.9	7.2	5.8	5.0	4.9	4.7
	5% WB	MCDBR	5.7	5.8	6.2	6.1	5.8	5.8	6.0	5.5	5.8	5.7	5.7	5.0
		MCWBR	4.6	4.7	5.3	5.6	5.7	6.3	7.8	6.9	6.0	4.9	5.1	4.4
Clear-Sky Solar Irradiance	taub		0.341	0.364	0.395	0.437	0.437	0.434	0.432	0.431	0.417	0.391	0.367	0.341
	taud		2.454	2.368	2.284	2.175	2.239	2.289	2.301	2.310	2.340	2.395	2.405	2.456
	Ebn at Noon		799	832	846	833	842	844	841	830	814	792	755	763
	Edh at Noon		77	98	119	142	137	131	128	123	111	94	81	72
All-Sky Solar Radiation	RadAvg		1.67	2.47	3.78	5.01	6.16	6.91	7.08	6.25	4.52	3.09	1.93	1.51
	RadStd		0.21	0.26	0.38	0.42	0.43	0.35	0.35	0.38	0.26	0.28	0.18	0.20

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.43	N/A	N/A	N/A	-0.69	N/A	-103	+156	+75

Nomenclature: See separate page