

CAMPOBASSO, Italy

WMO: 162520

Lat: 41.5634N

Lon: 14.6554E

Elev: 807

StdP: 92.00

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-2.8	-12.2	1.4	5.3	-9.3	1.9	3.9	15.2	5.3	13.0	4.6	3.0	340	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	31.9	18.5	30.1	18.5	28.8	18.2	21.7	26.4	20.8	25.6	20.1	25.1	1.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.4	16.6	23.2	19.4	15.6	22.8	18.4	14.7	22.4	67.6	26.6	64.2	25.8	61.3	24.5	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.2	7.5	-5.9	34.4	2.0	1.8	-7.3	35.7	-8.5	36.7	-9.6	37.8	-11.0	39.1		
(5)			-6.7	23.1	1.7	1.6	-7.9	24.2	-8.9	25.2	-9.9	26.0	-11.1	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.1	4.5	4.8	7.7	11.3	15.4	20.2	22.9	23.1	17.8	14.1	9.5	5.8
	DBStd	7.56	3.65	3.88	4.14	3.70	3.77	4.03	3.46	3.35	3.63	3.77	3.80	3.62
	HDD10.0	648	174	150	94	27	3	0	0	0	1	10	53	135
	HDD18.3	2336	431	380	329	213	107	26	4	3	52	136	266	388
	CDD10.0	1790	2	3	23	66	170	306	401	405	234	138	37	5
	CDD18.3	437	0	0	0	1	15	82	147	150	36	6	0	0
	CDH23.3	2893	0	0	0	2	56	517	1096	1066	147	9	1	0
CDH26.7	881	0	0	0	0	8	131	363	349	30	0	0	0	
Wind	WSAvg	2.0	2.1	2.4	2.5	1.9	1.9	1.9	1.9	1.6	1.7	1.7	2.0	2.2
Precipitation	PrecAvg	634	53	57	50	54	49	34	32	41	46	58	83	70
	PrecMax	838	126	144	141	188	186	93	121	122	107	254	223	180
	PrecMin	416	3	7	14	6	3	2	0	0	0	3	17	3
	PrecStd	123	36	36	26	38	35	23	28	29	30	49	50	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	15.7	19.1	23.1	27.8	31.9	33.8	34.8	29.9	24.7	19.7	15.0
		MCWB	8.2	7.5	10.6	13.6	17.6	19.4	18.8	18.6	17.5	14.9	12.1	9.8
	2%	DB	12.0	13.1	17.0	20.7	24.7	29.9	32.0	32.0	27.0	22.5	17.1	13.0
		MCWB	7.8	7.0	10.0	12.1	16.3	18.9	18.4	18.5	16.9	14.8	11.7	9.5
	5%	DB	10.7	11.2	15.1	18.3	22.9	28.1	30.2	30.1	24.9	20.9	15.8	11.7
		MCWB	7.2	6.6	9.4	11.3	15.2	18.1	18.4	18.4	16.6	14.0	11.4	8.4
	10%	DB	9.1	9.8	13.2	16.8	21.1	26.2	28.8	28.6	23.1	19.1	14.2	10.2
		MCWB	6.5	6.4	8.6	11.0	14.5	17.6	18.2	18.0	16.1	14.0	10.9	7.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	10.2	12.9	15.8	19.6	22.6	23.0	22.7	20.6	18.0	15.1	12.6
		MCDB	12.2	12.5	16.0	20.1	23.1	27.7	28.0	26.7	24.0	20.7	17.2	13.5
	2%	WB	9.0	8.9	11.5	14.1	18.0	21.2	21.7	21.5	19.3	16.7	13.3	10.5
		MCDB	10.9	10.6	14.6	17.4	22.4	26.0	26.7	25.7	22.5	19.4	15.6	11.8
	5%	WB	8.1	8.0	10.4	13.0	16.7	20.1	20.8	20.6	18.4	15.9	12.3	9.4
		MCDB	9.6	9.9	13.3	16.4	21.1	25.2	25.9	25.3	22.0	18.8	14.4	10.7
	10%	WB	7.1	7.0	9.5	11.9	15.5	19.1	19.9	19.8	17.5	15.0	11.3	8.4
		MCDB	8.7	9.1	12.2	15.3	19.8	24.4	25.4	25.0	21.2	17.5	13.4	9.9
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	6.3	6.8	7.3	7.9	8.4	8.5	6.9	6.2	4.8	4.5
		MCDBR	6.4	7.4	8.5	8.6	8.6	9.1	9.4	9.4	8.5	8.0	6.4	5.7
		MCWBR	4.1	4.5	4.6	4.8	4.6	4.9	4.4	4.1	3.8	3.9	4.0	3.9
	5% WB	MCDBR	5.5	6.1	7.5	7.6	8.2	8.6	8.9	8.8	7.7	7.0	5.7	4.6
		MCWBR	4.4	4.7	4.7	4.9	5.1	5.1	4.7	4.8	4.5	4.1	4.3	4.2
Clear-Sky Solar Irradiance	taub	0.301	0.322	0.351	0.387	0.388	0.386	0.384	0.383	0.373	0.346	0.327	0.304	
	taud	2.508	2.436	2.357	2.262	2.303	2.337	2.349	2.361	2.394	2.463	2.474	2.509	
	Ebn at Noon	857	887	895	883	888	887	885	876	861	847	813	821	
	Edh at Noon	73	91	110	130	128	124	122	117	105	88	75	68	
All-Sky Solar Radiation	RadAvg	1.70	2.45	3.65	4.84	5.91	6.74	6.99	6.21	4.44	3.09	1.96	1.55	
	RadStd	0.21	0.26	0.42	0.43	0.47	0.36	0.41	0.42	0.28	0.30	0.20	0.21	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.44	N/A	N/A	N/A	N/A	-0.34	N/A	-91	+141	+66

Nomenclature: See separate page