

AMENDOLA, Italy

WMO: 162610

Lat: 41.541N

Lon: 15.718E

Elev: 56

StdP: 100.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	0.5	-6.2	2.3	5.7	-4.2	2.7	5.1	13.8	8.4	12.3	8.6	3.2	300	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	36.0	22.4	34.3	22.0	32.9	21.7	25.0	30.2	24.1	29.7	23.4	29.2	5.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	18.8	26.9	22.8	17.6	26.3	21.8	16.6	25.8	76.3	29.9	72.7	29.6	69.8	29.1	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.9	8.7	-3.7	40.0	1.2	1.8	-4.5	41.3	-5.2	42.4	-5.9	43.4	-6.7	44.7		
			-4.2	27.3	0.9	1.4	-4.9	28.3	-5.4	29.1	-5.9	29.9	-6.6	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	7.7	8.0	10.4	13.1	18.9	23.4	25.9	26.0	21.4	17.5	12.5	8.9
	DBStd	7.27	2.92	2.97	3.41	2.83	2.81	3.40	2.53	2.71	2.89	2.94	3.49	3.09
	HDD10.0	267	82	69	36	8	0	0	0	0	0	17	56	
	HDD18.3	1578	329	289	246	159	27	3	0	6	51	176	292	
	CDD10.0	2526	11	14	48	99	274	401	492	497	342	233	92	23
	CDD18.3	796	0	0	1	1	44	154	234	238	97	25	1	0
	CDH23.3	7994	0	0	8	9	432	1659	2561	2491	701	131	2	0
	CDH26.7	3552	0	0	2	1	108	744	1246	1228	206	17	0	0
Wind	WSAvg	3.9	4.2	4.3	4.0	3.9	3.7	4.0	4.2	3.8	3.7	3.2	3.4	3.9
Precipitation	PrecAvg	459	39	31	37	43	32	33	19	25	52	44	56	52
	PrecMax	745	151	71	81	102	88	93	55	98	203	158	105	183
	PrecMin	287	4	5	0	11	1	1	2	0	12	0	7	2
	PrecStd	100	35	19	23	21	21	25	14	27	40	35	29	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	19.0	23.9	24.8	31.5	36.5	38.7	38.7	33.0	28.8	22.9	18.8
		MCWB	13.7	12.6	15.4	16.1	20.0	23.0	21.9	23.0	21.8	20.4	16.9	14.3
	2%	DB	15.7	16.8	20.2	22.2	29.2	34.8	36.0	36.1	30.8	26.2	20.9	16.8
		MCWB	12.2	11.7	13.9	14.7	18.7	22.1	22.3	22.2	20.7	18.8	16.3	13.6
	5%	DB	14.0	15.2	18.2	20.5	27.8	32.9	34.1	34.2	29.0	24.8	19.2	15.1
		MCWB	11.0	11.0	12.9	14.3	18.2	21.3	21.9	22.0	20.1	18.3	15.4	12.2
	10%	DB	12.2	13.5	16.2	19.0	25.9	31.0	32.3	32.8	27.2	23.0	17.8	13.8
		MCWB	9.8	10.1	12.3	13.6	17.4	20.8	21.6	21.8	19.9	17.6	14.7	11.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	14.1	16.6	17.5	21.5	25.4	26.1	26.2	24.1	22.3	19.6	15.2
		MCDB	16.7	16.5	21.5	21.0	27.4	31.7	30.6	30.2	28.2	25.4	20.9	17.3
	2%	WB	12.7	12.8	15.0	16.3	20.3	24.1	24.8	25.1	23.0	21.0	17.2	14.0
		MCDB	14.9	15.5	19.0	19.9	25.9	30.6	30.4	29.6	26.7	23.6	19.4	16.1
	5%	WB	11.5	11.6	13.8	15.3	19.5	23.1	23.9	24.2	22.1	19.8	16.0	12.8
		MCDB	13.6	14.4	17.3	19.1	24.9	29.4	29.9	29.3	25.9	22.8	18.2	14.6
	10%	WB	10.4	10.6	12.7	14.3	18.6	22.1	23.1	23.4	21.2	18.8	15.1	11.8
		MCDB	11.8	13.0	15.8	17.8	23.8	28.3	29.2	29.3	25.1	21.5	17.1	13.5
Mean Daily Temperature Range	5% DB	MDBR	7.8	9.3	10.4	10.8	12.4	13.1	12.9	12.8	11.1	10.5	8.4	7.5
		MCDBR	9.7	11.6	13.3	13.4	15.4	15.5	15.1	14.8	13.1	12.2	9.6	9.0
		MCWBR	6.8	7.5	8.1	7.5	6.7	6.3	6.0	6.3	6.1	6.4	6.0	6.5
	5% WB	MCDBR	8.4	10.2	11.9	11.1	13.2	13.6	13.2	13.7	11.3	10.7	8.1	7.7
		MCWBR	6.4	7.2	8.0	7.0	6.7	6.4	6.1	6.7	6.1	6.4	5.9	6.1
Clear-Sky Solar Irradiance	taub	0.346	0.373	0.408	0.467	0.463	0.456	0.452	0.453	0.439	0.399	0.373	0.347	
	taud	2.416	2.310	2.208	2.045	2.125	2.187	2.208	2.209	2.239	2.342	2.362	2.414	
	Ebn at Noon	793	823	833	806	820	825	824	810	793	783	749	757	
	Edh at Noon	81	104	129	162	154	145	140	136	124	100	85	75	
All-Sky Solar Radiation	RadAvg	1.72	2.47	3.75	5.00	6.13	6.89	7.08	6.26	4.47	3.13	1.99	1.54	
	RadStd	0.22	0.26	0.38	0.41	0.43	0.35	0.37	0.42	0.27	0.28	0.17	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-100	+144	+67

Nomenclature: See separate page